



**IEA**  
**SOLAR R&D**

**INTERNATIONAL ENERGY AGENCY**

program  
to develop and test  
solar heating  
and cooling systems

**task III**  
**performance testing**  
**of solar collectors**

**results and analyses**  
**of IEA**  
**round robin testing**

**Kernforschungsanlage Jülich GmbH**  
**Jülich, Fed. Republic of Germany, December 1979**

RESULTS AND ANALYSES  
OF IEA  
ROUND ROBIN TESTING

Abstract

Two flat-plate collectors were subjected a round robin testing. Three procedures were applied to determine thermal performance. A total of 16 laboratories were engaged in the test. The testing facilities were situated in 12 different countries distributed over the northern hemisphere. The meteorological test conditions and systematic errors of the test facilities can fully account for the spread of round robin efficiency data.

The most pronounced contribution to systematic deviation is caused by the pyranometer. None of the procedures proved to be superior with respect to the data scatter.

The results from the applied procedures do compare very well.

This report is part of the work of the  
IEA Solar Heating and Cooling Program.

Task III: Performance Testing of Solar Collectors.

Subtask A: Development and Application of Standard  
Test Procedures for Determining Thermal  
Performance.

---

Document No. III.A.1

Distribution: Unrestricted

Additional copies can be ordered from:

H.D. Talarek  
IKP - Kernforschungsanlage Jülich GmbH  
Postfach 1913  
D-5170 Jülich

---

RESULTS AND ANALYSIS  
OF IEA ROUND ROBIN TESTING

Austrian Solar and Space Agency  
Vienna/Austria  
M. Bruck

Faculte Polytechnique de Mons  
Mons/Belgium  
A. Pilatte

Katholieke Universiteit Leuven  
Heverlee/Belgium  
W. Dutre

Technical University of Denmark  
Thermal Insulation Lab.  
Lyngby/Denmark  
S. Svendsen

Division of Building Research  
National Research Council  
Ottawa/Canada  
J.R. Sasaki

Solar Energy Branch  
IKP - Kernforschungsanlage Jülich  
Jülich/FRG  
J. Stein

Brown, Boveri & Cie AG  
Central Research Lab.  
Heidelberg/FRG  
H. Birnbreier

Technische Hochschule  
Stuttgart/FRG  
W. Schwaigerer

Solar Research Lab.  
The Government Industrial Research  
Institute Nagoya  
Nagoya/Japan  
S. Tanemura

Techn.-Physische Dienst  
TNO-TH  
Delft/Netherlands  
C. den Ouden

Institut Nacional de Tecnica Aero-  
special  
Madrid/Spain  
E. Mezquida

Statens Provningsanstalt  
Borås/Sweden  
H.E.B. Andersson

Eidgen. Institut für Reaktorforschung  
Wuerenlingen/Switzerland  
P. Kesselring

Solar Energy Unit  
University College  
Cardiff/United Kingdom  
W.B. Gillett

National Bureau of Standards  
Washington/USA  
E. Streed

Desert Sunshine Exposure Tests Inc.  
Phoenix, Arizona / USA  
W.T. Dokos

European Commission  
Joint Research Center Euratom  
Ispra/Italy  
E. Aranovitch

Table of Contents

	Seite
Preface	2
International Energy Agency	2
Solar Heating and Cooling Program	2
Task III - Performance Testing of Solar Collectors	3
1. Introduction	5
2. Collector performance	6
3. Collector Test Procedures	7
$\eta_0$ determination	9
$q_L$ determination	10
4. Collectors in the Test	10
5. Results and Analysis of Data	11
Modelling of the "optical efficiency"	15
Modelling of the thermal performance	17
6. Conclusions and Recommendations	22
7. References	24
8. Tables	25
Appendix A: The EIR method for collector testing	A 1
Appendix B: IAEA/CEC Round Robin Testing Format Sheets	A 7
Appendix C: Data: IEA-1 Collector, NBS Procedure	A19
Appendix D: Data: IEA-2 Collector, NBS Procedure	A33
Appendix E: Data: IEA-1 Collector, BSE Procedure, EIR Procedure	A47
Appendix F: Data: IEA-2 Collector, BSE Procedure, EIR Procedure	A61



## PREFACE

INTERNATIONAL ENERGY AGENCY

In order to strengthen cooperation in the vital area of energy policy, an Agreement on an International Energy Program was formulated among a number of industrialized countries in November 1974. The International Energy Agency (IEA) was established as an autonomous body within the Organization for Economic Cooperation and Development (OECD) to administer that agreement. Twenty countries are currently members of the IEA, with the Commission of the European Communities participating under a special agreement.

As one element of the International Energy Program, the participants undertake cooperative activities in energy research, development, and demonstration. A number of new and improved energy technologies which have the potential of making significant contributions to our energy needs were identified for collaborative efforts. The IEA Committee on Energy Research and Development (CRD), assisted by a small Secretariat, coordinates the energy research, development, and demonstrations program.

SOLAR HEATING AND COOLING PROGRAM

Solar Heating and Cooling was one of the technologies selected by the IEA for a collaborative effort. The objective was to undertake cooperative research, development, demonstrations and exchanges of information in order to advance the activities of all Participants in the field of solar heating and cooling systems. Several tasks were developed in key areas of solar heating and cooling. A formal Implementing Agreement for this Program, covering the contributions, obligations and rights of the Participants, as well as the scope of each task, was prepared and signed by 15 countries and the Commission of the European Communities. The overall program is managed by an Executive Committee, while the management of the sub-projects is the responsibility of Operating Agents who act on behalf of the other Participants.



The tasks of the IEA Solar Heating and Cooling Program and their respective Operating Agents are:

- I. Investigation of the Performance of Solar Heating and Cooling Systems -  
Technical University of Denmark
- II. Coordination of R & D on Solar Heating and Cooling Components -  
Agency of Industrial Science and Technology, Japan
- III. Performance Testing of Solar Collectors -  
Kernforschungsanlage Jülich, Federal Republic of Germany
- IV. Development of an Insulation Handbook and Instrumentation Package -  
United States Department of Energy
- V. Use of Existing Meteorological Information for Solar Energy Application -  
Swedish Meteorological and Hydrological Institute
- VI. Performance of Solar Heating, Cooling and Hot Water Systems Using  
Evacuated Collectors -  
United States Department of Energy
- VII. Central Solar Heating with Seasonal Storage -  
Swedish Council for Building Research

Collaboration in additional areas is likely to be considered as projects are completed or fruitful topics for cooperation identified.

### TASK III - PERFORMANCE TESTING OF SOLAR COLLECTORS

A wide variety of collector designs with a broad range of qualitative differences exists. Since the collector is the key component in an active solar system, performance testing is a vital task. The objective of Task III is to develop internationally accepted test procedures for determining the thermal performance as well as the reliability and durability of collectors. This project is also experimenting with the use of solar simulators to allow year-round testing of collectors.

The subtasks of this project are:

- A. Development and Application of Standard Test Procedures for Determining Thermal Performance
- B. Development of Reliability and Durability Test Procedures
- C. Investigation of the Potential of Solar Simulators



The following countries are Participants in Task III:

Austria, Belgium, Canada, Denmark, Federal Republic of Germany, Greece, Italy, Japan, The Netherlands, New Zealand, Spain, Sweden, Switzerland, United Kingdom, USA, and the Commission of the European Communities.

This report documents work carried out under subtask A of this task. The cooperative work and resulting report is described in the following section.

## 1. Introduction

The promotion of solar technology in recent years has made evident the need for standardized methods for use in rating solar collectors. Efforts in several countries have resulted in the development of procedures to determine the efficiency of the collector over a range of operating temperatures. While it is well recognized that collector performance is also dependent upon system characteristics, it is necessary to make thermal performance and durability/reliability data available at an intermediate stage for comparison of collectors and for system design.

Since the methods of testing collectors should be generally applicable, practical and provide guidance for precise and accurate measurements, one had to resort to compromise. This resulted in a situation where the procedure itself - meeting a number of contradicting requirements - became the object of both analytical and experimental investigations.

A round robin test program in the US /1/ was already under way when the IEA program was defined. Moreover, the IEA round robin test - being international in scope - provided the unique chance of an adoption of test procedures by many countries based on common experience. The program initiated was not confined to a particular procedure but the NBS-method published in 1974 /2/ formed a basis to start with. A second procedure, the BSE-method /3/, came into being in the course of the program. These procedures subjected to amendments and supplemented by additional tests were applied to two collectors. Although the test program was initiated in 1977, some collector procurement problems resulted in delaying the tests by some participants until the summer of 1978.

A total of 16 laboratories were engaged in the test. The testing facilities were situated in 12 different countries distributed over the northern hemisphere.

The recommendations given, the conclusions drawn and the success of the round robin testing are the outcome of the contributions which were made readily available by all the experts in the working group.

This report is based on this excellent spirit of collaboration and the willingness to share experiences.

## 2. Collector performance

The performance of flat-plate collectors is investigated under conditions where essentially no heat is either released or stored by the structure and by the heat transfer medium in it (equilibrium conditions).

Effects of geometry can be neglected and the thermal conditions of the collector system can be described by averaged temperatures /4/. The rate of energy extracted from the collector balances, the rate of radiative energy absorbed and of heat lost to a uniform environment. This state may be expressed as:

$$\frac{\dot{Q}_u}{A} = G \cdot (\tau\alpha)_e - U_L (T_p - T_a) \quad (1)$$

$\dot{Q}_u$  = rate of useful energy extracted (W)

A = aperture area of collector ( $m^2$ )

G = solar irradiance, in the plane of the collector per unit area ( $W/m^2$ )

$(\tau\alpha)_e$  = effective transmittance - absorptance product of the cover-absorber system

$U_L$  = heat transfer loss coefficient for the collector ( $W/m^2 \text{ } ^\circ C$ )

$T_p$  = average temperature of the absorber surface of the collector ( $^\circ C$ )

$T_a$  = ambient air temperature ( $^\circ C$ )

Since the plate temperature is difficult to access by measurements, at least by non-destructive test-methods, it is convenient to relate the performance to the temperature of the fluid. It was shown by Duffie and Beckmann /5/ that either the inlet temperature or a mean temperature can be an appropriate reference temperature. This results in two equations:

$$\frac{\dot{Q}_u}{A} = F' \cdot G \cdot (\tau\alpha)_e - F' \cdot U_L \cdot (T_m - T_a) \quad (2)$$

$$\frac{\dot{Q}_u}{A} = F_R \cdot G \cdot (\tau\alpha)_e - F_R \cdot U_L \cdot (T_i - T_a) \quad (3)$$

$F'$  = collector efficiency factor

$F_R$  = collector heat removal factor

$T_m$  = average temperature of fluid in the collector (arithmetic mean of inlet and outlet temperature for example)

$T_i$  = inlet temperature of the fluid  
 $T_o$  = outlet temperature of the fluid

Equation (3) is now a feature of the ASHRAE-method /6/, while equation (2) was specified in the NBS and BSE methods and was the agreed-on reference equation for the tests reported in the IEA program

These two equations are correlated by /5/:

$$F_R = F' \left( \frac{1-e^{-x}}{x} \right) \quad x = \frac{U_L \cdot F' \cdot A}{m_f \cdot C_p} \quad (4)$$

$m_f$  = mass flow rate of the fluid (kg/s)  
 $C_p$  = specific heat of transfer fluid (J/kg·°C)

The collector efficiency is defined as the ratio of the useful energy extracted to the incident solar energy as follows:

$$\eta = \frac{\dot{Q}_u}{A \cdot G} = F' \cdot (\tau\alpha)_e - F' \cdot U_L \frac{(T_m - T_a)}{G} \quad (5)$$

$$\eta = \eta_o - U_o \frac{(T_m - T_a)}{G} \quad (6)$$

$\eta_o$  =  $F' (\tau\alpha)_e$ , efficiency for  $T_m = T_a$   
 $U_o$  =  $F' U_L$ , global heat transfer coefficient ( $W/m^2 \cdot ^\circ C$ )

If values of  $\eta$  are plotted versus corresponding values of  $(T_m - T_a)/G$  this will result in a curve with a negative slope  $U_o$  and intercept  $\eta_o$ .

Equation (6) forms the basis of the test procedures.

### 3. Collector Test Procedures

In the round robin test there were actually two procedure applied: the NBS method and the BSE method. A third procedure, the EIR method (Switzerland) was used by only one participant. It uses statistical long time measurements and is described in detail in Appendix A.

Common to all these test methods is the determination of the steady state efficiency of the collector. Due to inherently given changes in solar irradiance - even for clear sky conditions - it is rather a quasi-steady state that is investigated. To exclude time-dependencies, integration and averaging over the period of measurements is required.

This results in a straight forward definition of the efficiency  $\eta$ :

$$\eta = \frac{\int_{t_1}^{t_2} \dot{m}_f \cdot C_p \cdot (T_o - T_i) dt}{A \cdot \int_{t_1}^{t_2} G dt} \quad (7)$$

Although the procedures are applicable for collectors which use either a liquid or air as the transfer fluid, the IEA round robin test was confined to liquid heating collectors.

During the time of the round robin test, procedures were supplemented and changed. Additional tests were added: The NBS-method was modified with a procedure to determine the time constant of the collector and the influence of varying angles of incidence of radiation on the collector's surface. With these amendments - preserving the essence of the NBS method the procedure has been adopted as Standard 93-77 /6/ by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). A similar development was recorded for the BSE procedure.

It should be noted that it was not necessary for laboratories to perform all parts of the test procedures but it was expected that the essential efficiency measurements would be made.

The NBS procedure is conducted with the collector exposed to solar radiation at all times (specifications for the use of a solar simulator are incorporated in ASHRAE 93-77) requiring a minimum irradiance of  $630 \text{ W/m}^2$  and quasi-steady state conditions. This implies not too many suitable days of testing for places with less favourable weather conditions. Since collector efficiency is influenced by a number of environmental parameters, reproducibility of measurements is only given within a limited band.

The requirements concerning the mounting and the location, the test conduct, the accuracy and calibration of instrumentation are all specified in the procedure. The aim is to conduct the test under exposure conditions which will minimize the scatter.

During the test, a variety of steady-state conditions are monitored. The fluid inlet temperature is selected at four values over the range of interest. The average fluid temperature, the ambient temperature and solar irradiance are monitored, the efficiency is calculated at each temperature according to (7) resulting in a fitted efficiency curve. Ordinary flat-plate collectors show a performance that is close to linear with a slight tendency to quadratic curve.

The BSE procedure is a combined indoor-outdoor test thought to avoid the constraints mentioned above. While the efficiency at an operating temperature near ambient is measured outdoors, the heat losses of the collectors are determined indoors. From these data an efficiency curve is constructed. Repeating (5) and (6) we obtain:

$$\frac{\dot{Q}_u}{A} = \eta_0 \cdot G - U_0 \cdot (T_m - T_a) \quad (8)$$

and it becomes obvious that the expression  $q_L = U_0 \cdot (T_m - T_a)$  can be interpreted as a heat loss rate.

Two separate measurements are required:

#### $\eta_0$ determination

The collector is run in a steady-state at a mean fluid temperature that is close to the ambient air temperature: the heat loss rate  $q_L$  tends to become zero and  $\eta_0$  can be determined.

$$\eta_0 = \frac{\dot{Q}_u}{G A} \quad (9)$$

Since it is not easy to meet the requirement  $T_m = T_a$  exactly the BSE procedure provides for deviations up to 10 °C - with respective corrections:

q<sub>l</sub>-determination

The collector is run indoor in a number of steady states ( $G = 0$ ). The global heat transfer coefficient is determined as a function of the difference temperature  $T_m - T_a$ :

$$U_o = \frac{-\dot{Q}_u}{A (T_m - T_a)} \quad (10)$$

A linear least square fit is obtained as a function of  $(T_m - T_a)$ . The coefficients  $U_1, U_2$  are determined.

$$U_o = U_1 + U_2 \cdot (T_m - T_a) \quad (11)$$

For any value of the parameter  $G$  the efficiency curve can be constructed:

$$\eta = \eta_o - U_1 \cdot \frac{(T_m - T_a)}{G} - U_2 \cdot \frac{(T_m - T_a)^2}{G} \quad (12)$$


Special care is taken that a forced convection for air over the collector cover is maintained. The procedure requires the mounting of a fan.

Obviously the BSE procedure may be objectionable because a "laboratory efficiency" is determined with the collector not exposed to solar radiation, and it must be related to actual outdoor conditions.

#### 4. Collectors in the Test


Two commercially available flat-plate liquid-heating collectors were chosen for the tests. A list of collector characteristics is given in Table 1, page 25. The types of collectors were agreed on to be single glass selective and double glass black paint. It was felt advantageous to copy the choices taken for the US /1/ and the CEC /10/ round robin tests.

The collector coded in this report as the IEA-1 collector had one tempered glass cover of high transmittance  $\tau = 0.90$ , the absorber plate was made from steel and was coated with a selective surface ( $\alpha = 0.95$ ;  $\varepsilon = 0.12$ ).



SCHMATIC OF FLAT-PLATE COLLECTOR IEA-1

Figure 1



SCHMATIC OF FLAT-PLATE COLLECTOR IEA-2

Figure 2



Thermal insulation is provided by the mounting block and layers of glass-fiber in the back. The collector box was roll formed and consisted of galvanized steel.

The collector coded in this report as the IEA-2 collector had two float glass covers of a single glass transmittance  $\tau = 0.84$ . The absorber foil and the tubes were made from copper. The absorber foil was wrapped around the tube covering 75 % of the tube area. The surface was coated with matt black polymerized paint (expected values:  $\alpha = 0.95$ ;  $\epsilon = 0.92$ ). The absorber was backed by rigid foam polyurethane insulation. The whole system was housed in an aluminium casing.

A cross-sectional view of the two collectors is given in Figure 1 and 2.

It should be noted that it proved to be difficult to obtain a consistent set of collector parameters for one of the collectors. Even letters to the manufacturers could not clarify the situation. Quantities describing the collectors have, therefore, to be considered as the best choice.

## 5. Results and Analysis of Data

In conduct of the round robin test programs with the CEC and the IEA the need for a standard reporting format became obvious. A proposal on performance tests format sheets /8/ found general support and was jointly developed as a useful tool of round robin testing. The latest version of the format sheets are given in Appendix B.

The results for this round robin test were exclusively reported on this standard format. This eased the data handling a great deal. In correspondence with the number of collectors and procedures involved, there are four groups of data:

1. IEA-1 Collector, NBS-ASHRAE Procedure (Data given in Appendix C)
2. IEA-2 Collector, NBS-ASHRAE Procedure (Data given in Appendix D)
3. IEA-1 Collector, BSE Procedure (Data given in Appendix E)
4. IEA-2 Collector, BSE Procedure (Data given in Appendix F)

The results from one participant who used the EIR method sorted best with the BSE Procedure.

In a first step the data were subjected to a least square fitting to re-assure a correct interpretation of the author's results. The format sheet required a fit according to

$$\eta = \eta_0 - a_1 \cdot T^* - a_2 \cdot (T^*)^2 \quad (13)$$

$$\text{with } T^* = U \frac{(T_m - T_a)}{I}$$

$$U \text{ normalizing coefficient} = 10 \text{ W/m}^2 \text{ } ^\circ\text{C}$$

Since the reference area (aperture area) determined and reported by the participants showed remarkable scatter. All data points were based to a common value:  $A_{\text{IEA-1}} = 1.79 \text{ m}^2$ ;  $A_{\text{IEA-2}} = 2.29 \text{ m}^2$ .

It was left to the author to choose a linear, a square fit or both. This analysis skipped a square fit when it seemed not appropriate. The single glass collector IEA-1 tends to require a higher order fit while a linear fit is adequate for the IEA-2 collector.

This analysis yielded the intercepts, slopes or coefficients of the efficiency curves as listed in Table 3 to Table 6.

One participant reported values that showed a remarkable scatter, it was admitted that quasi-steady conditions were possibly not maintained, and the intercepts and slopes were regarded as "outliers" and not used. The data from 10 facilities are shown in Figure 3 for the IEA-1 collectors, from 11 facilities in Figure 4 for the IEA-2 collectors.

It should be noted that the testing conditions with regard to type of fluid and mass flow rate selected by the participants were not as uniform as required by the standards.

The efficiency data for both collectors show a substantial scatter. While a certain amount of scatter is inherent in the procedures due to differences in environmental conditions as well as measurement errors, the question prevails whether the amount of scatter shown can be considered as representative for the procedure.




Figure 3: Efficiency data according to NBS/ASHRAE Procedure from 10 facilities, IEA-1 collector




Figure 4: Efficiency data according to NBS/ASHRAE procedure from 11 facilities, IEA-2 collector

Pursuing this question a very rigid approach would be to correct each data point for deviation from an arbitrarily defined reference set of weather conditions based on a theoretical thermal performance collector model. The remaining scatter could be attributed to measurement errors; yielding at the same time the relative weights of both contributions /1/.

This kind of approach was considered as not feasible because the data base reported by the participants was not as complete as required for such an analysis, therefore an alternative approach was applied.

Step I: The efficiency data reported by the participants were evaluated to yield mean values of the intercepts and slopes for the efficiency curves of both collectors (Tables 3 to 6).

Step II: A theoretical collector model /7,15/ was applied to compute optical and thermal performance of the IEA-1 and IEA-2 collectors. This modelling is based on collector design parameters and an adjustment of edge and back loss coefficients resulting in verification of the mean values according to Table 3 and Table 4.

#### Modelling of the "optical efficiency"

As the collectors in the tests are of the flat-plate type, it is straight forward to analyse the "optical efficiency" by theoretical models.

This was done in two ways:

- I. A simple approximate method, Reference /5/,
- II. The more involved net radiation method, Reference /7/.

The results according to both methods are compared in Table 2. It is concluded that the simple approximation method is adequate. If the computed effective absorptance-transmittance product  $(\tau\alpha)_e$  is compared with the mean  $\eta_0$ -values for both collectors, the collector efficiency factors  $F'$  can be determined:

$$\eta_0 = F' (\tau\alpha)_e$$




Figure 5: Data enclosed by extremes of collector performance




Figure 6: Data enclosed by extremes of collector performance

$$\text{IEA-1 collector: } F' = \frac{0.83}{0.84} = 0.99$$

$$\text{IEA-2 collector: } F' = \frac{0.57}{0.754} = 0.75$$

These efficiency factors were used for thermal performance modelling of the collectors. In addition, these factors are exceptionally indicative of the collector's heat transfer properties.

It should be noted that the  $(\tau\alpha)_e$  product was evaluated for a set of parameters which are close to the true values. The solar absorptance and reflectance of the absorber plate was modelled as being isotropic.

### Modelling of the thermal performance

The theoretical model given in reference /5/ was used to determine the front-loss coefficient for varying environmental conditions which are encountered during collector testing. Looking at the requirements of the ASHRAE-procedure two sets of environmental parameters can be identified which result into extremes of collector performance. These two sets which result either in high or in low collector efficiency are given by:

Low Efficiency	High Efficiency
$T_a = 35 \text{ }^\circ\text{C}$	$T_a = 5 \text{ }^\circ\text{C}$
$G = 1100 \text{ W/m}^2$	$G = 630 \text{ W/m}^2$
$\theta = 30 \text{ }^\circ$	$\theta = 0 \text{ }^\circ$
$V_w = 4.5 \text{ m/s}$	$V_w = 0.0 \text{ m/s}$
$G_d = 0.5$	$G_d = 0.0$ (diffuse fraction)

Collector performance data enclosed by the two theoretical efficiency curves resulting from meteorological extremes allowed by ASHRAE standard 93-77 is shown in Figure 5 and Figure 6.

### Step III:

Errors in measurements are another cause for the scatter of data shown in Figure 3 and 4. There are two kinds of measurement errors:

Random errors are shown to be rather small as can be seen from the small scatter found in the data for each facility. Participants are apparently able to obtain consistent measurements. Random errors are not addressed in this analysis.




Figure 7: Data enclosed by the combined effect of meteorological extremes and measurement uncertainty




Figure 8: Data enclosed by the combined effect of meteorological extremes and measurement uncertainty

Systematic errors are peculiar to testing facilities and are either positive or negative in sign. Systematic errors are determined by the requirements of the test procedures for the accuracy of instruments and calibrations.

While the results from a particular facility are biased by systematic errors, and are correctible in principle, the option for the analysis of round robin test results is confined to the assumption that the systematic errors of different test facilities are associated with a random uncertainty.

Based on the accuracy of the instrumentation as specified in the ASHRAE and BSE standards the following inaccuracies of measurements were assumed for the analysis:

$\frac{\Delta G}{G} = \pm 3 \%$	solar irradiance
$\frac{\Delta \dot{m}}{\dot{m}} = \pm 1 \%$	mass flow rate
$\Delta(\Delta T) = \pm 0.1 \text{ } ^\circ\text{C}$	difference temperature
$\Delta(T) = \pm 0.5 \text{ } ^\circ\text{C}$	absolute temperature

The inaccuracies of measurements were assumed to propagate into an uncertainty  $\pm \Delta \eta$  and  $\pm \Delta T^*$  of the efficiency curves according to the root-mean-square error propagation. This kind of analysis yields an error band which is essentially parallel to the efficiency curve.

Figure 7 and Figure 8 show the data for both collectors bracketed by calculated efficiency curves for extreme environmental effects, and with the measurement uncertainty of systematic errors.

The essence of the analytical approach could be termed as follows:

- 1) The combined effect of environmental conditions and systematic errors on efficiency measurements could in principle explain the data scatter observed in round robin testing.  
Since the extreme meteorological conditions are by no means representative for the actual test conditions met by the participants, one should expect a very prominent grouping of data points around the mean values. This is shown to some extent for the IEA-1 collector, but not apparent for the IEA-2 collector.






Figure 9: Comparison of efficiency according to both procedures;  
IEA-1 collector  
NBS-Procedure (linear fit)  
BSE-Procedure (higher order fit)




Figure 10: Comparison of efficiency according to both procedures;  
IEA-2 collector  
NBS-Procedure (linear fit)  
BSE-Procedure (higher order fit)

- 2) The computed efficiency curves verify that the environmental impact tends to be small for small temperature differences ( $T_m - T_a$ ). The slope of the curves is predominantly effected by the wind speed resulting in a considerable spread at higher operating temperatures for the collectors.

This has to be seen in connection with the important result from the error analysis that the finite instruments' accuracies which cause a systematic error in measurement have a negligible effect on the slope of the efficiency curve. This is true as long as the dominant uncertainty is associated with the inaccuracy of the irradiance measurement. The data scatter found near the  $\eta_0$ -intercept can therefore be taken as a quantitative measure for systematic errors of the different test facilities.

Since the data scatter found for the IEA-2 collector is insufficiently covered by the analytical efficiency curves, the effect of fabrication induced scatter cannot be excluded. This is consistent with indications from a number of participants that the thermal contact between tube and absorber sheet for collector IEA-2 could not inherently guarantee stable thermal properties for different specimens.

The results derived from application of the BSE-procedure were expected to be less affected from an environmental impact on the slope and to show only small scatter. This is contrary to the experimental evidence: the scatter is not less than for the outdoor measurement.

It is probable that systematic errors do account for the scatter. The heat loss coefficient proved to be a rather sensitive parameter as can be seen from the scatter reported by individual participants. Constructing the efficiency curve, the uncertainties are smoothed out partly because of a kind of integration process. Indoor measurements have their own "environment" and are difficult to control when natural convection is applied.

The BSE procedure requires a wind speed of 5 m/s over the collector for those data points that are used for the construction of the efficiency curve. Since not all of the participants followed this rule, the statistics for mean values is not very complete.

It is of some interest to compare efficiency curves derived from both of

the two procedures. The mean efficiency curves according to NBS/ASHRAE and BSE are compared in Figure 9 and Figure 10. The measurements for both procedures are not independent with regard to the intercept  $\eta_0$ . Although this comparison is of limited relevance as far as the physics of an indoor and outdoor correlation are concerned, the empirical result shows a remarkable agreement for the efficiency curves of both collectors.

## 6. Conclusions and Recommendations

The scatter of data of the efficiency curves is in the "traditional" range obtained from round robin tests.

The analysis has given an indication that systematic test uncertainties of the testing facilities are a key reason for the scatter of measured collector efficiencies.

Apart from the analysis conducted, participants have expressed their concern about the uncertainty associated with the accuracy of the pyranometers. The Participants had difficulties to ascertain the nominal accuracy of  $\pm 3 \%$  for their pyranometers.

Both procedures have been shown to be applicable and useful for determining collector thermal performance. Neither of the two procedures proved to be superior with respect to small data scatter. The mean curves according to both procedures do compare well. Moreover, physically more meaningful, the curves for both procedures taken at a particular facility do compare very well.

The recommendations given are supported not only by the conclusions derived from the formal analysis but also by participants' views and experience gained independently from round robin testing.

Experimentalists should give great care to the calibrations of their testing facility.

The experimentalists should employ a comprehensive in-situ calibration of the testing facility. A calorimetric calibration is recommended.

International pyranometer standards and calibration methods are needed to provide the individual test facilities with an instrument of known accuracy and precision for collector test purposes.

The calibration procedure for pyranometers should include performance under tilted positions.

The indoor environment and the stepwise procedure of taking data according to the BSE standard over a range of temperatures should be observed carefully.

Application of forced convection by a fan system during outdoor testing could help to reproduce testing condition with respect to wind speed.

The standard procedures evaluated in this round robin test are intended to be generally applicable. However, the results derived from flat-plate collector testing have to be considered as selective. It is felt that further comparative testing is required to validate the usefulness of the procedures for other types of collectors.

It is felt necessary that the procedure should provide efficiency data supplemented by confidence limits.

This is not apparent from the data. It is possible that wind effects over the top surface of the collector may differ from those measured adjacent to the collector and that wind screens and fans may be desirable to provide reproducible testing conditions outdoors.

7. References

- /1/ Streed, E.R.; Thomas, W.C.; Dawson, K.G.; Woods, B.D., and Hill, J.E.  
Result and Analysis of a Round Robin Test Program for Liquid-Heating Flat-Plate Solar Collectors  
NBS Technical Note 975, August 1978, Washington, D.C.
- /2/ Hill, J.E.; Kusuda, T.  
Method of Testing for Rating Solar Collectors Based on Thermal Performance  
NBSIR 74-635, December 1974, Washington, D.C.
- /3/ Usability of Solar Collectors, Guidelines and Directions  
A Solar Collector Efficiency Test  
BSE, 4300 Essen, Germany, May 1978
- /4/ Hottel, H.C., and Woertz, B.B.  
The Performance of Flat-Plate Solar Heat Collectors  
ASME Transactions, Vol. 64, p. 9, 1942
- /5/ Duffie, J.A., and Beckmann, W.A.  
Solar Energy Thermal Process, John Wiley and Sons, New York, 1974
- /6/ Methods of Testing to Determine the Thermal Performance of Solar Collectors  
ASHRAE Standard 93-77  
ASHRAE, 345 Est 47th Street, New York, N.Y. 10017, 1977
- /7/ Ramsey, J.W.; Borzoni, J.T., and Holland, T.H.  
Development of Flat-Plate Solar Collectors for the Heating and Cooling of Buildings  
NASA CR-134804, June 1975
- /8/ Aranovitch, E.  
Proposal on: Performance Tests Format Sheets Solar Collector Programme  
European Commission Joint Research Centre, Euratom ISPRA/Italy, 1977
- /9/ Derrick, A.  
Recommendation for European Solar Collector Test Methods  
Solar Energy Unit, University College, Cardiff, U.K.
- /10/ Results and Analysis of the CEC Round Robin Testing of Three Solar Collectors  
Edited by A. Derrick, Solar Energy Unit, University College, Cardiff, U.K., INTERIM Draft, May 1979

Table 1 Collector characteristics and parameters  
(from manufacturer's literature and from [1] )

Characteristics	Collector IEA-1	Collector IEA-2
Manufacturer	Chamberlain Mfg. Co Elmhurst, Illinois USA	Commercial Solar Energy Nottingham, England
Gross dimensions (m)	2.14 x 0.92	2.00 x 1.22
Aperture dimensions (m)	2.08 x 0.86	1.94 x 1.18
Aperture Area (m <sup>2</sup> )	1.79	2.29
Cover plate assembly		
Number of glass plates	1	2
Thickness (mm)	3.2	4.0
Material	low-iron tempered glass	float glass
Solar transmittance	0.90	0.84 (each)
I. R. emittance	0.88	0.84
Absorber plate		
Material	Mild steel	Copper
Plate construction	Stich welded	10 parallel tubes
Tube spacing (m)	-	0.112
Coating	Black Chrome	Matt black paint
Solar absorptance	0.95	0.95
Solar emittance	0.12	0.92
Air Spaces (mm)		
Between covers	-	18.0
Between cover and absorber	19.0	21.0
Insulation		
Material	glass-fiber	Polyurethane
Density (kg/m <sup>3</sup> )	80.	50.
Thickness (mm)	76.2	50.
Thermal conductivity (W/m · °K)	0.03	0.024

Table 2

## Optical Properties

FLAT-PLATE COLLECTOR					
		IEA 1	IEA 2		
Index of Refraction		1.51	1.526		
Thickness of pane I		3.2 mm	4 mm		
Thickness of pane II		—	4 mm		
Extinctions Coefficient		0.1 cm <sup>-1</sup>	0.125 cm <sup>-1</sup>		
Solar absorptance $\alpha$		0.94	0.95		
I.R. emittance $\varepsilon$		0.14	0.95		
Assumptions: diffuse adsorber diffuse light is isotropically distributed		Theoretical model A: Net radiation method [5] B: Approximate method [6]			
		A	B	A	B
<b>Cover system</b>					
Transmittance		0.892	0.891	0.765	0.766
Reflectance		0.077	0.079	0.140	0.139
Absorption (normal incidence)		0.031	0.030	0.095	0.095
<b>Cover system</b>			60° appr.		60° appr.
Transmittance		0.818	0.814	0.678	0.672
Reflectance		0.147	0.148	0.216	0.219
Adsorption (100 % diffuse light)		0.035	0.038	0.106	0.109
<b>Cover system + absorber</b>					
Reflectance		0.121	—	0.162	—
Absorption (panes)		0.033	—	0.099	—
Absorptance (normal incidence)		0.846	0.845	0.735	0.736
<b>Cover system + absorber</b>					
Reflectance		0.188	—	0.241	—
Adsorption (panes)		0.037	—	0.109	—
Absorptance (100 % diffuse light)		0.775	0.771	0.650	0.645
(15 % diffuse)	$\tau\alpha =$	0.835	0.834	0.722	0.722
(15 % diffuse)	$(\tau\alpha)_e =$	0.839	0.838	0.754	0.757

Table 3

**Summary of Collector Thermal Performance  
Collector: IEA-1; Procedure: NBS**

Participant	Linear Curve				$\eta = \eta_0 - a_1 \cdot T^* - a_2 \cdot (T^*)^2$					Pyranometer modell
	$\eta_0$	$\Delta\eta_0$	$a_1$	$\Delta a_1$	$\eta_0$	$\Delta\eta_0$	$a_1$	$a_2$	Area	
A	0.73	-12 %	0.37	-23 %	-	-	-	-	1.79	Kipp + Zonen CM 5
CDN	0.84	2 %	0.47	-3 %	0.83	1 %	0.42	0.06	1.79	Eppley 8-48
D Jülich	0.82	-2 %	0.48	0 %	0.80	-3 %	0.36	0.13	1.79	Kipp + Zonen CM 5
D Heidelberg	0.84	2 %	0.44	-9 %	-	-	-	-	1.79	Eppley
D Stuttgart	0.84	2 %	0.42	-13 %	-	-	-	-	1.79	Kipp + Zonen CM 6
DK	0.87	5 %	0.59	22 %	0.86	4 %	0.49	0.13	1.79	Kipp + Zonen CM 5
GB	0.81	-3 %	0.41	-15 %	-	-	-	-	1.79	Kipp + Zonen
J	0.83	0 %	0.52	8 %	0.81	-2 %	0.37	0.19	1.79	EKO - MS 41
NL	0.77	-7 %	0.45	-7 %	-	-	-	-	1.79	Kipp + Zonen
S	0.81	-3 %	0.52	-8 %	0.80	-3 %	0.35	0.24	1.70	Eppley
USA NBS	0.83	0 %	0.44	9 %	-	-	-	-	1.79	Eppley PSP
USA Phoe.	0.87	5 %	0.55	-15 %	0.85	3 %	0.39	0.20	1.79	-
Mean $\bar{\eta}_0$	0.83		0.48		0.825					
Standard Deviation $\sigma$	$\pm 0.03$		$\pm 0.06$		$\pm 0.025$					



Table 4

**Summary of Collector Thermal Performance**  
**Collector: IEA-2; Procedure: NBS**

Participant	Linear Curve			$\eta = \eta_0 - a_1 \cdot T^* - a_2 \cdot (T^*)^2$					Pyranometer modell	
	$\eta_0$	$\Delta\eta_0$	$a_1$	$\Delta a_1$	$\eta_0$	$\Delta\eta_0$	$a_1$	$a_2$		Area
A	0.47	-22 %	0.22	-50 %	-	-	-	-	2.29	Kipp + Zonen CM 5
B Heverlee	0.59	3 %	0.50	15 %	0.53	-6 %	0.13	0.50	2.29	Kipp + Zonen CM 5
B Mons	0.66	+15 %	0.60	38 %	0.61	8 %	0.29	0.35	2.29	Eppley 4-48
D Jülich	0.57	0 %	0.41	-6 %	0.58	3 %	0.43	-0.02	2.29	Kipp + Zonen CM 5
D Heidelberg	0.54	-6 %	0.41	-6 %	0.52	-8 %	0.20	0.16	2.29	Eppley
D Stuttgart	0.60	5 %	0.51	18 %	0.61	8 %	0.52	0.00	2.20	Kipp + Zonen CM 6
E	0.56	-3 %	0.37	-15 %	0.55	-2 %	0.35	0.02	2.29	Eppley
GB	0.55	-4 %	0.37	-15 %	0.56	1 %	0.41	-0.03	2.29	Kipp + Zonen
J	0.59	3 %	0.46	6 %	0.56	1 %	0.27	0.21	2.29	EKO - MS 41
NL	0.57	0 %	0.41	-6 %	0.57	1 %	0.44	-0.06	2.29	Kipp + Zonen
S	0.58	1 %	0.48	11 %	0.53	-6 %	0.10	0.56	2.29	Eppley
US NBS	0.58	1 %	0.47	9 %	0.58	3 %	0.47	0.00	2.29	Eppley PSP
Mean $\bar{\eta}_0$	0.57		0.43		0.56					
Standard Deviation $\sigma$	$\pm 0.05$		$\pm 0.094$		$\pm 0.03$					

Table 5

**Summary of Collector Thermal Performance**  
**Collector: IEA-1; Procedure: BSE**

Participant	Efficiency $\eta = \eta_0 - a_1 \cdot T^* - a_2 \cdot (T^*)^2$				[I]=kW		Heat Transfer Coefficient $U_m = U_o + U_1 (T_m - T_a)$ ; (W/m <sup>2</sup> ·°C)				Pyranometer modell
	$\eta_0$	$\Delta\eta_0$	$a_1$	$a_2$	$U_o$	$\Delta U_o$	$U_1$	$\Delta U_1$	wind		
CH*	0.85	2%	0.33	0.00	3.27	-12%	0.000	const.	1 m/s	-	
D Jülich	0.81	-3%	0.35	0.30	3.50	-6%	0.003	18%	5 m/s	Kipp + Zonen CM 5	
D Heidelberg	0.86	4%	0.43	0.22	4.30	16%	0.022	-15%	5 m/s	Eppley	
DK	0.86	4%	0.36	0.23	3.60	-3%	0.023	-10%	5 m/s	Kipp + Zonen CM 5	
GB	0.84	1%	0.42	0.04	4.20	13%	0.004	const.	0 m/s	Kipp + Zonen	
NL	0.77	-8%	0.37	0.23	3.65	-1%	0.023	-10%	5 m/s	Kipp + Zonen	
J**	0.83	0%	0.40	0.16	4.03	9%	0.016	-37%	2 m/s	EKO - MS 41	
USA	0.83	0%	0.35	0.29	3.45	-7%	0.029	14%	5 m/s	Eppley PSP	
Mean $\bar{\eta}_0$	0.83				3.70		0.025	(for 5 m/s + BSE-method)			
Standard $\sigma$	±0.03				±0.35		±0.004				

\* According to the EIR-method

\*\* Losses measured outdoors

Table 6

Summary of Collector Thermal Performance  
Collector: IEA-2; Procedure: BSE

Participant	Efficiency $\eta = \eta_0 - a_1 \cdot T^* - a_2 \cdot (T^*)^2$				[I]=kW		Heat Transfer Coefficient $U_m = U_0 + U_1 (T_m - T_a)$ ; (W/m <sup>2</sup> ·°C)				Pyranometer modell
	$\eta_0$	$\Delta\eta_0$	$a_1$	$a_2$	$U_0$	$\Delta U_0$	$U_1$	$\Delta U_1$	wind		
B	0.61	7%	0.37	0.30	3.68	5%	0.03	-70%	0 m/s	Kipp + Zonen CM 5	
CH*	0.52	-	0.36	0.00	3.61	3%	0.00	const.	3 m/s		
D Jülich	0.56	-	0.31	0.13	3.13	-11%	0.01	-25%	3 m/s	Kipp + Zonen CM 5	
D Heidelberg	0.51	-11%	0.30	0.12	2.99	-15%	0.01	-30%	0 m/s	Eppley	
DK	0.63	10%	0.37	0.17	3.66	5%	0.02	0%	5 m/s	Kipp + Zonen CM 5	
E**	0.55	-	0.36	0.01	3.62	4%	0.00	const.	0 m/s	Eppley	
GB	0.55	-	0.40	0.04	4.04	16%	0.00	const.	0 m/s	Kipp + Zonen	
J**	0.56	-	0.28	0.18	2.79	-20%	0.02	4%	0 m/s	EKO - MS 41	
NL	0.56	-	0.32	0.19	3.22	-8%	0.02	10%	5 m/s	Kipp + Zonen	
USA NBS	0.58	2%	0.32	0.12	3.25	-7%	0.01	-30%	8 m/s	Eppley	
Mean $\bar{\eta}_0$	0.57				3.49		0.017				
Standard Deviation $\sigma$	±0.04				±0.36		±.006				

\* According to the EIR-method

\*\* Losses measured outdoors

APPENDIX A

The EIR method for collector testing  
(Text by P. Kesselring, J.M. Suter)

### The EIR method for collector testing

Testing hot water collectors under Swiss meteorological conditions is a hard job, as the clear sky required e.g. by ASHRAE or NBS procedures exists only on a few days a year. Therefore, from the very beginning we tried at EIR to aim at a method suitable for outdoor testing of collectors under covered sky conditions. The method described in the following fulfills this requirement and is able to provide the same parameters as the NBS or BSE procedures.

### The evaluation principle

The evaluation principle has some similarity with the BSE (former ASE) procedure:  $\eta_0$  is also determined around solar noon under clear sky condition and  $T^* \approx 0$  by extrapolation of measured points to  $T^* = 0$ . The difference lies in the determination of thermal losses. These are measured outdoor under 100 % diffuse radiation condition.

### Measurement of thermal loss factor

The situation of stable 100 % diffuse radiation - e.g. covered sky, fog or early morning hours - is often characterized by slowly varying ambient temperature and low absolute values of radiation (100 - 300 W/m<sup>2</sup>). We then have a case, where the thermal losses of a collector are very nearly stationary. At the same time, the incident radiation may change by an order of magnitude in intensity, although the angular distribution remains constant - e.g. isotropic. Under these conditions  $T^*$  may easily vary by a factor of 10 with a corresponding change in the efficiencies. If the mean collector temperature lies only slightly above ambient temperature, then  $\eta$ -values from e.g. -1 (radiation losses  $\approx$  irradiated energy) to nearly  $\eta_0$  may occur. As the thermal losses are very early constant, the  $\eta$  vs.  $T^*$  plot is very nearly linear, its slope giving the low temperature heat loss factor  $a_1$ . The  $\eta$ -axis intercept gives a value of the optical efficiency for diffuse radiation. We call it  $\eta_{0D}$ .

Increasing the mean collector temperature, the same procedure gives values for the high temperature loss factor. As the values are lying in the high

$T^*$ -value range -  $\eta$  being usually always negative - no reliable extrapolation to  $T^* = 0$  can be made. This means that although the slope values are quite satisfactory, the  $\eta$ -axis intercept are of no value in this case.

### $\eta_0$ -Determination

In measuring  $\eta_0$  another difficulty arises. We remember that here the radiation should be of normal incidence to the collectors. However, in our climate it often happens, that under clear sky conditions the amount of diffuse light is up to 30 %. Because of the modified angular distribution of the incident light the measured  $\eta_0$ -values will be systematically low, since they should be determined at 100 % direct insolation.

Using the values  $\eta_{0D}$ , determined under completely diffuse radiation conditions, we can calculate an upper limit for  $\eta_0$ . We assume that the diffuse part  $d$  of the radiation may be used with efficiency  $\eta_{0D}$ , the percentage  $(1-d)$  with efficiency  $\eta_0$  to give then the measured efficiency  $\eta_{0G}$  for the actual global radiation.

$$(0) \quad d\eta_{0D} + (1-d)\eta_0 = \eta_{0G}$$

$$(1) \quad \eta_0 = \frac{\eta_{0G} - d\eta_{0D}}{(1-d)}$$

This value will be systematically high, as the actual diffuse radiation under clear sky conditions is mostly circumsolar, whereas the  $\eta_{0D}$  was determined at rather isotropic radiation conditions.

### Construction of the clear sky collector characteristic

The IEA form of the stationary collector equation is

$$(2) \quad \eta = \eta_0 - a_1 T^* - a_2 T^{*2} \quad (\text{see page 13, eq. 13})$$

As mentioned above the  $\eta_0$  value is a clear sky value determined in a BSE like way. From measurements as described we get a thermal loss factor function  $K = K(T_m, T_a)$  which can be approximated

$$(3) \quad K = \alpha + \beta (T_m - T_a)$$

where  $\alpha$  is the low temperature loss factor. Comparing this with (2) and eq. 13 (page 13), we have

$$(4) \quad a_1 = \alpha/U_0$$

$$(5) \quad a_2 = \frac{\beta \cdot G}{U_0^2}$$

Remains the question, what value of  $G$  in equation (5) should be used. As the NBS rules to determine (2) require high irradiation conditions, it is clear that e.g. a value of  $G = 900 \text{ W/m}^2$  is appropriate.

### Test performed on the IEA collectors

#### Experiments under diffuse radiation conditions

Tests are conducted on the automatic test facility of the Swiss Federal Institute for Reactor Research (EIR). About 40 runs similar to that documented on pages A 62, A 77 for August 14, 1979, have been performed for both IEA collectors. Taking a statistical mean of the collector parameters leads to the value given below.

In checking the data set in page A 61, A 62 it should be noted that a mass-flow correction of + 6 % has been applied in computing the ETA values. This takes into account the results of manual calibrating (bucket and watch method) of the computer operated flow meter, which is the source of the values in the tables. The correction factor is checked every few days.

#### $\eta_{0G}$ Measurements

The data given on page A 61, A 76 contain the results of a clear day experiment on July 30, 1978. The same flow value correction as above applies also in this case.

In comparing the  $\eta_{0G}$  values with the mean values below, it is important to remember the definitions for the different parameters  $\eta_{0D}$ ,  $\eta_{0G}$ , and  $\eta_0$  given by eq. (0) (page A3).

The mean values for  $\eta_0$  below result from experiments on 17 different days.

Mean values of collector parameters

Results of parameter measurements with diffuse radiation scatter around mean values because meteorological "boundary conditions" vary in a manner, very difficult to identify. However, statistical mean values over many experiments are reproducible to less than 2 %. The following table gives the collector parameters as computed from the above mentioned data set.

<u>Collector</u>	$\eta_{oD}$		$a_1$		$\eta_o$	$\eta_o(0.2)$
IEA 1	0.73	0.01	0.33	0.01	0.89	0.86
IEA 2	0.50	0.01	0.34	0.01	0.58	0.56

The errors given are standard deviations from the  $\eta_{oD}$ ,  $a_1$  values measured in the above mentioned set of experiments.

The experience of the last two years shows that e.g. the standard deviation  $\sigma_{oD}$  of the  $\eta_{oD}$  mean values as a function of the numbers of experiments  $m$ , conducted on different days, follows quite well the law  $\sigma_{oD} = 0.06/\sqrt{m}$ .

So far no  $a_2$  values for the IEA collectors have been measured.

With  $\eta(0.02)$  we denote the  $\eta_o$  values for 20 % diffuse radiation. It is this  $\eta(0.20)$  value that should be compared to ASHRAE or BSE values. By the way, the ratio  $\eta_o/\eta_{oD} \approx 1.17$  is about as expected theoretically on the basis of purely direct and completely isotropic radiation.





APPENDIX B  
IEA/CEC Round Robin Testing Format Sheets



IEA SOLAR COLLECTOR TESTING PROGRAMME  
FORMAT SHEET

Ref. ....

TESTS PERFORMED BY : .....

..... Tel. ....

..... Telex .....

**1. Description of Solar Collector**

1.1 NAME OF COLLECTOR AND MANUFACTURER : .....

.....

1.2 TRANSPARENT COVERS

— Number ..... Thickness ..... mm

— Material .....

— Aperture dimensions .....

1.3 ABSORBER PLATE

— Material .....

— Surface treatment .....

— Manufacturing process .....

— Weight empty ..... Kg      Water content ..... Kg

— Dimensions .....

.....

1.4 THERMAL INSULATIONS AND CASING

— Thermal insulation:      Thickness ..... cm

— Material .....

— Casing:      Material .....

— Total weight of collector with water ..... Kg

— Gross dimensions .....

1.5 LIMITATIONS

- Maximum temperature of operation .....
- Maximum pressure .....
- Acceptable heat transfer fluids .....
- .....

1.6 SCHEMA OF SOLAR COLLECTOR

## 2. Instantaneous Efficiency Test

2.1 METHOD .....

.....

2.2 SCHEMA OF TEST INSTALLATION

2.3 INSTRUMENTATION .....

– Incident radiation .....

– Diffuse radiation .....

– Fluid mass flow .....

– Ambient temperature .....

– Fluid absolute temperature .....

– Differential fluid temperature .....

– Wind velocity .....

– Data recording .....

– Pressure drop transducers .....



### 3. Instantaneous Efficiency Curve

THE INSTANTANEOUS EFFICIENCY  $\eta$  IS DEFINED BY :  $\eta = \frac{q_u}{A \cdot I}$


$q_u$  : useful power extracted (W)

$I$  : incident radiation ( $W/m^2$ )

$A$  : reference area ( $m^2$ )

Specify reference area used for curve

- gross area of collector
- aperture area
- absorber area



RECOMMENDED EQUATION :  $\eta = \eta_0 - a_1 T^* - a_2 (T^*)^2$

$\eta =$





4. Instantaneous Efficiency : Experimental Data

LATITUDE .....

LONGITUDE .....

AZIMUTH .....

HOUR AT SOLAR NOON .....

SLOPE : .....

Cp .....

FLUID : .....

D	hr	I	$I_d/I$	$m_f$	$T_a$	$T_f$	$\Delta T$	$T_m$	$T^*$	$\eta$	V

REFERENCE AREA : ..... m<sup>2</sup> HEAT CAPACITY : ..... KJ/°C

(AZIMUTH refers to collector position)



#### 4. Instantaneous Efficiency : Experimental Data

LATITUDE .....

LONGITUDE .....

AZIMUTH .....

HOUR AT SOLAR NOON .....

Cp .....

FLUID : .....

SLOPE : .....

D	hr	I	$I_d/I$	$m_f$	$T_a$	$T_f$	$\Delta T$	$T_m$	$T^*$	$\eta$	V

REFERENCE AREA : .....  $m^2$  HEAT CAPACITY : .....  $KJ/^{\circ}C$

(AZIMUTH refers to collector position)



4. Instantaneous Efficiency : Experimental Data

LATITUDE .....

LONGITUDE .....

AZIMUTH .....

HOUR AT SOLAR NOON .....

SLOPE : .....

Cp .....

FLUID : .....

D	hr	I	$I_d/I$	$m_f$	$T_a$	$T_j$	$\Delta T$	$T_m$	$T^*$	$\eta$	V

REFERENCE AREA : ..... m<sup>2</sup>      HEAT CAPACITY : ..... KJ/°C


(AZIMUTH refers to collector position)



## 5. Heat Losses


### 5.1 GLOBAL THERMAL LOSSES

indoor   
 outdoor




The heat losses  $q_l$  are expressed as a function of the temperature difference  $(T_m - T_a)_l$

### 5.2 GLOBAL HEAT TRANSFER COEFFICIENT



$$U_m = \frac{q_l}{A_a (T_m - T_a)_l}$$





5.3. HEAT LOSSES: EXPERIMENTAL DATA


FLUID ..... SLOPE : .....

D	hr	$m_f$	$T_a$	$T_i$	$\Delta T$	$T_m$	$T_m - T_a$	$Q_l$	$U_m$	V	$T_{sky}$	$C_p$

REFERENCE AREA : ..... m<sup>2</sup>      HEAT CAPACITY : ..... KJ/C



## 6. Pressure Drop



The pressure drop  $\Delta P$  across the collector is measured with water at ambient temperature

## 7. Other Methods or Special Remarks

(Give a short description of methods and essential results)

**7. Other Methods or Special Remarks** *(continued)*

## 8. Nomenclature

$A_g$	: Gross area of collector	( $m^2$ )
$A_a$	: Aperture area	( $m^2$ )
$A_p$	: Absorber plate area	( $m^2$ )
$C_p$	: Specific heat	( $J/g \cdot ^\circ C$ )
D	: Date — [ day - month - year ]	
hr	: Local time	
I	: Incident radiation	( $W/m^2$ )
$I_d$	: Diffuse incident radiation	( $W/m^2$ )
$\dot{m}_f$	: Mass flow	(g/s)
$q_l$	: Heat losses	(W)
$q_u$	: Useful Power	(W)
$T_a$	: Ambient temperature	( $^\circ C$ )
$T_i$	: Collector inlet temperature	( $^\circ C$ )
$T_m$	: Average temperature of fluid in collector	( $^\circ C$ )
$T_{SKY}$	: SKY temperature	( $^\circ C$ )
$T^*$	: Reduced temperature	dimensionless
$\Delta T$	: Temperature difference between outlet and inlet	( $^\circ C$ )
$U_m$	: Global heat transfer coefficient	( $W/m^2 \cdot ^\circ C$ )
$U_0$	: Normalized coefficient	$U_0 = 10 W/m^2 \cdot ^\circ C$
V	: Wind velocity	m/s
$\eta_0$	: Efficiency when $T^* = 0$	dimensionless
$\Delta P$	: Pressure drop	(Pa)

APPENDIX C

Data: IEA-1 Collector

NBS Procedure

A


COLLECTOR TYPE: IFA-1 TESTING PROCEDURE: NBS/ASHRAE SITE: AUSTRIA  
 REFERENCE AREA: 1.789 M\*\*2; FLUID: WATER SLOPE: 38/47 DEGREE

NUMBER OF DATA POINTS = 26

TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 1

SITE = A COLLECTOR TYPE IEP

ID	NO	DATE	HOUR	I	ID/I	FLOA	TR	T1	DELTA T	TM	T*	ETA	WIND	TSKY
1	1	177.10.14	13.50	627.01	0.0	35.6	13.40	0.0	5.1	31.8	0.29	0.68	1.5	0.0
1	2	177.10.17	14.07	564.01	0.0	31.7	17.20	0.0	4.2	43.1	0.46	0.55	1.5	0.0
1	3	177.10.18	12.03	850.01	0.0	23.3	18.80	0.0	6.3	73.1	0.67	0.40	0.5	0.0
1	4	177.10.18	12.07	753.01	0.0	27.8	19.60	0.0	6.5	61.0	0.56	0.56	1.5	0.0
1	5	177.10.18	14.31	498.01	0.0	29.4	19.30	0.0	3.1	52.0	0.66	0.43	2.0	0.0
1	6	177.10.19	12.57	774.01	0.0	33.3	15.70	0.0	8.0	33.4	0.22	0.80	1.5	0.0
1	7	177.10.19	13.53	627.01	0.0	54.4	17.30	0.0	3.9	35.1	0.28	0.67	1.5	0.0
1	8	177.10.20	13.32	669.0	0.0	53.3	17.70	0.0	2.5	73.6	0.83	0.46	2.0	0.0
1	9	177.10.21	13.51	537.01	0.0	56.7	18.00	0.0	1.6	57.7	0.74	0.39	2.0	0.0
1	10	177.11.11	13.47	557.01	0.0	20.5	15.60	0.0	7.5	28.7	0.24	0.65	1.0	0.0
1	11	177.11.20	12.12	829.01	0.0	20.8	11.00	0.0	9.3	22.1	0.13	0.54	4.0	0.0
1	12	177.12.19	12.58	738.01	0.0	22.2	2.80	0.0	9.8	21.3	0.25	0.69	1.0	0.0
2	1	178.6.12	12.52	894.01	0.0	75.8	21.30	0.0	3.6	39.6	0.20	0.63	2.0	0.0
2	2	178.6.12	13.48	854.01	0.0	77.8	21.40	0.0	3.2	45.9	0.29	0.60	2.0	0.0
2	3	178.6.12	14.25	831.01	0.0	76.8	22.20	0.0	2.7	42.2	0.33	0.73	2.0	0.0
2	4	178.6.13	12.44	831.01	0.0	76.2	15.70	0.0	2.5	39.6	0.28	0.46	2.0	0.0
2	5	178.6.13	13.20	832.01	0.0	76.8	16.60	0.0	2.8	41.7	0.31	0.54	2.0	0.0
2	6	178.6.13	14.09	861.01	0.0	77.7	17.40	0.0	2.9	42.5	0.29	0.55	2.0	0.0
2	7	178.6.14	12.09	974.01	0.0	80.1	17.80	0.0	3.7	41.8	0.25	0.62	2.0	0.0
2	8	178.6.14	12.45	976.01	0.0	80.1	18.90	0.0	3.9	47.8	0.30	0.67	2.0	0.0
2	9	178.6.19	13.51	875.01	0.0	80.1	19.20	0.0	3.3	49.8	0.35	0.63	2.0	0.0
2	10	178.6.19	11.15	930.01	0.0	82.0	22.50	0.0	3.2	63.7	0.44	0.60	1.0	0.0
2	11	178.6.19	12.00	957.01	0.0	83.7	23.60	0.0	3.3	69.6	0.48	0.63	1.0	0.0
2	12	178.6.19	12.30	974.01	0.0	85.0	23.60	0.0	3.0	73.8	0.51	0.56	1.0	0.0
2	13	178.6.19	13.14	1032.01	0.0	84.9	23.50	0.0	3.2	76.8	0.52	0.56	1.0	0.0
2	14	178.6.20	12.44	1010.01	0.0	81.7	19.80	0.0	3.6	63.4	0.43	0.61	2.0	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA-0.0 0.0 \*TSTAR  
 ETA-0.600 0.367\*TSTAR 0.2431TSTAR\*\*2

LEAST SQUARE FIT


ETA-0.734 -.374\*TSTAR  
 ETA-0.640 0.105\*TSTAR -.5091TSTAR\*\*2



COLLECTOR TYPE: IEA-1 TESTING PROCEDURE: NBS/BSHRE SITE: CANADA  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: H2O/GLYCOL; SLOPE: 40/60 DEGREE

SITE = CAN COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASHRE/BSE = 1/21 = 1 NUMBER OF DATA POINTS = 34

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	Ta	Tm	ETA	HIND	TSKY	
1	1	178	2.131	12.001	1080.01	0.16	63.6	31.6	5.5	34.4	0.39	0.67	2.2	0.0	
1	2	178	2.281	12.061	1098.01	0.15	58.5	15.6	7.0	19.1	0.24	0.73	2.7	0.0	
1	3	178	3.11	12.001	1103.01	0.14	62.7	19.7	6.3	22.9	0.26	0.72	1.3	0.0	
1	4	178	3.41	12.001	1134.01	0.18	84.1	21.9	6.0	24.9	0.29	0.69	3.5	0.0	
1	5	178	3.51	11.451	1097.01	0.22	63.5	10.40	24.3	5.8	27.2	0.32	0.69	4.0	0.0
1	6	178	3.81	12.001	1114.01	0.12	62.8	4.60	22.7	6.0	25.7	0.27	0.70	2.7	0.0
1	7	178	3.101	11.181	1039.01	0.16	61.6	3.70	19.9	6.4	23.1	0.19	0.76	1.9	0.0
1	8	178	3.191	12.001	1058.01	0.16	61.1	5.10	19.9	6.6	23.1	0.17	0.77	1.8	0.0
1	9	178	3.101	13.091	1002.01	0.17	61.1	8.60	19.2	6.3	22.4	0.14	0.77	1.8	0.0
1	10	178	3.111	10.491	978.01	0.23	60.0	-0.10	18.1	6.0	21.1	0.22	0.74	1.3	0.0
1	11	178	3.161	12.001	1085.01	0.13	62.4	-5.20	22.9	6.1	26.0	0.29	0.72	2.2	0.0
1	12	178	3.171	11.401	1076.01	0.14	63.3	-3.10	71.4	3.9	73.4	0.71	0.53	1.3	0.0
1	13	178	3.201	10.401	1008.01	0.18	68.1	-6.80	23.4	4.8	25.8	0.33	0.68	2.2	0.0
1	14	178	3.301	11.251	1086.01	0.13	71.4	2.30	72.0	3.4	73.7	0.66	0.52	3.1	0.0
1	15	178	3.301	12.001	1103.01	0.13	71.2	3.10	71.7	3.6	73.5	0.64	0.53	3.1	0.0
1	16	178	3.311	12.001	1081.01	0.15	70.7	5.60	71.9	3.7	73.8	0.63	0.54	3.1	0.0
1	17	178	4.21	11.301	1080.01	0.11	71.6	-2.10	43.7	4.4	45.9	0.45	0.69	4.9	0.0
1	18	178	4.21	12.001	1052.01	0.11	71.5	-1.40	43.9	4.5	46.2	0.44	0.69	4.9	0.0
2	1	178	5.271	12.071	899.01	0.18	59.1	31.30	31.2	6.0	34.2	0.03	0.81	1.8	0.0
2	2	178	5.281	12.001	890.01	0.19	58.2	30.30	31.4	6.0	34.4	0.05	0.80	2.2	0.0
2	3	178	5.291	11.331	921.01	0.14	56.0	29.60	36.8	6.1	39.9	0.11	0.79	2.2	0.0
2	4	178	5.301	12.121	869.01	0.26	54.2	31.80	36.8	6.1	39.9	0.09	0.79	1.3	0.0
2	5	178	6.31	12.321	986.01	0.18	62.0	17.80	72.9	3.9	74.9	0.58	0.57	2.7	0.0
2	6	178	6.41	12.121	1036.01	0.27	61.0	18.40	72.6	4.3	74.8	0.54	0.60	2.2	0.0
2	7	178	6.61	11.381	912.01	0.11	60.5	19.30	72.7	3.6	74.5	0.61	0.56	3.1	0.0
2	8	178	6.61	12.161	923.01	0.11	60.5	19.80	72.7	3.6	74.5	0.59	0.58	3.1	0.0
2	9	178	6.91	11.301	903.01	0.11	57.7	18.80	82.3	3.5	84.1	0.72	0.52	3.1	0.0
2	10	178	6.91	12.201	927.01	0.12	57.7	19.50	83.2	3.4	84.9	0.70	0.50	3.1	0.0
2	11	178	6.101	12.001	928.01	0.0	57.2	14.90	83.4	3.4	84.1	0.75	0.49	2.2	0.0
2	12	178	6.121	11.281	882.01	0.19	55.9	28.20	87.6	3.3	89.9	0.69	0.51	3.6	0.0
2	13	178	6.151	12.061	954.01	0.0	55.1	18.30	87.6	3.5	89.4	0.75	0.48	4.0	0.0
2	14	178	6.161	12.081	931.01	0.10	54.6	22.40	88.5	3.5	89.4	0.75	0.48	4.0	0.0
2	15	178	6.161	13.001	885.01	0.09	54.7	23.40	88.5	3.5	89.4	0.75	0.48	4.0	0.0
2	16	178	6.161	13.211	851.01	0.10	54.6	24.20	88.5	3.5	89.4	0.75	0.48	4.0	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA-0.0 0.0 #TSTAR

ETA-0.831 -.418#TSTAR -.0581#TSTAR\*\*2

LEAST SQUARE FIT

ETA-0.839 -.466#TSTAR

ETA-0.831 -.417#TSTAR -.0501#TSTAR\*\*2

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NDS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE.JUELICH


SITE = 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASHRAE/BSE = 1/21 = 1 NUMBER OF DATA POINTS = 16

ID	NO	DATE	HOUR	I	ID/1	FLOH	TA	TI	IDELT(I)	TH	TM	ETA	WIND	TSKY	
1	1	178	5.311	9.101	856.01	0.26	36.4	21.40	32.0	7.5	35.7	0.17	0.74	1.2	0.0
1	2	178	5.311	9.351	836.01	0.25	36.5	22.30	32.0	7.7	35.8	0.16	0.74	1.5	0.0
1	3	178	5.311	12.351	925.01	0.27	37.7	25.90	51.4	7.1	51.9	0.31	0.60	2.0	0.0
1	4	178	5.311	13.101	942.01	0.26	37.6	26.50	51.4	7.5	55.1	0.30	0.70	2.1	0.0
1	5	178	6.11	9.251	868.01	0.25	38.1	23.50	70.0	5.4	72.7	0.57	0.55	1.0	0.0
1	6	178	6.11	10.151	904.01	0.23	38.1	25.50	70.0	6.0	73.0	0.52	0.59	1.2	0.0
1	7	178	6.11	14.351	957.01	0.34	43.6	28.40	80.9	5.1	83.4	0.56	0.55	1.0	0.0
1	8	178	6.21	9.301	752.01	0.37	43.4	23.20	94.8	2.6	96.0	0.97	0.35	1.0	0.0
1	9	178	6.21	9.301	777.01	0.36	43.4	23.40	94.8	2.7	96.2	0.94	0.35	2.0	0.0
1	10	178	6.161	13.201	887.01	0.39	37.8	27.80	59.5	2.9	62.1	0.45	0.61	1.0	0.0
1	11	178	6.191	9.401	894.01	0.32	39.2	20.00	26.5	7.5	30.2	0.11	0.77	0.8	0.0
1	12	178	6.191	10.151	918.01	0.31	39.6	21.10	26.5	7.6	30.3	0.10	0.77	0.8	0.0
1	13	178	6.191	10.501	975.01	0.29	38.1	21.60	26.4	8.4	30.6	0.09	0.77	1.0	0.0
1	14	178	6.191	13.301	988.01	0.32	39.5	24.20	25.0	8.3	28.2	0.05	0.78	1.0	0.0
1	15	178	6.191	14.001	985.01	0.28	39.6	24.20	25.3	8.3	29.4	0.05	0.78	0.8	0.0
1	16	178	6.191	16.201	809.01	0.29	41.0	23.50	59.5	5.2	62.1	0.48	0.62	0.5	0.0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NDS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE.JUELICH

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR  
 ETA=0.800 -.360\*TSTAR -.130(TSTAR\*\*2)  
 LEAST SQUARE FIT  
 ETA=0.821 -.477\*TSTAR  
 ETA=0.804 -.356\*TSTAR -.126(TSTAR\*\*2)




T\* = UTM. - IRI/ I

COLLECTOR TYPE : IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: UERRARY  
 REFERENCE AREA: 1.79 (1\*\*2); FLUID: WATER ; SLOPE: 7 DEGREE; HEIDELBERG

SITE = 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASHRAE /BSE = 1/21 = 1 NUMBER OF DATA POINTS : 29

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	TM	T*	ETA	WIND	TSKY
1	1	0	0	0	0	896.0	15.30	0.0	9.2	27.9	0.13	0.75	0.8	0.0
1	2	0	0	0	0	951.0	15.40	0.0	9.0	36.5	0.21	0.70	0.8	0.0
1	3	0	0	0	0	956.0	17.70	0.0	8.8	46.6	0.31	0.67	0.8	0.0
1	4	0	0	0	0	915.0	16.80	0.0	7.5	55.2	0.42	0.60	0.8	0.0
1	5	0	0	0	0	920.0	17.90	0.0	7.6	65.4	0.52	0.60	1.3	0.0
1	6	0	0	0	0	836.0	18.30	0.0	6.1	74.8	0.88	0.52	1.3	0.0
1	7	0	0	0	0	738.0	17.60	0.0	4.6	83.3	0.89	0.46	1.0	0.0
1	8	0	0	0	0	907.0	16.20	0.0	7.0	94.3	0.85	0.56	0.0	0.0
1	9	0	0	0	0	936.0	16.20	0.0	6.8	85.6	0.72	0.53	0.0	0.0
1	10	0	0	0	0	943.0	20.70	0.0	8.0	85.4	0.58	0.62	0.0	0.0
1	11	0	0	0	0	999.0	20.00	0.0	8.1	65.6	0.46	0.51	0.0	0.0
1	12	0	0	0	0	980.0	22.10	0.0	7.2	58.5	0.37	0.57	0.0	0.0
1	13	0	0	0	0	901.0	11.20	0.0	6.2	73.9	0.70	0.57	0.3	0.0
1	14	0	0	0	0	968.0	12.20	0.0	6.7	74.1	0.64	0.56	0.3	0.0
1	15	0	0	0	0	1044.0	13.20	0.0	7.4	74.6	0.59	0.58	0.3	0.0
1	16	0	0	0	0	1047.0	17.90	0.0	9.0	46.4	0.27	0.73	0.0	0.0
1	17	0	0	0	0	862.0	29.40	0.0	7.4	36.3	0.08	0.87	5.0	0.0
1	18	0	0	0	0	717.0	28.80	0.0	6.3	35.6	0.09	0.79	5.0	0.0
1	19	0	0	0	0	903.0	25.50	0.0	8.5	36.7	0.12	0.80	5.0	0.0
1	20	0	0	0	0	910.0	23.30	0.0	9.5	37.3	0.15	0.78	5.0	0.0
1	21	0	0	0	0	917.0	23.50	0.0	9.8	38.6	0.16	0.80	5.0	0.0
1	22	0	0	0	0	923.0	23.10	0.0	9.9	38.4	0.17	0.80	5.0	0.0
1	23	0	0	0	0	904.0	30.8	0.0	9.9	38.5	0.16	0.79	5.0	0.0
1	24	0	0	0	0	894.0	23.80	0.0	10.0	38.5	0.15	0.80	5.0	0.0
1	25	0	0	0	0	889.0	31.1	0.0	10.0	38.4	0.15	0.81	5.0	0.0
1	26	0	0	0	0	864.0	25.30	0.0	7.4	32.2	0.08	0.87	5.0	0.0
1	27	0	0	0	0	717.0	25.10	0.0	6.3	31.9	0.09	0.79	5.0	0.0
1	28	0	0	0	0	903.0	26.00	0.0	8.5	37.2	0.12	0.80	5.0	0.0
1	29	0	0	0	0	910.0	32.0	0.0	8.2	36.0	0.12	0.80	5.0	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.836 -.422\*1STAR  
 ETA=0.0 0.0 \*1STAR 0.0 (1STAR\*\*2)

LEAST SQUARE FIT


ETA=0.844 -.436\*1STAR  
 ETA=0.898 -.898\*1STAR 0.460(1STAR\*\*2)

D

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : MBS/ASHKHE ; SITE:GERMANY  
 REFERENCE AREA: 1.789 M<sup>2</sup>; FLUID: WATER ; SLOPE: 40.5 DEGREE-STUTT.

SITE = 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASHKHE/BSE = 1/21 = 1 NUMBER OF DATA POINTS = 30

ID	NO	DATE	HO	HR	I	IO/I	FLOW	TA	TI	DELTA T	TM	TA	ETA	HIND	TSKY		
1	1	178	5	27	10	33	788.51	0.27	34.4	19.81	0.0	6.2	54.4	0.44	0.64	0.0	0.0
1	2	178	5	27	10	58	857.61	0.26	35.5	19.64	0.0	6.9	56.2	0.43	0.65	0.0	0.0
1	3	178	5	28	10	19	747.31	0.26	35.9	20.94	0.0	5.6	55.9	0.47	0.64	0.0	0.0
1	4	178	5	28	10	54	820.41	0.29	36.6	21.16	0.0	6.1	58.3	0.45	0.64	0.0	0.0
1	5	178	5	29	9	47	652.01	0.31	42.0	22.00	0.0	3.7	62.2	0.62	0.56	0.0	0.0
1	6	178	5	29	10	59	810.51	0.30	42.3	22.78	0.0	5.3	63.7	0.50	0.64	0.0	0.0
1	7	178	5	30	9	42	648.81	0.24	36.4	24.26	0.0	4.4	62.3	0.59	0.58	0.0	0.0
1	8	178	5	30	10	10	718.71	0.29	36.9	23.61	0.0	5.1	62.5	0.54	0.62	0.0	0.0
1	9	178	5	30	11	57	913.91	0.20	37.7	24.28	0.0	6.7	64.3	0.44	0.64	0.0	0.0
1	10	178	5	30	13	10	895.01	0.21	37.7	24.51	0.0	6.6	66.5	0.49	0.65	0.0	0.0
1	11	178	5	31	10	13	733.71	0.28	38.3	21.45	0.0	4.5	62.1	0.55	0.55	0.0	0.0
1	12	178	5	31	12	14	869.21	0.21	37.8	23.33	0.0	6.5	65.9	0.48	0.65	0.0	0.0
1	13	178	5	31	13	44	819.91	0.23	37.9	24.11	0.0	5.9	66.6	0.52	0.64	0.0	0.0
1	14	178	5	31	14	52	681.11	0.25	38.0	26.77	0.0	4.6	65.2	0.56	0.60	0.0	0.0
1	15	178	6	1	10	34	714.61	0.30	38.8	23.48	0.0	3.5	92.2	0.96	0.45	0.0	0.0
1	16	178	6	1	11	21	752.51	0.33	37.8	24.84	0.0	4.4	84.6	0.79	0.52	0.0	0.0
1	17	178	6	1	12	00	866.21	0.24	37.2	25.70	0.0	5.5	84.9	0.68	0.55	0.0	0.0
1	18	178	6	1	13	01	811.21	0.25	36.3	26.51	0.0	5.2	84.3	0.71	0.55	0.0	0.0
1	19	178	6	2	10	03	668.41	0.31	36.6	26.42	0.0	5.0	48.4	0.33	0.64	0.0	0.0
1	20	178	6	2	11	09	794.41	0.28	30.6	27.67	0.0	7.1	58.5	0.39	0.64	0.0	0.0
1	21	178	6	2	12	05	865.21	0.27	31.1	27.09	0.0	7.7	65.9	0.45	0.65	0.0	0.0
1	22	178	6	2	12	51	842.41	0.28	31.9	28.74	0.0	7.4	69.6	0.49	0.64	0.0	0.0
1	23	178	6	3	14	02	800.11	0.31	32.3	28.38	0.0	6.6	72.5	0.55	0.63	0.0	0.0
1	24	178	6	3	10	20	738.51	0.23	36.3	28.48	0.0	7.3	29.0	0.01	0.83	0.0	0.0
1	25	178	6	3	11	30	856.11	0.20	36.3	27.95	0.0	6.6	29.6	0.02	0.85	0.0	0.0
1	26	178	6	4	10	05	693.21	0.27	36.7	26.79	0.0	6.5	28.4	0.04	0.80	0.0	0.0
1	27	178	6	4	10	52	769.31	0.26	36.6	26.74	0.0	7.6	30.3	0.05	0.82	0.0	0.0
1	28	178	6	4	11	41	833.91	0.26	36.9	28.35	0.0	8.2	30.5	0.02	0.85	0.0	0.0
1	29	178	6	4	12	03	840.21	0.26	36.9	28.39	0.0	8.2	30.6	0.03	0.84	0.0	0.0
1	30	178	6	4	12	58	861.51	0.26	36.7	28.7	0.0	8.2	30.6	0.03	0.84	0.0	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.838 - .424\*TSTAR

ETA=0.0 0.0 =TSTAR 0.0 (TSTAR#2)

LEAST SQUARE FIT

ETA=0.838 - .423\*TSTAR

ETA=0.845 - .501\*TSTAR 0.102(TSTAR#2)

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : RAS/RSURIE ; SITE: DENMARK  
 REFERENCE AREA: 1.70 m\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE; COPENHAGEN  
 DK

NUMBER OF DATA POINTS = 40

TEST-PROCEDURE (ASHKIE/SSE = 1/21 = 1

COLLECTOR TYPE IEA-1

ID	NO	DATE	HOUR	I	ID/I	FLOW	TR	TI	DEL'AT	TM	Y*	ETA	HIND	TSKY
1	1	177	8	21	11	151	961	0.1	0.22	19.9	0.04	0.05	6.0	0.0
1	2	177	8	21	11	301	951	0.1	0.23	19.8	0.04	0.84	6.0	0.0
1	3	177	8	21	11	451	944	0.1	0.23	19.8	0.04	0.84	6.0	0.0
1	4	177	8	21	12	001	976	0.1	0.22	19.9	0.03	0.89	6.0	0.0
1	5	177	8	21	12	151	984	0.1	0.23	19.9	0.03	0.84	6.0	0.0
1	6	177	8	21	12	301	980	0.1	0.24	19.9	0.03	0.89	6.0	0.0
1	7	177	8	21	12	451	998	0.1	0.33	22.9	0.07	0.84	6.0	0.0
1	8	177	8	21	11	301	907	0.1	0.33	22.9	0.07	0.84	6.0	0.0
1	9	177	8	21	11	451	898	0.1	0.35	22.9	0.07	0.84	6.0	0.0
1	10	177	8	21	12	001	916	0.1	0.36	22.9	0.07	0.82	6.0	0.0
1	11	177	8	21	12	151	918	0.1	0.37	22.9	0.06	0.84	6.0	0.0
1	12	177	8	21	12	301	886	0.1	0.40	22.9	0.06	0.85	6.0	0.0
2	1	177	8	24	11	001	930	0.1	0.25	43.0	0.32	0.70	2.0	0.0
2	2	177	8	24	11	151	913	0.1	0.29	42.9	0.32	0.69	2.0	0.0
2	3	177	8	24	11	301	830	0.1	0.28	42.9	0.34	0.67	2.0	0.0
2	4	177	8	24	11	451	998	0.1	0.27	43.0	0.29	0.71	2.0	0.0
2	5	177	8	24	12	001	967	0.1	0.24	42.9	0.30	0.70	2.0	0.0
2	6	177	8	24	12	151	908	0.1	0.22	43.0	0.29	0.71	2.0	0.0
2	7	177	8	24	12	301	983	0.1	0.21	43.0	0.29	0.71	2.0	0.0
2	8	177	8	24	12	451	982	0.1	0.22	43.1	0.29	0.71	2.0	0.0
2	9	177	8	16	11	151	957	0.1	0.0	47.7	0.35	0.66	6.0	0.0
2	10	177	8	16	11	301	984	0.1	0.0	47.9	0.35	0.66	6.0	0.0
2	11	177	8	16	11	451	973	0.1	0.0	47.9	0.35	0.66	6.0	0.0
2	12	177	8	16	12	001	973	0.1	0.0	47.9	0.34	0.67	6.0	0.0
2	13	177	8	16	12	151	965	0.1	0.0	47.9	0.34	0.67	6.0	0.0
2	14	177	8	16	12	301	959	0.1	0.0	47.9	0.34	0.67	6.0	0.0
2	15	177	8	17	11	301	851	0.1	0.37	58.2	0.60	0.52	1.0	0.0
2	16	177	8	17	11	451	944	0.1	0.25	59.3	0.54	0.59	1.0	0.0
2	17	177	8	17	12	001	982	0.1	0.23	59.3	0.52	0.56	1.0	0.0
2	18	177	8	17	12	151	937	0.1	0.24	59.3	0.54	0.58	1.0	0.0
2	19	177	8	21	11	151	974	0.1	0.18	77.6	0.66	0.45	2.0	0.0
2	20	177	8	22	11	301	980	0.1	0.19	78.8	0.65	0.49	2.0	0.0
2	21	177	8	22	11	451	985	0.1	0.21	78.5	0.65	0.50	2.0	0.0
2	22	177	8	22	12	001	981	0.1	0.19	78.7	0.65	0.50	2.0	0.0
2	23	177	8	22	12	151	978	0.1	0.20	78.8	0.65	0.51	2.0	0.0
2	24	177	8	22	12	301	982	0.1	0.20	78.7	0.66	0.50	2.0	0.0
2	25	177	8	30	11	301	894	0.1	0.28	87.4	0.77	0.39	6.0	-5.0
2	26	177	8	30	11	451	901	0.1	0.28	87.5	0.77	0.40	6.0	-5.0
2	27	177	8	30	12	001	882	0.1	0.31	87.7	0.79	0.40	6.0	-5.0
2	28	177	8	30	12	151	880	0.1	0.31	87.6	0.78	0.39	6.0	-5.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA-0.0 0.0 \*TSTAR


ETA-0.0 0.0 \*TSTAR 0.0 TSTAR\*\*21

LEAST SQUARE FIT

ETA-0.073 -.589\*TSTAR


COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: DENMARK  
 REFERENCE AREA: 1.78 M<sup>2</sup>; FLUID: WATER ; SLOPE: 45 DEGREE, COPENHAGEN

□ □  
 —  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0



COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: G-BRITAIN  
 REFERENCE AREA: 1.785 M<sup>2</sup>; FLUID: WATER ; SLOPE: 45 DEGREE, CARDIFF

□ □  
 —  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0



GB

COLLECTOR TYPE: IER-1 | TESTING PROCEDURE: MDS/MASHRAE | DATE: 01.01.2011  
REFERENCE AREA: 1.785 M\*\*2, FLUID: WATER, SLOPE: 45 DEGREE, CARNOFF

SITE = GB | TEST-PROCEDURE: MASHRAE/BSE = 1/2 | NUMBER OF DATA POINTS = 82

COLLECTOR TYPE: IER-1 | TEST-PROCEDURE: MASHRAE/BSE = 1/2 | NUMBER OF DATA POINTS = 82

ID	NO	DATE	HOUR	I	ID/I	FLOW	TR	TI	DELTA	TH	TK	ETA	WIND	TSKY
1	177	8.23	11.45	894.0	0.20	25.5	20.00	0.0	10.6	35.6	0.18	0.73	0.5	0.0
1	177	8.23	11.50	902.0	0.19	25.5	20.10	0.0	10.5	36.0	0.18	0.70	0.5	0.0
1	3	177	8.23	11.55	902.0	0.19	20.60	0.0	10.4	36.5	0.18	0.69	0.5	0.0
1	4	177	8.23	12.00	894.0	0.19	25.5	0.0	10.5	37.2	0.18	0.70	0.5	0.0
1	5	177	8.23	12.05	886.0	0.19	20.50	0.0	10.6	38.0	0.20	0.72	1.0	0.0
1	6	177	8.23	12.15	919.0	0.19	25.5	0.0	10.7	38.9	0.21	0.70	1.5	0.0
1	7	177	8.23	12.20	862.0	0.20	20.30	0.0	10.8	39.5	0.22	0.75	0.5	0.0
1	8	177	8.23	12.25	894.0	0.20	20.50	0.0	10.8	40.0	0.22	0.72	0.5	0.0
1	9	177	8.23	12.30	902.0	0.20	20.50	0.0	10.5	40.5	0.23	0.70	0.5	0.0
1	10	177	8.23	12.35	910.0	0.20	20.00	0.0	10.8	41.1	0.23	0.71	0.5	0.0
1	11	177	8.23	12.40	927.0	0.18	20.10	0.0	10.7	41.5	0.23	0.69	1.0	0.0
1	12	177	8.23	12.45	927.0	0.18	20.50	0.0	10.7	42.0	0.23	0.69	1.0	0.0
1	13	177	8.23	12.50	919.0	0.18	20.50	0.0	10.8	42.6	0.24	0.70	1.0	0.0
1	14	177	8.23	12.50	919.0	0.18	20.90	0.0	9.1	20.1	0.15	0.78	0.5	0.0
1	15	177	8.23	12.55	894.0	0.19	16.00	0.0	9.2	26.3	0.15	0.78	0.5	0.0
1	16	177	8.23	12.55	894.0	0.19	16.00	0.0	9.6	27.2	0.14	0.79	1.5	0.0
1	17	177	8.23	12.55	894.0	0.19	16.00	0.0	9.8	27.8	0.16	0.78	1.0	0.0
1	18	177	8.23	12.55	894.0	0.19	16.00	0.0	9.9	28.3	0.16	0.77	1.5	0.0
1	19	177	8.23	12.55	894.0	0.19	18.00	0.0	10.4	45.7	0.32	0.72	1.0	0.0
1	20	177	8.23	12.55	894.0	0.19	18.00	0.0	10.6	46.6	0.31	0.70	1.5	0.0
1	21	177	8.23	12.55	894.0	0.19	18.00	0.0	10.5	46.7	0.32	0.71	1.5	0.0
1	22	177	8.23	12.55	894.0	0.19	18.50	0.0	10.4	47.8	0.32	0.68	1.5	0.0
1	23	177	8.23	12.55	894.0	0.19	18.50	0.0	10.7	48.1	0.32	0.70	1.5	0.0
1	24	177	8.23	12.55	894.0	0.19	18.10	0.0	10.9	48.7	0.33	0.69	1.5	0.0
1	25	177	8.23	12.55	894.0	0.19	18.00	0.0	5.4	63.0	0.88	0.43	1.5	0.0
1	26	177	8.23	12.55	894.0	0.19	18.00	0.0	4.9	62.5	0.82	0.42	1.5	0.0
1	27	177	8.23	12.55	894.0	0.19	17.50	0.0	4.7	62.4	0.95	0.41	1.5	0.0
1	28	177	8.23	12.55	894.0	0.19	17.50	0.0	3.9	76.5	1.04	0.41	1.5	0.0
1	29	177	8.23	12.55	894.0	0.19	18.30	0.0	9.8	44.2	0.31	0.70	1.5	0.0
1	30	177	8.23	12.55	894.0	0.19	18.30	0.0	9.6	44.7	0.31	0.69	1.5	0.0
1	31	177	8.23	12.55	894.0	0.19	18.50	0.0	9.4	44.6	0.33	0.71	1.5	0.0
1	32	177	8.23	12.55	894.0	0.19	19.00	0.0	8.5	44.8	0.35	0.68	1.5	0.0
1	33	177	8.23	12.55	894.0	0.19	17.80	0.0	8.1	44.6	0.36	0.65	1.5	0.0
1	34	177	8.23	12.55	894.0	0.19	18.80	0.0	8.1	45.3	0.37	0.67	1.5	0.0
1	35	177	8.23	12.55	894.0	0.19	18.50	0.0	8.1	45.6	0.38	0.67	1.5	0.0
1	36	177	8.23	12.55	894.0	0.19	19.50	0.0	7.9	45.7	0.37	0.67	1.5	0.0
1	37	177	8.23	12.55	894.0	0.19	19.00	0.0	7.7	45.8	0.39	0.67	1.5	0.0
1	38	177	8.23	12.55	894.0	0.19	18.00	0.0	7.7	45.8	0.41	0.68	1.5	0.0
1	39	177	8.23	12.55	894.0	0.19	18.30	0.0	7.2	46.3	0.42	0.65	1.5	0.0
1	40	177	8.23	12.55	894.0	0.19	18.10	0.0	7.1	46.5	0.44	0.66	1.5	0.0
1	41	177	8.23	12.55	894.0	0.19	19.00	0.0	6.8	46.5	0.44	0.65	1.5	0.0
1	42	177	8.23	12.55	894.0	0.19	18.50	0.0	6.5	46.4	0.46	0.64	1.5	0.0
1	43	177	8.23	12.55	894.0	0.19	17.90	0.0	7.0	44.9	0.40	0.62	1.5	0.0
1	44	177	8.23	12.55	894.0	0.19	18.20	0.0	7.1	45.4	0.41	0.65	1.0	0.0
1	45	177	8.23	12.55	894.0	0.19	19.20	0.0	7.6	60.0	0.53	0.60	0.5	0.0
1	46	177	8.23	12.55	894.0	0.19	19.00	0.0	7.5	59.8	0.52	0.57	1.5	0.0
1	47	177	8.23	12.55	894.0	0.19	20.00	0.0	8.0	60.4	0.49	0.57	1.0	0.0
1	48	177	8.23	12.55	894.0	0.19	20.10	0.0	8.3	60.9	0.49	0.60	1.0	0.0
1	49	177	8.23	12.55	894.0	0.19	20.50	0.0	8.4	60.7	0.49	0.61	1.0	0.0
1	50	177	8.23	12.55	894.0	0.19	20.50	0.0	8.7	61.0	0.49	0.63	1.0	0.0
1	51	177	8.23	12.55	894.0	0.19	20.20	0.0	7.5	60.3	0.54	0.60	0.5	0.0
1	52	177	8.23	12.55	894.0	0.19	20.20	0.0	7.7	60.8	0.54	0.61	1.5	0.0
1	53	177	8.23	12.55	894.0	0.19	20.00	0.0	7.6	60.9	0.54	0.60	1.0	0.0
1	54	177	8.23	12.55	894.0	0.19	19.80	0.0	8.2	60.4	0.52	0.63	1.0	0.0
1	55	177	8.23	12.55	894.0	0.19	20.20	0.0	7.7	61.0	0.51	0.58	1.0	0.0
1	56	177	8.23	12.55	894.0	0.19	20.20	0.0	8.0	61.6	0.50	0.53	1.0	0.0

GB

1	57	177.	9.14	12.551	813.01	0.19	25.5	20.10	0.0	8.6	61.4	0.51	0.63	1.0	0.0
1	58	177.	9.14	13.001	821.01	0.19	25.5	20.10	0.0	8.6	61.5	0.50	0.63	1.0	0.0
1	59	177.	9.14	13.051	829.01	0.19	25.5	20.50	0.0	8.3	61.5	0.49	0.60	1.0	0.0
1	60	177.	9.14	14.101	772.01	0.20	25.5	20.20	0.0	6.8	73.6	0.69	0.53	3.0	0.0
1	61	177.	9.14	14.151	756.01	0.24	25.5	20.80	0.0	6.0	73.2	0.69	0.47	2.5	0.0
1	62	177.	9.14	14.201	748.01	0.24	25.5	20.70	0.0	6.3	73.1	0.70	0.50	2.0	0.0
1	63	177.	9.14	14.251	764.01	0.24	25.5	20.60	0.0	6.7	73.2	0.69	0.52	3.5	0.0
1	64	177.	9.14	14.301	756.01	0.24	25.5	20.40	0.0	6.5	72.6	0.69	0.51	2.0	0.0
1	65	177.	9.14	14.351	732.01	0.25	25.5	20.50	0.0	6.2	72.6	0.71	0.50	2.5	0.0
1	66	177.	9.14	14.551	602.01	0.31	25.5	20.60	0.0	5.1	71.3	0.84	0.51	2.0	0.0
1	67	177.	9.14	15.001	626.01	0.30	25.5	20.50	0.0	5.2	71.2	0.81	0.49	2.5	0.0
1	68	177.	9.14	15.051	618.01	0.26	25.5	20.70	0.0	5.2	70.7	0.81	0.50	1.5	0.0
1	69	177.	9.14	15.101	626.01	0.26	25.5	20.50	0.0	5.0	68.8	0.79	0.48	1.0	0.0
1	70	177.	9.14	15.151	634.01	0.23	25.5	20.50	0.0	5.2	69.2	0.77	0.49	2.0	0.0
1	71	177.	9.14	15.201	634.01	0.23	25.5	20.20	0.0	5.4	68.7	0.76	0.50	2.5	0.0
1	72	177.	9.14	15.251	626.01	0.22	25.5	20.80	0.0	4.8	68.5	0.76	0.46	2.5	0.0
1	73	177.	9.14	15.301	610.01	0.23	25.5	20.10	0.0	5.0	68.2	0.79	0.49	2.0	0.0
1	74	177.	9.14	15.351	593.01	0.22	25.5	20.20	0.0	4.6	67.6	0.80	0.46	2.0	0.0
1	75	177.	9.14	15.401	585.01	0.22	25.5	20.10	0.0	4.9	67.9	0.82	0.50	3.0	0.0
1	76	177.	9.14	15.451	568.01	0.23	25.5	20.00	0.0	4.5	67.0	0.83	0.47	2.5	0.0
1	77	177.	9.14	15.501	553.01	0.22	25.5	20.00	0.0	4.3	66.6	0.84	0.46	2.0	0.0
1	78	177.	9.14	15.551	545.01	0.22	25.5	19.80	0.0	4.2	66.3	0.85	0.46	2.0	0.0
1	79	177.	9.14	16.001	528.01	0.0	25.5	20.00	0.0	4.1	65.8	0.87	0.47	2.0	0.0
1	80	177.	9.14	16.051	512.01	0.0	25.5	20.10	0.0	4.1	65.5	0.89	0.47	0.0	0.0
1	81	177.	9.14	16.101	496.01	0.0	25.5	20.00	0.0	4.1	65.3	0.91	0.49	0.0	0.0
1	82	177.	9.14	16.151	488.01	0.0	25.5	20.00	0.0	3.9	65.1	0.93	0.48	0.0	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.840    -.450\* $TSTAR$

ETA=0.0    0.0 \* $TSTAR$     0.0 ( $TSTAR^2$ )

LEAST SQUARE FIT

ETA=0.813    -.408\* $TSTAR$

ETA=0.818    -.427\* $TSTAR$     0.018( $TSTAR^2$ )



COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ;SITE: JAPAN  
 REFERENCE AREA: 1.785 M\*\*2; FLUID: WATER;SLOPE:37.9 DEGREE. NAGOYA

J


SITE = J COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE / 1/2) = 1 NUMBER OF DATA POINTS = 16

ID	NO	DATE	HOUR	I	ID/I	FLOH	TA	TI	DELTA T	TH	T*	ETA	WIND	TSKY
1	1	178.	4.14	10.321	864.41	0.27	12.45	0.0	7.3	28.4	0.18	0.72	1.5	0.0
1	2	178.	4.14	11.371	935.11	0.25	14.44	0.0	8.3	28.7	0.15	0.77	1.1	0.0
1	3	178.	4.14	12.071	894.61	0.26	16.15	0.0	8.0	28.5	0.14	0.77	0.5	0.0
1	4	178.	4.14	13.221	818.41	0.27	18.51	0.0	7.3	28.2	0.12	0.76	1.4	0.0
1	5	178.	4.14	13.521	767.61	0.29	19.09	0.0	6.0	27.9	0.12	0.76	1.1	0.0
1	6	178.	4.15	11.071	832.41	0.33	19.80	0.0	6.7	43.5	0.29	0.68	0.8	0.0
1	7	178.	4.15	12.221	812.51	0.34	22.35	0.0	6.9	43.5	0.26	0.71	1.2	0.0
1	8	178.	4.15	13.221	753.21	0.39	23.33	0.0	5.9	43.0	0.27	0.69	1.6	0.0
1	9	178.	4.19	10.371	939.41	0.16	16.86	0.0	6.1	59.8	0.46	0.56	3.0	0.0
1	10	178.	4.19	12.221	967.51	0.18	19.16	0.0	7.2	60.3	0.43	0.64	1.7	0.0
1	11	178.	4.19	13.221	886.61	0.20	20.92	0.0	6.5	60.3	0.44	0.63	1.5	0.0
1	12	178.	4.22	10.521	952.01	0.14	16.76	0.0	5.1	76.6	0.64	0.49	1.7	0.0
1	13	178.	4.22	11.371	983.81	0.14	18.12	0.0	5.8	77.0	0.60	0.52	1.5	0.0
1	14	178.	4.26	12.071	973.61	0.13	18.87	0.0	5.8	77.4	0.60	0.53	2.6	0.0
1	15	178.	4.26	12.371	969.41	0.12	19.68	0.0	5.8	77.4	0.60	0.53	2.6	0.0
1	16	178.	4.26	13.371	874.01	0.12	20.88	0.0	4.9	76.9	0.64	0.49	2.2	0.0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ;SITE: JAPAN  
 REFERENCE AREA: 1.785 M\*\*2; FLUID: WATER;SLOPE:37.9 DEGREE. NAGOYA

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR  
 ETA=0.830 -.465\*TSTAR -.0911\*TSTAR\*\*2  
 LEAST SQUARE FIT  
 ETA=0.834 -.520\*TSTAR  
 ETA=0.814 -.373\*TSTAR -.19311\*TSTAR\*\*2



**NL**

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ;SITE:NETHERL.

REFERENCE AREA: 1.791 M\*\*2; FLUID: WATER;SLOPE:45.0 DEGREE, DELFT

SITE = NL COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 1 NUMBER OF DATA POINTS = 7

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	Ta	Tm	ETA	WIND	TSKY
1	1	177.6.41	11.30	975.01	0.12	37.4	4.10	0.0	8.1	14.4	0.11	0.79	5.5	0.0
1	2	177.6.41	12.30	1008.01	0.12	37.7	5.10	0.0	8.1	22.6	0.17	0.70	5.5	0.0
1	3	177.6.41	14.00	1000.01	0.12	38.0	7.40	0.0	7.3	32.8	0.25	0.65	5.5	0.0
1	4	177.6.41	14.30	1099.01	0.11	38.6	7.40	0.0	6.8	42.0	0.34	0.60	5.5	0.0
1	5	177.6.41	15.00	1025.01	0.12	39.1	8.20	0.0	6.2	56.5	0.47	0.56	5.5	0.0
1	6	177.6.41	15.30	1018.01	0.12	38.5	8.00	0.0	5.6	68.8	0.60	0.50	5.5	0.0
1	7	177.6.41	16.30	958.01	0.13	38.0	8.10	0.0	4.8	79.3	0.74	0.44	5.5	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.780 -.480\*TSKAR


ETA=0.0 0.0 \*TSKAR 0.0 (TSKAR\*\*2)

LEAST SQUARE FIT

ETA=0.770 -.451\*TSKAR

ETA=0.793 -.597\*TSKAR 0.173(TSKAR\*\*2)

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ;SITE:NETHERL.  
REFERENCE AREA: 1.791 M\*\*2; FLUID: WATER;SLOPE:45.0 DEGREE, DELFT




X-MIN = 0.000000E0  
 X-MAX = 0.126000E1  
 Y-MIN = 0.000000E0  
 Y-MAX = 1.000000E0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: SWEDEN  
 REFERENCE AREA: 1.78 m<sup>2</sup>; FLUID: WATER; SLOPE: 45.0 DEGREE. BORAS

SITE = S COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASHRAE/PSI = 1/21 = 1 NUMBER OF DATA POINTS = 22

ID	NO	DATE	HOUR	I	ID/I	FLOH	TR	TI	DELTA T	TR	TW	ETA	HIND	ISKY
1	1	177	9.20	15.35	707.01	0.07	37.0	0.0	4.3	63.5	0.64	0.51	1.5	0.0
1	2	177	9.20	9.10	770.01	0.05	37.0	0.0	4.3	63.0	0.65	0.47	1.2	0.0
1	3	177	9.20	9.25	810.01	0.04	37.0	0.0	4.6	63.2	0.61	0.48	1.3	0.0
1	4	177	9.22	13.10	894.01	0.09	37.0	0.0	5.3	73.2	0.62	0.50	2.2	0.0
1	5	177	9.22	14.50	801.01	0.09	37.0	0.0	4.2	72.5	0.70	0.44	2.9	0.0
1	6	177	9.26	12.35	936.01	0.07	37.0	0.0	5.3	73.3	0.64	0.48	2.7	0.0
1	7	177	9.26	13.30	932.01	0.07	37.0	0.0	4.3	72.8	0.70	0.43	2.5	0.0
1	8	177	9.26	14.05	794.01	0.07	37.0	0.0	3.9	72.6	0.73	0.41	2.1	0.0
1	9	177	9.26	13.30	865.01	0.07	37.0	0.0	4.6	72.9	0.68	0.44	2.2	0.0
1	10	177	9.21	10.30	902.01	0.05	37.0	0.0	7.6	38.2	0.24	0.72	2.1	0.0
1	11	177	9.21	10.45	929.01	0.05	37.0	0.0	7.8	39.2	0.23	0.72	1.6	0.0
1	12	177	9.21	11.00	934.01	0.05	37.0	0.0	7.9	39.2	0.23	0.72	2.2	0.0
1	13	177	9.21	11.15	936.01	0.06	37.0	0.0	7.9	38.2	0.23	0.72	2.2	0.0
1	14	177	9.22	10.15	866.01	0.08	36.0	0.0	6.5	49.6	0.38	0.63	1.6	0.0
1	15	177	9.22	10.30	880.01	0.07	36.0	0.0	6.4	49.6	0.37	0.62	1.4	0.0
1	16	177	9.22	10.45	881.01	0.07	37.0	0.0	6.4	49.6	0.36	0.62	1.6	0.0
1	17	177	9.22	11.00	880.01	0.08	37.0	0.0	6.4	49.7	0.35	0.62	1.4	0.0
1	18	177	9.21	12.30	923.01	0.06	37.0	0.0	8.6	19.8	0.01	0.80	2.2	0.0
1	19	177	9.21	12.45	933.01	0.06	37.0	0.0	8.6	19.8	0.00	0.79	2.3	0.0
1	20	177	9.21	13.00	938.01	0.07	37.0	0.0	8.6	19.8	0.01	0.79	2.5	0.0
1	21	177	9.21	13.15	936.01	0.07	37.0	0.0	8.6	19.8	0.01	0.79	2.3	0.0
1	22	177	9.21	13.30	934.01	0.08	37.0	0.0	8.6	19.8	0.01	0.79	2.5	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR  
 ETA=0.802 -.344\*TSTAR -.2511\*TSTAR\*\*2

LEAST SQUARE FIT

ETA=0.811 -.520\*TSTAR  
 ETA=0.797 -.346\*TSTAR -.2421\*TSTAR\*\*2

# USA

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:USA  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER;SLOPE:VARIABLE. PHOENIX

SITE = USA      COLLECTOR TYPE IEA-1      TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 1      NUMBER OF DATA POINTS = 20

ID	NO	DATE	HOUR	ID/1	FLOW	TR	TI	DELTA T	TM	ETA	WIND	TSKY		
1	1	176	8.31	9.431	990.01	0.04	35.8	1	9.8	37.8	0.04	0.84	2.2	0.0
1	2	176	8.31	9.581	999.01	0.04	35.7	1	10.0	37.5	0.05	0.84	3.1	0.0
1	3	176	8.31	10.371	1013.01	0.03	35.0	1	8.8	62.7	0.29	0.71	3.1	0.0
1	4	176	8.31	10.521	1013.01	0.03	34.9	1	8.8	62.7	0.29	0.71	4.5	0.0
1	5	176	8.31	11.421	1017.01	0.03	35.1	1	7.6	81.1	0.46	0.62	0.9	0.0
1	6	176	8.31	11.571	1016.01	0.03	35.2	1	7.6	81.1	0.47	0.62	1.8	0.0
1	7	176	8.31	12.371	1015.01	0.04	35.0	1	6.5	95.6	0.62	0.53	4.5	0.0
1	8	176	8.31	12.521	1012.01	0.04	34.9	1	6.4	96.1	0.61	0.53	2.2	0.0
1	9	176	8.31	13.071	1012.01	0.04	34.6	1	6.7	96.1	0.62	0.54	1.3	0.0
1	10	176	8.31	13.221	1008.01	0.04	34.5	1	6.7	96.2	0.62	0.54	2.7	0.0
1	11	176	8.31	14.021	1008.01	0.04	35.4	1	7.8	80.6	0.46	0.64	4.9	0.0
1	12	176	8.31	14.171	1004.01	0.04	35.8	1	7.7	80.3	0.46	0.64	4.9	0.0
1	13	176	8.31	14.521	984.11	0.05	36.2	1	8.4	61.6	0.28	0.71	4.9	0.0
1	14	176	8.31	15.071	1019.01	0.01	36.3	1	8.6	61.2	0.26	0.71	4.5	0.0
1	15	176	9.11	12.231	1006.01	0.04	34.9	1	5.7	108.6	0.72	0.47	0.9	0.0
1	16	176	9.11	12.381	1006.01	0.04	34.9	1	5.6	108.6	0.72	0.46	1.3	0.0
1	17	176	9.11	12.531	1010.01	0.04	34.5	1	5.7	108.8	0.71	0.46	3.1	0.0
1	18	176	9.11	13.081	1011.01	0.04	34.4	1	5.6	108.8	0.71	0.45	3.6	0.0
1	19	176	9.11	13.521	1002.01	0.05	35.3	1	10.0	42.6	0.06	0.83	4.5	0.0
1	20	176	9.11	14.071	996.71	0.05	35.4	1	9.0	42.1	0.04	0.83	2.7	0.0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:USA  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER;SLOPE:VARIABLE. PHOENIX


□ □ □  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0    0.0    \*TSTAR  
 ETA=0.0    0.0    \*TSTAR    0.0    (TSTAR\*\*2)

LEAST SQUARE FIT

ETA=0.858    -.549\*TSTAR  
 ETA=0.851    -.394\*TSTAR    -.203(TSTAR\*\*2)





APPENDIX D

Data: IEA-2 Collector  
NBS Procedure



COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:AUSTRIA  
 REFERENCE AREA: 2.32 m<sup>2</sup>; FLUID:WATER ; SLOPE: 30/47 DEGREE.INNSBRUCK

A

SITE : A COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHRAE/BSE = 1/21 - 1 NUMBER OF DATA POINTS = 22

ID	NO	DATE	HOUR	ID	FLOW	TR	TI	DELTA	TA	TM	ETA	WIND	TSKY
1	1	177	4.29	10.30	953.0	17.20	0.0	8.6	22.3	0.05	0.58	4.5	0.0
1	2	177	5.11	13.57	160.0	11.70	0.0	0.9	26.0	0.89	0.37	0.5	0.0
1	3	177	4.29	11.11	995.0	15.00	0.0	7.4	35.6	0.21	0.48	4.5	0.0
1	4	177	4.29	13.00	953.0	18.00	0.0	6.5	44.0	0.29	0.47	4.5	0.0
1	5	177	4.29	12.02	720.0	16.90	0.0	4.1	53.0	0.50	0.37	4.5	0.0
1	6	177	4.29	14.02	780.0	21.60	0.0	4.3	77.1	0.71	0.35	1.5	0.0
1	7	177	5.41	12.29	1018.0	20.10	0.0	5.7	81.9	0.61	0.35	1.5	0.0
1	8	177	5.41	13.59	780.0	17.30	0.0	4.9	37.6	0.26	0.31	1.5	0.0
1	9	177	5.31	12.52	894.0	21.30	0.0	3.3	42.4	0.24	0.43	2.0	0.0
1	10	177	6.12	13.48	854.0	21.40	0.0	2.8	49.1	0.32	0.39	2.0	0.0
1	2	1	177	6.12	14.25	591.0	0.0	2.3	45.4	0.39	0.46	2.0	0.0
1	2	12	177	6.13	12.44	831.0	0.0	2.7	43.4	0.33	0.38	2.0	0.0
1	2	13	177	6.13	13.20	892.0	0.0	2.7	43.7	0.33	0.38	2.0	0.0
1	2	14	177	6.13	14.09	861.0	0.0	2.7	46.4	0.33	0.37	2.0	0.0
1	2	15	177	6.14	12.09	974.0	0.0	2.9	45.3	0.28	0.36	2.0	0.0
1	2	16	177	6.14	12.45	976.0	0.0	3.0	51.8	0.34	0.39	2.0	0.0
1	2	17	177	6.14	13.51	875.0	0.0	2.5	53.9	0.39	0.36	2.0	0.0
1	2	18	177	6.19	11.15	930.0	0.0	2.3	66.0	0.47	0.32	1.0	0.0
1	2	19	177	6.19	12.00	957.0	0.0	2.4	72.5	0.51	0.34	1.0	0.0
1	2	20	177	6.19	12.30	974.0	0.0	2.3	76.8	0.55	0.32	1.0	0.0
1	2	21	177	6.19	13.14	1032.0	0.0	2.1	79.2	0.54	0.28	1.0	0.0
1	2	22	177	6.20	1.44	1010.0	0.0	2.6	65.9	0.45	0.33	2.0	0.0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:AUSTRIA  
 REFERENCE AREA: 2.32 m<sup>2</sup>; FLUID:WATER ; SLOPE: 30/47 DEGREE.INNSBRUCK

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT


ETA=0.550 0.371\*ISTAR

ETA=0.550 0.371\*ISTAR 0.0771\*ISTAR\*\*2

LEAST SQUARE FIT

ETA=0.459 -.215\*ISTAR

ETA=0.604 -.897\*ISTAR 0.7221\*ISTAR\*\*2





COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHKRE ; SITE: BELGIUM  
 REFERENCE AREA: 2.30 m<sup>2</sup>; FLUID: H2O ; SLOPE: 50 DEGREE; HEVERLEE

B

NUMBER OF DATA POINTS = 58

TESTY-PROCEDURE IASHKRE/BSE = 1/21 \* 1

SITE \* B COLLECTOR TYPE IEA-2

ID	NO	DATE	HOUR	I	IDY1	FLOW	IA	II	DELTA T	TA	TM	ETA	WIND	TSKY
1	1	177	7	41	9.301	626.01	0.0	27.2	0.0	5.2	42.5	0.31	0.41	2.0
1	2	177	7	41	9.501	650.01	0.0	25.0	0.0	6.1	43.1	0.29	0.42	2.0
1	3	177	7	41	10.101	706.01	0.0	23.6	0.0	7.6	43.8	0.27	0.46	2.0
1	4	177	7	41	10.301	764.01	0.0	22.9	0.0	8.4	44.7	0.25	0.46	2.0
1	5	177	7	41	10.501	769.01	0.0	21.8	0.0	9.5	45.6	0.26	0.49	2.0
1	6	177	7	41	11.101	824.01	0.0	21.1	0.0	10.7	46.9	0.25	0.50	2.0
1	7	177	7	41	11.301	827.01	0.0	20.1	0.0	10.9	47.2	0.25	0.48	2.0
1	8	177	7	41	11.501	855.01	0.0	19.4	0.0	11.8	48.4	0.25	0.49	2.0
1	9	177	7	41	12.101	826.01	0.0	19.0	0.0	11.2	49.4	0.26	0.47	2.0
1	10	177	7	41	12.301	856.01	0.0	18.7	0.0	11.2	49.4	0.24	0.45	2.0
1	11	177	7	41	12.501	839.01	0.0	18.4	0.0	11.8	49.4	0.25	0.47	2.0
1	12	177	7	41	13.101	871.01	0.0	18.4	0.0	12.7	51.3	0.25	0.49	2.0
1	13	177	7	41	13.501	792.01	0.0	16.9	0.0	11.5	51.3	0.26	0.45	2.0
1	14	177	7	41	14.301	674.01	0.0	16.1	0.0	10.3	52.2	0.32	0.45	2.0
1	15	177	7	51	10.301	768.01	0.25	34.4	0.0	3.0	75.6	0.64	0.25	2.0
1	16	177	7	51	10.501	800.01	0.27	36.9	0.0	2.9	76.9	0.62	0.25	2.0
1	17	177	7	51	11.101	832.01	0.22	39.4	0.0	3.0	76.9	0.59	0.26	2.0
1	18	177	7	51	11.301	864.01	0.20	36.7	0.0	3.1	80.6	0.61	0.24	2.0
1	19	177	7	51	11.501	848.01	0.23	39.2	0.0	3.1	81.9	0.64	0.26	2.0
1	20	177	7	51	12.101	848.01	0.24	38.1	0.0	3.5	82.8	0.63	0.28	2.0
1	21	177	7	51	12.301	880.01	0.30	37.2	0.0	3.3	84.1	0.62	0.25	2.0
1	22	177	7	51	13.301	800.01	0.29	28.1	0.0	6.2	66.3	0.46	0.40	2.0
1	23	177	7	51	13.501	768.01	0.31	30.8	0.0	5.0	64.4	0.44	0.37	2.0
1	24	177	7	51	14.101	752.01	0.33	29.7	0.0	4.9	62.5	0.43	0.35	2.0
1	25	177	7	51	14.301	656.01	0.46	29.7	0.0	4.3	61.9	0.48	0.39	2.0
1	26	177	7	51	14.501	688.01	0.57	31.4	0.0	4.0	62.5	0.49	0.33	2.0
1	27	177	7	61	9.501	704.01	0.27	16.6	0.0	9.2	46.9	0.32	0.40	2.0
1	28	177	7	61	10.361	768.01	0.29	12.9	0.0	14.0	49.7	0.31	0.43	2.0
1	29	177	7	61	10.501	832.01	0.23	12.4	0.0	15.0	50.3	0.29	0.41	2.0
1	30	177	7	61	11.101	816.01	0.25	11.4	0.0	17.9	52.2	0.31	0.46	2.0
1	31	177	7	61	11.301	872.01	0.28	10.6	0.0	18.3	51.6	0.28	0.41	2.0
1	32	177	7	121	9.501	616.01	0.49	69.3	0.0	2.4	43.8	0.35	0.41	2.0
1	33	177	7	121	10.101	664.01	0.46	66.6	0.0	2.6	43.8	0.32	0.42	2.0
1	34	177	7	121	10.301	704.01	0.43	27.1	0.0	6.8	44.4	0.31	0.48	2.0
1	35	177	7	121	10.501	728.01	0.44	24.0	0.0	8.1	45.3	0.30	0.49	2.0
1	36	177	7	121	11.101	752.01	0.40	22.8	0.0	9.0	46.2	0.29	0.50	2.0
1	37	177	7	121	11.501	792.01	0.38	20.9	0.0	10.2	48.1	0.29	0.49	2.0
1	38	177	7	121	12.101	776.01	0.39	20.3	0.0	10.5	48.4	0.29	0.50	2.0
1	39	177	7	121	12.301	776.01	0.40	19.8	0.0	10.6	46.9	0.25	0.49	2.0
1	40	177	7	121	12.501	760.01	0.46	19.6	0.0	10.6	47.5	0.26	0.47	2.0
1	41	177	7	121	13.101	760.01	0.51	18.5	0.0	10.6	48.1	0.26	0.46	2.0
1	42	177	7	121	13.301	736.01	0.62	16.1	0.0	2.2	48.1	0.27	0.47	2.0
1	43	177	7	121	13.501	688.01	0.72	13.9	0.0	2.1	48.8	0.28	0.46	2.0
1	44	177	7	121	14.101	672.01	0.78	13.9	0.0	1.9	48.8	0.28	0.44	2.0
1	45	177	7	121	14.301	640.01	0.87	13.9	0.0	1.8	48.8	0.30	0.43	2.0
1	46	177	8	51	10.051	736.01	0.17	65.0	0.0	3.0	32.5	0.15	0.48	2.0
1	47	177	8	51	10.251	800.01	0.14	65.0	0.0	3.1	34.0	0.16	0.47	2.0
1	48	177	8	51	10.451	848.01	0.12	62.5	0.0	3.4	35.6	0.16	0.46	2.0
1	49	177	8	51	11.051	880.01	0.14	63.9	0.0	3.6	37.5	0.17	0.48	2.0
1	50	177	8	51	11.251	896.01	0.12	63.3	0.0	3.6	38.9	0.18	0.46	2.0
1	51	177	8	51	11.451	896.01	0.12	62.8	0.0	3.8	40.6	0.20	0.48	2.0
1	52	177	8	51	12.051	904.01	0.12	62.8	0.0	3.8	42.5	0.20	0.48	2.0
1	53	177	8	51	12.251	912.01	0.10	62.8	0.0	3.9	43.7	0.22	0.48	2.0
1	54	177	8	51	12.451	912.01	0.10	62.8	0.0	3.7	45.0	0.23	0.47	2.0
1	55	177	8	51	13.051	896.01	0.09	64.7	0.0	3.7	45.2	0.23	0.49	2.0
1	56	177	8	51	13.251	864.01	0.13	64.4	0.0	3.6	46.2	0.24	0.49	2.0

**B**

1	57	177.	8.	51	13.451	832.01	0.22	4.64	4.	23.80	0.0	3.4	46.2	0.27	0.49	2.0	0.0	1
1	58	177.	8.	51	14.051	816.01	0.33	1.64	4.	24.10	0.0	3.3	46.2	0.27	0.47	2.0	0.0	1
1	59	177.	8.	51	14.251	768.01	0.47	1.64	7.	25.10	0.0	3.0	46.2	0.27	0.47	2.0	0.0	1
1	60	177.	8.	51	14.451	704.01	0.62	1.63	1.	23.50	0.0	2.9	46.2	0.32	0.50	2.0	0.0	1
1	61	177.	9.	131	9.301	768.01	0.17	44.2	1.	13.20	0.0	4.7	24.0	0.14	0.49	2.0	0.0	1
1	62	177.	9.	141	10.501	780.01	0.24	42.8	1.	16.63	0.0	5.0	29.4	0.16	0.50	2.0	0.0	1
1	63	177.	9.	141	11.101	825.01	0.19	42.5	1.	17.50	0.0	5.3	31.3	0.17	0.49	2.0	0.0	1
1	64	177.	9.	141	11.301	800.01	0.17	41.1	1.	17.30	0.0	5.3	32.5	0.19	0.50	2.0	0.0	1
1	65	177.	9.	141	13.001	810.01	0.32	38.9	1.	18.20	0.0	5.6	38.8	0.25	0.49	2.0	0.0	1
1	66	177.	9.	191	10.001	784.01	0.0	46.7	1.	15.00	0.0	4.8	21.1	0.10	0.52	2.0	0.0	1
1	67	177.	9.	191	13.001	848.01	0.0	41.9	1.	17.50	0.0	6.1	20.0	0.03	0.55	2.0	0.0	1
1	68	177.	9.	191	13.301	808.01	0.0	40.8	1.	17.50	0.0	6.0	20.0	0.03	0.56	2.0	0.0	1

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR


ETA=0.504 0.228\*TSTAR 0.0331TSTAR\*\*21

LEAST SQUARE FIT

ETA=0.590 -.500\*TSTAR

ETA=0.533 -.128\*TSTAR -.5001TSTAR\*\*21

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:BELGIUM  
 REFERENCE AREA: 2.30 M\*\*2; FLUID: H2O ; SLOPE: 50 DEGREE;HEVERLEE




□ □  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: BELGIUM  
 REFERENCE AREA: 2.30 M<sup>2</sup>; FLUID: H<sub>2</sub>O ; SLOPE: 35 DEGREE. MONS

B

SITE # 0 COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/DSE = 1/2) - 1 NUMBER OF DATA POINTS = 38

ID	NO	DATE	HOUR	I	ID/1	FLOW	TR	TI	IDELTAT	TP	T <sub>m</sub>	ETA	WIND	TSKY
1	1	177	5.181	13.001	751.01	0.18	34.2	19.70	0.0	6.3	40.4	0.27	0.51	0.0
1	2	177	5.181	14.001	752.01	0.19	34.2	19.00	0.0	6.3	41.8	0.29	0.52	0.0
1	3	177	5.241	12.061	756.01	0.0	34.2	23.10	0.0	5.4	52.3	0.41	0.45	0.0
1	4	177	5.241	13.181	774.01	0.0	34.2	22.60	0.0	5.9	50.4	0.36	0.48	0.0
1	5	177	5.251	12.181	753.01	0.0	34.2	24.20	0.0	5.4	54.8	0.41	0.45	0.0
1	6	177	5.251	12.541	768.01	0.0	34.2	25.90	0.0	5.7	54.8	0.38	0.47	0.0
1	7	177	5.251	13.301	831.01	0.0	34.2	27.30	0.0	6.4	55.0	0.33	0.48	0.0
1	8	177	5.261	11.001	708.01	0.0	34.2	21.80	0.0	3.5	61.1	0.56	0.31	0.0
1	9	177	5.261	11.361	748.01	0.0	34.2	22.70	0.0	4.7	59.8	0.50	0.39	0.0
1	10	177	5.261	12.061	781.01	0.0	34.2	22.60	0.0	5.1	57.9	0.45	0.41	0.0
1	11	177	5.261	12.441	795.01	0.0	34.2	22.60	0.0	5.0	56.6	0.43	0.40	0.0
1	12	177	5.271	11.001	737.01	0.0	34.2	17.30	0.0	2.9	66.8	0.67	0.25	0.0
1	13	177	5.271	13.181	862.01	0.0	34.2	19.20	0.0	4.4	65.6	0.54	0.32	0.0
1	14	177	5.281	11.001	72.51	0.0	34.2	20.90	0.0	2.7	72.1	0.71	0.23	0.0
1	15	177	5.281	11.351	77.41	0.0	34.2	21.50	0.0	3.2	73.8	0.68	0.26	0.0
1	16	177	5.281	12.101	816.01	0.0	34.2	21.80	0.0	3.6	75.5	0.65	0.27	0.0
1	17	177	5.281	13.201	846.01	0.0	34.2	22.60	0.0	3.6	78.1	0.65	0.26	0.0
1	18	177	5.291	11.021	685.01	0.0	34.2	22.20	0.0	2.3	73.5	0.75	0.21	0.0
1	19	177	5.291	11.361	737.01	0.0	34.2	21.70	0.0	2.6	74.9	0.72	0.22	0.0
1	20	177	5.291	12.101	764.01	0.0	34.2	23.10	0.0	2.9	76.9	0.70	0.24	0.0
1	21	177	6.131	12.101	755.01	0.0	34.2	31.20	0.0	7.2	40.0	0.11	0.57	0.0
1	22	177	6.131	12.381	802.01	0.0	34.2	31.80	0.0	7.3	42.4	0.13	0.57	0.0
1	23	177	6.131	13.181	842.01	0.0	34.2	32.10	0.0	7.6	44.4	0.15	0.56	0.0
1	24	177	7.41	13.161	782.01	0.26	34.2	29.30	0.0	6.9	42.4	0.17	0.55	0.0
1	25	177	7.51	11.361	724.01	0.14	34.2	26.20	0.0	6.3	38.6	0.17	0.54	0.0
1	26	177	7.51	12.101	758.01	0.20	34.2	26.90	0.0	6.5	40.6	0.18	0.53	0.0
1	27	177	7.51	12.441	782.01	0.24	34.2	27.80	0.0	6.8	42.6	0.19	0.54	0.0
1	28	177	7.61	11.021	624.01	0.17	34.2	25.60	0.0	4.7	43.4	0.29	0.47	0.0
1	29	177	7.61	11.521	683.01	0.27	34.2	26.90	0.0	5.4	45.4	0.27	0.49	0.0
1	30	177	7.61	13.121	821.01	0.17	34.2	28.20	0.0	6.8	48.8	0.25	0.51	0.0
1	31	177	7.121	11.161	638.01	0.0	34.2	23.40	0.0	4.6	47.0	0.37	0.45	0.0
1	32	177	7.121	11.501	687.01	0.0	34.2	25.50	0.0	5.2	48.2	0.33	0.47	0.0
1	33	177	7.121	12.241	731.01	0.0	34.2	27.40	0.0	5.7	49.4	0.30	0.48	0.0
1	34	177	7.121	12.581	748.01	0.0	34.2	28.60	0.0	5.9	50.6	0.29	0.49	0.0
1	35	177	9.21	11.501	747.01	0.01	34.2	20.60	0.0	6.7	39.1	0.24	0.54	0.0
1	36	177	9.21	12.141	812.01	0.02	34.2	21.10	0.0	7.0	42.6	0.26	0.54	0.0
1	37	177	9.41	11.061	663.01	0.0	34.2	20.40	0.0	5.7	33.9	0.20	0.54	0.0
1	38	177	9.41	11.381	738.01	0.03	34.2	21.40	0.0	6.3	37.3	0.21	0.53	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT  
 ETA-0.0 0.0 \*ISTAR  
 ETA-0.560 0.264\*ISTAR 0.327(ISTAR\*\*2)  
 LEAST SQUARE FIT  
 ETA-0.654 -.590\*ISTAR  
 ETA-0.611 -.291\*ISTAR -.353(ISTAR\*\*2)

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID:WATER ; SLOPE: 45 DEGREE. JUELICH

SITE : D COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHRAE/BSSE = 1/21 = 1 NUMBER OF DATA POINTS = 21

ID	NO	DATE	HR	I	ID/I	FLOW	TA	TI	DELTA T	TN	Tm	ETA	WIND	TSKY
1	1	177	9.271	12.001	878.01	0.28	17.2	18.50	22.5	14.1	29.6	0.13	1.5	0.0
1	2	177	9.271	0.0	894.01	0.0	17.5	18.80	23.1	14.2	30.2	0.13	1.5	0.0
1	3	177	9.271	13.101	852.01	0.0	17.4	19.70	23.6	13.8	30.5	0.13	1.5	0.0
1	4	177	9.241	13.001	891.01	0.0	13.2	17.00	35.2	15.9	43.1	0.29	1.5	0.0
1	5	177	9.241	0.0	876.01	0.0	14.8	17.40	35.2	14.3	42.3	0.28	1.5	0.0
1	6	177	9.241	0.0	836.01	0.0	15.2	17.50	48.9	10.9	54.4	0.44	1.5	0.0
1	7	177	9.241	0.0	819.01	0.0	15.5	17.50	48.9	10.9	54.4	0.45	1.5	0.0
1	8	177	9.241	0.0	807.01	0.0	15.5	17.50	48.9	10.9	54.4	0.46	1.5	0.0
1	9	177	9.241	15.201	740.01	0.0	15.9	17.50	63.2	7.7	67.1	0.67	1.5	0.0
1	10	177	9.271	14.001	900.01	0.0	17.4	19.90	64.7	7.7	68.6	0.61	1.5	0.0
1	11	177	9.271	15.001	658.01	0.0	17.2	20.20	80.5	4.0	82.5	0.95	1.5	0.0
1	12	177	10.121	12.451	857.01	0.0	16.3	17.50	80.1	7.5	83.8	0.77	1.5	0.0
1	13	177	10.121	0.0	857.01	0.0	16.2	17.50	80.1	7.3	83.8	0.77	1.5	0.0
1	14	177	10.121	0.0	777.01	0.0	16.6	17.70	89.5	4.2	91.6	0.95	1.5	0.0
1	15	177	10.121	0.0	756.01	0.0	16.6	17.70	89.5	3.9	91.5	0.98	1.5	0.0
1	16	177	10.121	15.151	728.01	0.0	16.8	17.70	89.4	3.7	91.3	1.01	1.5	0.0
1	17	178	10.121	9.301	661.01	0.0	41.4	13.50	35.5	3.7	37.4	0.36	1.5	0.0
1	18	178	10.121	10.101	755.01	0.0	41.4	15.30	35.0	4.4	37.2	0.29	1.5	0.0
1	19	178	10.121	11.501	838.01	0.0	41.7	18.50	59.3	3.9	61.2	0.51	1.5	0.0
1	20	178	10.121	12.101	854.01	0.0	41.7	18.90	59.3	4.2	61.4	0.50	1.5	0.0
1	21	178	10.121	14.301	769.01	0.0	43.4	21.00	86.0	1.9	88.9	0.88	1.5	0.0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID:WATER ; SLOPE: 45 DEGREE. JUELICH

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT


ETA=0.570 0.410\*STAR

ETA=0.0 0.0 \*STAR 0.0 !STAR\*\*2

LEAST SQUARE FIT

ETA=0.571 -.409\*STAR

ETA=0.576 -.431\*STAR 0.0191\*STAR\*\*2



COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID:WATER ; SLOPE, VARIABLE, HEIDELBERG


SITE = 0 COLLECTOR TYPE IEA- 2 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 1 NUMBER OF DATA POINTS = 14

ID	NO	DATE	HOUR	I	10/I	FLOW	TA	TI	DELTA T	TH	Tm	ETA	WIND	TSKY		
1	1	0	0	0	0	945.01	0.0	11.4	24.40	0.0	22.7	37.2	0.14	0.49	0.0	0.0
1	2	0	0	0	0	792.01	0.0	11.3	27.50	0.0	18.9	35.3	0.10	0.48	0.0	0.0
1	3	0	0	0	0	773.01	0.0	11.1	28.80	0.0	18.7	35.2	0.08	0.48	0.0	0.0
1	4	0	0	0	0	665.01	0.0	11.1	28.60	0.0	16.0	34.3	0.09	0.50	0.0	0.0
1	5	0	0	0	0	690.01	0.0	10.9	29.00	0.0	17.7	34.8	0.08	0.50	0.0	0.0
1	6	0	0	0	0	816.01	0.0	20.7	23.70	0.0	9.4	54.6	0.38	0.43	0.0	0.0
1	7	0	0	0	0	841.01	0.0	20.5	24.70	0.0	8.3	64.1	0.47	0.38	0.0	0.0
1	8	0	0	0	0	893.01	0.0	20.1	27.80	0.0	8.3	74.1	0.52	0.33	0.0	0.0
1	9	0	0	0	0	883.01	0.0	19.8	28.30	0.0	7.2	83.2	0.62	0.29	0.0	0.0
1	10	0	0	0	0	930.01	0.0	23.1	31.00	0.0	5.5	93.7	0.67	0.24	0.0	0.0
1	11	0	0	0	0	895.01	0.0	22.3	28.00	0.0	6.9	72.9	0.50	0.30	0.0	0.0
1	12	0	0	0	0	925.01	0.0	22.1	28.90	0.0	9.5	57.3	0.31	0.40	0.0	0.0
1	13	0	0	0	0	915.01	0.0	21.9	27.60	0.0	7.1	73.1	0.50	0.30	0.0	0.0
1	14	0	0	0	0	880.01	0.0	23.5	28.40	0.0	5.0	92.9	0.73	0.23	0.0	0.0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID:WATER ; SLOPE, VARIABLE, HEIDELBERG

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR  
 ETA=0.530 0.303\*TSTAR 0.147\*(TSTAR\*\*2)  
 LEAST SQUARE FIT  
 ETA=0.536 -.410\*TSTAR  
 ETA=0.522 -.289\*TSTAR -.164\*(TSTAR\*\*2)



X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:GERMANY

REFERENCE AREA: 2.303 M\*\*2; FLUID:WATER ; SLOPE: 40.5. STUTTGART

D

SITE : D COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 1 NUMBER OF DATA POINTS = 32

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	IDELTR	TH	TM	ETA	WIND	TSKY		
1	1	178	5	27	10.33	788.6	0.27	36.4	19.81	0.0	4.0	58.1	0.49	0.34	0.0	0.0
1	2	178	5	27	10.56	857.6	0.26	36.1	19.64	0.0	4.8	58.2	0.45	0.37	0.0	0.0
1	3	178	5	28	10.19	747.3	0.29	35.8	20.94	0.0	4.2	58.1	0.50	0.37	0.0	0.0
1	4	178	5	28	10.54	820.4	0.29	36.1	21.16	0.0	4.8	58.4	0.45	0.39	0.0	0.0
1	5	178	5	29	9.47	652.0	0.31	35.7	22.00	0.0	3.2	57.6	0.55	0.32	0.0	0.0
1	6	178	5	29	10.59	810.5	0.30	35.6	22.78	0.0	5.0	58.4	0.44	0.40	0.0	0.0
1	7	178	5	30	9.42	648.8	0.24	34.8	24.26	0.0	2.7	67.1	0.66	0.27	0.0	0.0
1	8	178	5	30	10.10	718.7	0.29	34.8	23.61	0.0	3.3	67.6	0.61	0.30	0.0	0.0
1	9	178	5	30	11.57	913.9	0.20	34.9	24.28	0.0	5.0	67.2	0.47	0.36	0.0	0.0
1	10	178	5	30	13.10	895.0	0.21	34.8	24.51	0.0	5.2	68.1	0.49	0.37	0.0	0.0
1	11	178	5	31	10.13	733.7	0.28	35.3	21.45	0.0	2.7	65.7	0.60	0.24	0.0	0.0
1	12	178	5	31	10.57	823.2	0.21	35.2	22.34	0.0	4.3	67.4	0.55	0.33	0.0	0.0
1	13	178	5	31	12.14	889.2	0.21	35.3	23.33	0.0	5.1	66.8	0.49	0.37	0.0	0.0
1	14	178	5	31	13.44	819.9	0.23	35.5	24.11	0.0	4.5	67.6	0.53	0.35	0.0	0.0
1	15	178	6	1	10.34	714.6	0.30	33.2	23.48	0.0	3.3	67.3	0.60	0.31	0.0	0.0
1	16	178	6	1	11.21	752.5	0.33	33.0	24.84	0.0	2.1	85.4	0.87	0.17	0.0	0.0
1	17	178	6	1	12.00	866.2	0.24	33.0	25.70	0.0	2.4	85.9	0.81	0.19	0.0	0.0
1	18	178	6	1	13.01	811.2	0.25	33.7	26.51	0.0	3.6	86.1	0.70	0.25	0.0	0.0
1	19	178	6	2	10.03	668.4	0.31	36.3	26.42	0.0	3.3	85.8	0.73	0.25	0.0	0.0
1	20	178	6	2	11.09	749.4	0.29	36.9	27.76	0.0	4.8	88.8	0.19	0.48	0.0	0.0
1	21	178	6	2	12.05	865.2	0.27	37.0	27.09	0.0	6.8	84.9	0.09	0.57	0.0	0.0
1	22	178	6	2	12.51	842.4	0.27	36.9	28.74	0.0	7.4	85.2	0.09	0.57	0.0	0.0
1	23	178	6	2	14.02	800.1	0.23	36.8	28.38	0.0	7.3	85.0	0.08	0.59	0.0	0.0
1	24	178	6	3	10.20	738.5	0.23	35.2	28.48	0.0	7.0	85.0	0.08	0.59	0.0	0.0
1	25	178	6	3	11.30	856.1	0.20	35.3	27.96	0.0	6.6	81.6	0.04	0.58	0.0	0.0
1	26	178	6	3	12.10	886.4	0.21	35.3	28.24	0.0	7.7	81.6	0.04	0.58	0.0	0.0
1	27	178	6	4	10.05	693.2	0.27	35.5	26.73	0.0	7.9	80.2	0.02	0.58	0.0	0.0
1	28	178	6	4	10.52	785.3	0.25	35.4	26.74	0.0	5.8	82.4	0.08	0.54	0.0	0.0
1	29	178	6	4	11.41	833.9	0.26	35.2	28.35	0.0	7.6	82.8	0.08	0.56	0.0	0.0
1	30	178	6	4	12.03	840.2	0.26	35.2	28.39	0.0	7.6	83.2	0.06	0.58	0.0	0.0
1	31	178	6	4	12.28	861.5	0.26	35.0	28.62	0.0	7.8	83.3	0.05	0.58	0.0	0.0
1	32	178	6	4	12.28	861.5	0.26	35.0	28.62	0.0	7.8	83.3	0.05	0.58	0.0	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT


ETA=0.603 0.506\*STAR

ETA=0.0 0.0 \*STAR 0.0 (TSTAR\*\*2)

LEAST SQUARE FIT

ETA=0.606 -.509\*STAR

ETA=0.607 -.516\*STAR 0.0091TSTAR\*\*2




COLLECTOR TYPE : IEA-2 , TESTING PROCEDURE : NBS/ASHRAE , SITE : SPAIN  
 REFERENCE AREA : 2.31 M\*\*2, FLUID : WATER , SLOPE : 45 DEGREE. HMDRID

E

SITE : E COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHRAE/DSE = 1/21 = 1 NUMBER OF DATA POINTS = 33

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	TH	T*	ETA	WIND	TSKY
1	1	78	6.21	0.0	1.921	0.0	21.80	0.0	5.4	48.9	0.29	0.49	1.5	0.0
1	2	78	6.22	0.0	1.630	0.0	26.50	0.0	2.4	58.9	0.53	0.34	1.5	0.0
1	3	78	6.28	0.0	1.1003	0.0	24.10	0.0	4.3	63.7	0.39	0.39	1.5	0.0
1	4	78	6.28	0.0	1.1013	0.0	48.0	0.0	4.5	64.0	0.39	0.39	2.5	0.0
1	5	78	7.31	0.0	1.905	0.0	24.90	0.0	4.9	66.9	0.45	0.39	1.5	0.0
1	6	78	7.31	0.0	1.943	0.0	30.30	0.0	4.7	72.2	0.44	0.42	1.5	0.0
1	7	78	7.41	0.0	1.961	0.0	26.10	0.0	5.8	42.9	0.18	0.51	1.5	0.0
1	8	78	7.41	0.0	1.988	0.0	27.30	0.0	5.7	46.6	0.19	0.49	1.5	0.0
1	9	78	7.51	0.0	1.847	0.0	18.00	0.0	4.7	27.4	0.11	0.49	1.5	0.0
1	10	78	7.71	0.0	1.845	0.0	20.80	0.0	3.5	58.5	0.47	0.37	1.5	0.0
1	11	78	7.71	0.0	1.11015	0.0	24.80	0.0	4.6	59.1	0.29	0.46	1.5	0.0
1	12	78	7.10	0.0	1.767	0.0	31.60	0.0	4.0	52.5	0.24	0.50	1.5	0.0
1	13	78	7.10	0.0	1.907	0.0	31.20	0.0	5.3	28.3	0.03	0.57	1.5	0.0
1	14	78	7.11	0.0	1.914	0.0	47.4	0.0	5.7	29.1	0.03	0.54	1.5	0.0
1	15	78	7.11	0.0	1.961	0.0	26.40	0.0	5.9	30.1	0.02	0.53	1.5	0.0
1	16	78	7.11	0.0	1.995	0.0	28.00	0.0	6.0	32.9	0.06	0.52	1.5	0.0
1	17	78	7.12	0.0	1.970	0.0	27.20	0.0	11.0	34.3	0.06	0.53	1.5	0.0
1	18	78	7.12	0.0	1.981	0.0	25.6	0.0	11.1	76.2	0.55	0.36	1.5	0.0
1	19	78	7.14	0.0	1.832	0.0	30.70	0.0	6.5	74.8	0.47	0.41	1.5	0.0
1	20	78	7.14	0.0	1.895	0.0	32.30	0.0	8.0	73.9	0.42	0.40	1.5	0.0
1	21	78	7.14	0.0	1.947	0.0	34.00	0.0	8.3	71.8	0.42	0.40	1.5	0.0
1	22	78	7.14	0.0	1.842	0.0	36.50	0.0	7.3	48.0	0.14	0.52	1.5	0.0
1	23	78	7.17	0.0	1.923	0.0	34.90	0.0	10.7	52.0	0.15	0.51	1.5	0.0
1	24	78	7.17	0.0	1.967	0.0	37.00	0.0	10.7	63.4	0.40	0.39	1.5	0.0
1	25	78	7.18	0.0	1.841	0.0	29.80	0.0	3.7	88.7	0.62	0.29	1.5	0.0
1	26	78	7.19	0.0	1.11018	0.0	25.6	0.0	6.3	90.3	0.67	0.30	1.5	0.0
1	27	78	7.20	0.0	1.943	0.0	27.00	0.0	6.2	91.8	0.61	0.34	1.5	0.0
1	28	78	7.20	0.0	1.11010	0.0	25.0	0.0	7.4	90.9	0.74	0.27	1.5	0.0
1	29	78	7.20	0.0	1.802	0.0	31.80	0.0	4.8	91.7	0.78	0.27	1.5	0.0
1	30	78	7.21	0.0	1.745	0.0	33.70	0.0	6.2	93.4	0.63	0.36	1.5	0.0
1	31	78	7.21	0.0	1.975	0.0	17.2	0.0	11.2	92.2	0.64	0.35	1.5	0.0
1	32	78	7.21	0.0	1.970	0.0	30.10	0.0	10.5	65.4	0.63	0.35	1.5	0.0
1	33	78	7.24	0.0	1.866	0.0	30.40	0.0	6.5				1.5	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 =TSTAR  
 ETA=0.551 0.359=TSTAR 0.0071TSTAR\*\*21  
 LEAST SQUARE FIT  
 ETA=0.558 -.368\*TSTAR  
 ETA=0.555 -.350\*TSTAR -.0241TSTAR\*\*21

COLLECTOR TYPE: EA-2, TESTING PROCEDURE: NBS/ASHRAE, SITE: GREAT B.  
 REFERENCE AREA: 1 MM<sup>2</sup>, FLUID: WATER, SLOPE: 45.0, CARDOFF

GB

SITE: GB COLLECTOR TYPE: EA-2 TEST-PROCEDURE (ASHRAE/BSE - 1/2) - 1 NUMBER OF DATA POINTS - 5

ID	NO	DATE	HOUR	IO/I	FLOW	TA	TI	DELTA T	TH	TM	ETA	WIND	TSKY			
1	1	177	7	41	19.30	841.01	0.29	25.5	26.20	0.0	0.0	44.4	0.22	0.48	1.0	0.0
1	2	177	7	61	15.13	740.01	0.30	25.5	26.80	0.0	0.0	54.5	0.37	0.41	1.5	0.0
1	3	177	8	11	15.05	829.01	0.0	25.5	23.50	0.0	0.0	71.3	0.58	0.34	2.0	0.0
1	4	177	8	101	15.25	707.01	0.28	25.5	25.00	0.0	0.0	88.4	0.90	0.22	1.5	0.0
1	5	177	8	101	16.40	492.01	0.32	25.5	24.70	0.0	0.0	80.1	1.13	0.14	1.5	0.0

COLLECTOR TYPE: EA-2; TESTING PROCEDURE: NBS/ASHRAE; SITE: GREAT B.  
 REFERENCE AREA: 2.31 MM<sup>2</sup>; FLUID: WATER; SLOPE: 45.0, CARDOFF

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.550 0.370\*TSR


ETA=0.0 0.0 \*TSR 0.0 (TSR\*\*2)

LEAST SQUARE FIT

ETA=0.553 -.373\*TSR

ETA=0.562 -.408\*TSR 0.026(TSR\*\*2)

□ □  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0





COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: JAPAN  
 REPRESENTATIVE VALUES ONLY; FLUID:H2O ;SLOPE:37.93 DEGREE. NAGDOYA


SITE = J COLLECTOR TYPE IEA- 2 TEST-PROCEDURE IASHRAE/05E - 1/21 - 1 NUMBER OF DATA POINTS = 5

ID	NO	DATE	HOUR	I	ID/1	FLOW	TA	TJ	DELTA T	TH	TM	ETA	HIND	TSKY	
1	1	178	4.141	13.371	800.71	0.28	143.5	18.66	0.0	5.3	27.4	0.11	0.53	1.7	0.0
1	2	178	4.151	10.521	830.01	0.32	142.6	18.35	0.0	5.0	42.3	0.28	0.47	0.9	0.0
1	3	178	4.191	11.371	964.51	0.14	142.8	18.00	0.0	5.1	59.4	0.43	0.41	2.1	0.0
1	4	178	4.221	10.521	952.41	0.14	145.1	16.76	0.0	3.6	76.1	0.62	0.31	2.2	0.0
1	5	178	5.21	13.221	892.41	0.22	145.8	20.94	0.0	2.2	92.9	0.81	0.21	5.7	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT  
 COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE: JAPAN  
 REPRESENTATIVE VALUES ONLY; FLUID:H2O ;SLOPE:37.93 DEGREE. NAGDOYA

ETA=0.0 0.0 \*TSTAR  
 ETA=0.564 0.301\*TSTAR 0.1781(TSTAR\*\*2)  
 LEAST SQUARE FIT  
 ETA=0.592 -.464\*TSTAR  
 ETA=0.561 -.275\*TSTAR -.2061(TSTAR\*\*2)

STATISTICS  
 X-MIN = 0.10000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0



COLLECTOR TYPE: IER-2 , TESTING PROCEDURE : NBS/ASHRAE, SITE:NETHERL.  
 REFERENCE AREA: 2.315 M\*\*2, FLUID:WATER , SLOPE: 45 DEGREE. DELFT

NL

SITE \* NL COLLECTOR TYPE IER- 2 TEST-PROCEDURE (ASHRAE/BSE - 1/2) - 1 NUMBER OF DATA POINTS = 8

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	TM	Ym	ETA	WIND	TSKY
1	1	177	5.251	13.001	989.01	0.13	19.70	0.0	10.6	20.7	0.01	0.57	8.5	0.0
1	2	177	5.251	14.001	955.01	0.13	19.80	0.0	10.2	22.6	0.03	0.56	8.5	0.0
1	3	177	5.251	14.301	944.01	0.13	20.70	0.0	9.8	24.9	0.05	0.54	8.5	0.0
1	4	177	5.251	15.151	935.01	0.13	20.90	0.0	9.4	29.8	0.10	0.53	8.5	0.0
1	5	177	5.251	15.451	933.01	0.13	20.90	0.0	8.8	37.5	0.18	0.49	8.5	0.0
1	6	177	5.251	16.301	905.01	0.14	20.90	0.0	7.8	46.2	0.28	0.45	8.5	0.0
1	7	177	5.251	17.001	844.01	0.15	21.30	0.0	6.7	52.9	0.37	0.41	8.5	0.0
1	8	177	5.251	17.301	771.01	0.0	20.80	0.0	4.9	66.7	0.60	0.33	5.5	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.0 0.0 \*TSTAR


ETA=0.0 0.0 \*TSTAR 0.0 (TSTAR\*\*2)

LEAST SQUARE FIT

ETA=0.567 -.405\*TSTAR

ETA=0.569 -.438\*TSTAR 0.059(TSTAR\*\*2)

COLLECTOR TYPE: IER-2 ; TESTING PROCEDURE : NBS/ASHRAE; SITE:NETHERL.  
 REFERENCE AREA: 2.315 M\*\*2; FLUID:WATER ; SLOPE: 45 DEGREE. DELFT



X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE, SITE:SWEDEN  
 REFERENCE AREA: 2.320 M\*\*2, FLUID:WATER ; SLOPE: 45 DEGREE. BORAS

S

SITE : S ; COLLECTOR TYPE IEA-2 ; TEST-PROCEDURE IASHRAE/BSE = 1/2) - 1 ; NUMBER OF DATA POINTS = 17

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	TH	T*	ETA	WIND	TSKY
1	1	177	9.191	13.00	931.01	0.06	43.0	20.00	0.0	5.7	33.2	0.14	0.48	1.6
1	1	177	9.191	13.15	921.01	0.06	43.0	20.20	0.0	5.9	33.5	0.14	0.50	1.4
1	3	177	9.191	13.30	904.01	0.06	43.0	20.00	0.0	5.9	33.3	0.15	0.52	1.7
1	4	177	9.191	13.45	886.01	0.06	43.0	20.50	0.0	5.9	33.2	0.14	0.52	1.1
1	5	177	9.191	14.20	866.01	0.06	43.0	20.50	0.0	5.1	43.3	0.25	0.46	1.4
1	6	177	9.191	14.35	845.01	0.06	44.0	20.50	0.0	5.0	43.3	0.27	0.47	1.3
1	7	177	9.191	14.50	815.01	0.06	44.0	20.50	0.0	4.8	43.2	0.28	0.47	1.7
1	8	177	9.191	15.05	789.01	0.07	44.0	20.50	0.0	4.6	43.0	0.28	0.46	1.2
1	9	177	9.201	10.00	842.01	0.08	44.0	13.50	0.0	3.7	53.1	0.47	0.35	2.0
1	10	177	9.201	10.35	845.01	0.09	44.0	15.30	0.0	3.9	53.3	0.45	0.37	1.6
1	11	177	9.201	10.50	848.01	0.08	44.0	15.90	0.0	3.9	53.2	0.44	0.37	1.9
1	12	177	9.201	11.05	840.01	0.09	44.0	16.30	0.0	3.9	53.2	0.44	0.37	1.8
1	13	177	9.201	11.50	866.01	0.09	43.0	16.50	0.0	3.6	62.6	0.53	0.32	2.0
1	14	177	9.201	12.05	874.01	0.09	43.0	17.10	0.0	3.7	62.7	0.52	0.33	1.9
1	15	177	9.201	12.20	885.01	0.09	43.0	17.20	0.0	3.8	62.8	0.51	0.33	1.9
1	16	177	9.201	12.35	886.01	0.09	43.0	17.30	0.0	3.8	62.8	0.51	0.33	1.8
1	17	177	9.201	12.50	893.01	0.08	44.0	17.60	0.0	3.8	62.8	0.51	0.34	2.1

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE, SITE:SWEDEN  
 REFERENCE AREA: 2.320 M\*\*2, FLUID:WATER ; SLOPE: 45 DEGREE. BORAS

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT


ETA=0.574 0.471\*STAR

ETA=0.551 0.281\*STAR 0.0221\*STAR\*\*2

LEAST SQUARE FIT

ETA=0.582 -.480\*STAR

ETA=0.531 -.102\*STAR -.5631\*STAR\*\*2




0.0  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

# USA

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : NBS/ASHRAE ; SITE:USA  
 REFERENCE AREA: 2.29 M\*\*2, FLUID:DENIN.H2O , SLOPE: 25/27 DEGREE

SITE: USA COLLECTOR TYPE IEA- 2 TEST-PROCEDURE IASHRAE/BSE - 1/21 - I NUMBER OF DATA POINTS - 29

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA T	TM	Y*	ETA	WIND	ISKY		
1	1	178	4	28	11	4211045	0.11	45.4	18.40	0.0	5.9	42.6	0.23	0.47	1.3	0.0
1	2	178	4	28	11	4711045	0.11	45.4	18.50	0.0	5.8	42.7	0.23	0.46	3.9	0.0
1	3	178	4	26	11	5211051	0.11	45.4	18.30	0.0	6.1	42.7	0.23	0.48	2.6	0.0
1	4	178	4	28	11	5711053	0.11	45.4	18.50	0.0	6.0	42.6	0.23	0.47	5.3	0.0
1	5	178	4	28	12	0311051	0.11	45.4	18.60	0.0	5.9	42.7	0.23	0.47	2.8	0.0
1	6	178	4	28	12	0811038	0.11	45.4	18.60	0.0	6.0	42.7	0.23	0.48	3.7	0.0
1	7	178	4	28	12	1311043	0.11	45.4	18.20	0.0	6.1	42.7	0.23	0.48	2.0	0.0
2	1	178	5	11	12	5511020	0.12	44.8	10.90	0.0	4.5	61.6	0.49	0.36	4.3	0.0
2	2	178	5	11	13	0011020	0.12	44.8	11.10	0.0	4.4	61.7	0.49	0.35	3.0	0.0
2	3	178	5	11	13	0511003	0.12	44.8	12.00	0.0	4.4	61.7	0.49	0.35	1.1	0.0
2	4	178	5	11	13	0911002	0.12	44.8	11.80	0.0	4.3	61.8	0.50	0.35	2.8	0.0
2	5	178	5	11	13	1511050	0.12	44.5	11.80	0.0	3.8	74.8	0.60	0.29	0.0	0.0
2	6	178	5	11	13	2011053	0.12	44.5	11.60	0.0	3.8	74.7	0.60	0.30	3.2	0.0
2	7	178	5	21	12	0411032	0.11	44.3	13.20	0.0	3.3	84.0	0.68	0.26	3.2	0.0
2	8	178	5	21	12	0911032	0.11	44.3	13.90	0.0	3.3	84.1	0.68	0.26	5.0	0.0
2	9	178	5	21	12	1411031	0.11	44.3	13.80	0.0	3.3	84.1	0.68	0.26	3.8	0.0
2	10	178	5	21	12	1911017	0.11	44.3	14.00	0.0	3.3	84.2	0.68	0.26	0.1	0.0
2	11	178	5	21	12	2311020	0.11	44.3	13.80	0.0	3.3	84.3	0.69	0.26	3.0	0.0
2	12	178	5	31	12	1611025	0.13	45.3	15.80	0.0	6.6	27.5	0.11	0.53	1.1	0.0
2	13	178	5	31	12	2111016	0.13	45.3	15.80	0.0	6.5	27.6	0.12	0.53	2.5	0.0
2	14	178	5	31	12	2511025	0.13	45.3	16.00	0.0	6.5	27.7	0.11	0.53	1.8	0.0
2	15	178	5	31	11	5511041	0.13	45.3	15.10	0.0	6.7	26.9	0.11	0.53	2.8	0.0
2	16	178	5	31	12	0511033	0.13	45.3	15.40	0.0	6.7	27.0	0.11	0.53	1.0	0.0
2	17	178	5	31	12	0511033	0.13	45.3	15.80	0.0	6.7	27.1	0.11	0.53	0.5	0.0
2	18	178	5	31	12	1011023	0.13	45.3	16.50	0.0	6.6	27.3	0.11	0.53	2.5	0.0
2	19	178	5	11	10	5511017	0.13	44.8	11.80	0.0	4.2	61.4	0.49	0.34	3.0	0.0
2	20	178	5	11	11	0011028	0.13	44.8	11.60	0.0	4.3	61.5	0.49	0.34	1.6	0.0
2	21	178	5	11	11	0511038	0.13	44.8	9.60	0.0	4.3	61.6	0.50	0.34	3.3	0.0
2	22	178	5	11	11	0311030	0.13	44.8	10.70	0.0	4.3	61.7	0.49	0.34	2.7	0.0



THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.583 0.471\*1STAR

EIR=0.0 0.0 \*1STAR 0.0 1TSTAR\*\*21

LEAST SQUARE FIT


ETA=0.581 -.470\*1STAR

EIR=0.581 -.474\*1STAR 0.0051TSTAR\*\*21



APPENDIX E

Data: IEA-1 Collector  
BSE Procedure  
EIR Procedure



COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE: EIR, SITE: SWITZERLAND  
 REFERENCE AREA: 1.79 M\*2; FLUID: WATER ; SLOPE: 40 DEGREE

CH

SITE \* CH COLLECTOR TYPE IEA-1 TEST-PROCEDURE IASIKRAT/OSE = 1/21 = 0 NUMBER OF DATA POINTS \* 21

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA TI	TH	T*	ETA	WIND	SKY
1	1	178	7:30	11.301	0.62	51	0.22	14.8	0.0	19.3	37.2	0.06	1.9	0.0
1	2	178	7:30	11.361	0.67	81	0.22	14.8	0.0	19.4	37.4	0.05	1.1	0.0
1	3	178	7:30	11.421	0.76	81	0.22	14.8	0.0	19.7	37.6	0.06	2.1	0.0
1	4	178	7:30	11.481	0.71	41	0.22	14.8	0.0	19.7	37.9	0.06	2.2	0.0
1	5	178	7:30	11.541	0.76	71	0.22	14.8	0.0	19.7	38.1	0.07	2.0	0.0
1	6	178	7:30	12.001	0.94	01	0.21	14.8	0.0	20.3	38.4	0.05	2.0	0.0
1	7	178	7:30	12.061	0.91	81	0.20	14.8	0.0	20.4	38.0	0.07	2.6	0.0
1	8	178	7:30	12.121	0.92	01	0.20	14.8	0.0	20.5	39.0	0.07	2.6	0.0
1	9	178	7:30	12.181	0.91	21	0.20	14.9	0.0	20.7	39.2	0.07	2.4	0.0
1	10	178	7:30	12.241	0.91	41	0.20	14.9	0.0	20.7	39.4	0.07	2.9	0.0
1	11	178	7:30	12.301	0.92	51	0.20	14.8	0.0	20.7	39.6	0.08	2.4	0.0
1	12	178	7:30	12.361	0.91	71	0.20	14.9	0.0	20.9	39.6	0.07	2.7	0.0
1	13	178	7:30	12.421	0.91	91	0.20	14.9	0.0	20.7	39.7	0.07	2.8	0.0
1	14	178	7:30	12.481	0.91	11	0.20	14.9	0.0	20.7	39.7	0.07	2.4	0.0
1	15	178	7:30	12.541	0.92	01	0.20	14.9	0.0	20.7	39.9	0.08	3.3	0.0
1	16	178	7:30	13.001	0.92	01	0.19	14.9	0.0	20.7	39.9	0.08	2.8	0.0
1	17	178	7:30	13.061	0.92	51	0.19	14.9	0.0	20.9	40.0	0.07	2.2	0.0
1	18	178	7:30	13.121	0.87	41	0.19	14.9	0.0	20.6	39.8	0.07	2.2	0.0
1	19	178	7:30	13.181	0.89	71	0.19	14.9	0.0	20.2	39.7	0.07	2.9	0.0
1	20	178	7:30	13.241	0.91	51	0.19	14.9	0.0	20.4	39.7	0.07	2.2	0.0
1	21	178	7:30	13.301	0.64	31	0.19	14.9	0.0	20.2	39.6	0.06	2.3	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT FOR DETAILS SEE APPENDIX A

ETA=0.0 0.0 \*TSTAR  
 ETA=0.654 0.0 \*TSTAR 0.0 ITSTAR=21


THE AVERAGED ETA

ETA0 = 0.6535

LEAST SQUARE FIT

ETA=0.843 -0.161\*TSTAR  
 ETA=0.636 5.715\*TSTAR \*\*\*\*\*ITSTAR=21

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE: EIR, SITE: SWITZERLAND  
 REFERENCE AREA: 1.79 M\*2; FLUID: WATER ; SLOPE: 40.DIFFUSE-LIGHT





CH

COLLECTOR TYPE: ITR-1 TESTING PROCEDURE: EIR. SITE: SWITZERLAND  
 REFERENCE AREA: 1.79 m<sup>2</sup>; FLUID: WATER; SLOPE: 40.0; DIFFUSE-LIGHT

SITE: CH COLLECTOR TYPE: ITR-1 TEST-PROCEDURE: IASHRAE/DISE = 1/21 = I NUMBER OF DATA POINTS: 38

ID	NO	DATE	HOUR	I	ID/I	FLOW	IA	YI	DELTA	IN	Y*	ETR	HIND	ISKY	
1	1	178	8.14	5.481	13.61	0.88	14.4	12.50	0.0	-0.3	19.2	5.80	0.6	0.0	
1	2	178	8.14	5.541	12.41	0.88	14.5	12.50	0.0	-0.3	19.2	5.43	0.5	0.0	
1	3	178	8.14	5.541	12.41	0.88	14.5	12.50	0.0	-0.3	19.2	5.43	0.5	0.0	
1	4	178	8.14	5.061	11.11	0.87	14.5	12.60	0.0	-0.3	19.2	5.98	0.5	0.0	
1	5	178	8.14	6.121	12.01	0.88	14.5	12.60	0.0	-0.3	19.3	5.54	0.5	0.0	
1	6	178	8.14	6.181	13.61	0.93	14.5	12.50	0.0	-0.3	19.3	4.97	1.2	0.0	
1	7	178	8.14	6.241	17.71	0.89	14.4	12.50	0.0	-0.2	19.2	3.78	0.7	0.0	
1	8	178	8.14	6.301	18.41	0.90	14.4	12.60	0.0	-0.2	19.2	3.59	0.7	0.0	
1	9	178	8.14	6.361	21.51	0.91	14.5	12.60	0.0	-0.2	19.3	3.10	0.8	0.0	
1	10	178	8.14	6.421	21.61	0.92	14.5	12.60	0.0	-0.1	19.3	3.12	0.9	0.0	
1	11	178	8.14	6.481	29.61	0.92	14.5	12.60	0.0	-0.1	19.4	2.88	0.9	0.0	
1	12	178	8.14	6.541	32.11	0.91	14.4	12.60	0.0	0.0	19.4	2.12	1.0	0.0	
1	13	178	8.14	7.061	32.51	0.93	14.4	12.70	0.0	0.1	19.4	2.07	1.0	0.0	
1	14	178	8.14	7.061	31.51	0.92	14.5	12.70	0.0	0.1	19.5	2.14	1.0	0.0	
1	15	178	8.14	7.121	34.51	0.92	14.4	12.80	0.0	0.1	19.5	1.93	0.6	0.0	
1	16	178	8.14	7.181	34.71	0.91	14.4	12.90	0.0	0.2	19.6	1.93	0.5	0.0	
1	17	178	8.14	7.241	35.61	0.92	14.4	13.00	0.0	0.3	19.6	1.86	0.27	0.4	0.0
1	18	178	8.14	7.301	41.61	0.93	14.4	13.10	0.0	0.3	19.7	1.58	0.25	0.4	0.0
1	19	178	8.14	7.361	54.51	0.96	14.4	13.10	0.0	0.4	19.7	1.21	0.29	0.5	0.0
1	20	178	8.14	7.421	69.41	0.94	14.4	13.10	0.0	0.8	19.9	0.98	0.39	0.5	0.0
1	21	178	8.14	7.541	76.01	0.92	14.4	13.20	0.0	0.9	20.0	0.89	0.45	1.0	0.0
1	22	178	8.14	7.541	83.11	0.94	14.4	13.30	0.0	1.1	20.1	0.81	0.48	0.6	0.0
1	23	178	8.14	8.001	110.91	0.94	13.8	13.20	0.0	1.5	20.2	0.62	0.46	1.1	0.0
1	24	178	8.14	8.061	109.61	0.93	14.0	13.30	0.0	1.7	20.3	0.64	0.55	0.9	0.0
1	25	178	8.14	8.121	112.41	0.94	14.0	13.30	0.0	1.8	20.3	0.62	0.55	1.3	0.0
1	26	178	8.14	8.181	122.91	0.93	14.1	13.20	0.0	2.0	20.4	0.59	0.56	1.2	0.0
1	27	178	8.14	8.241	123.71	0.93	14.2	13.40	0.0	2.1	20.4	0.57	0.58	1.2	0.0
1	28	178	8.14	8.301	128.71	0.93	14.1	13.70	0.0	2.2	20.6	0.54	0.58	0.8	0.0
1	29	178	8.14	8.361	129.91	0.90	14.1	13.90	0.0	2.3	20.8	0.53	0.60	0.9	0.0
1	30	178	8.14	8.421	144.01	0.94	14.1	14.10	0.0	2.4	20.9	0.47	0.58	1.0	0.0
1	31	178	8.14	8.481	154.91	0.94	14.1	14.20	0.0	2.6	21.1	0.45	0.59	1.3	0.0
1	32	178	8.14	8.541	165.41	0.93	14.1	14.40	0.0	2.9	21.3	0.41	0.61	0.8	0.0
1	33	178	8.14	9.001	168.71	0.93	14.1	14.90	0.0	3.1	21.4	0.39	0.64	0.6	0.0
1	34	178	8.14	9.061	165.61	0.92	14.0	14.80	0.0	3.1	21.5	0.40	0.65	0.8	0.0
1	35	178	8.14	9.121	163.61	0.92	14.0	15.20	0.0	3.3	21.6	0.35	0.63	0.5	0.0
1	36	178	8.14	9.181	194.51	0.92	14.0	15.40	0.0	3.6	21.7	0.32	0.64	0.7	0.0
1	37	178	8.14	9.241	213.11	0.92	14.0	15.60	0.0	3.9	22.0	0.30	0.64	0.7	0.0
1	38	178	8.14	9.301	205.91	0.92	14.0	15.70	0.0	4.2	22.1	0.31	0.70	0.6	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT FOR DETAILS SEE APPENDIX A

ETR=0.0 0.0 \*1STAR

ETR=0.730 - .304\*1STAR 0.0 IYSTAR\*\*2

LEAST SQUARE FIT

ETR=0.714 - .387\*1STAR

COLLECTOR TYPE: IEA-1 , TESTING PROCEDURE : ASE/INDOOR, SITE:GERMANY  
 REFERENCE AREA: 1.79 M<sup>2</sup>, FLUID: WATER , SLOPE: 45 DEGREE, JUELICH

**D**

SITE = 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 6

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.810- -0.4600\*STAR--0.30000E-021\*STAR\*\*21M1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TM	TM-TR	OL	UA	WIND	TSKY	C-P	
1	4	1 178	5.251	11.001	36.901	18.70	50.6	1.60	49.8	31.1	240.2	7.72	5.0	0.0	4186.7
1	4	2 178	5.251	13.051	37.201	18.90	68.7	2.80	67.3	48.4	436.3	9.01	5.0	0.0	4186.7
1	4	3 178	5.251	15.001	36.901	18.90	90.8	4.40	88.6	69.6	683.2	9.82	5.0	0.0	4186.7
1	4	4 178	5.251	15.251	36.901	18.90	90.8	4.40	88.6	69.6	683.2	9.82	5.0	0.0	4186.7
1	4	5 178	5.251	16.451	37.101	18.90	70.4	2.90	67.4	48.5	450.7	9.29	5.0	0.0	4186.7
1	4	6 178	5.251	9.151	37.001	18.80	50.0	1.50	49.2	30.4	232.1	7.63	5.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.810- 0.34589\*STAR- 0.30315E-031\*STAR\*\*21M1


THE CORRECTED ETRO

ETRO= 0.8060

LEAST SQUARE FIT

ETA=0.806- 0.34589\*STAR- 0.30315E-031\*STAR\*\*21M1

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR; SITE:GERMANY  
 REFERENCE AREA: 1.79 M<sup>2</sup>; FLUID: WATER ; SLOPE: 45 DEGREE; JUELICH



COEF  
 --- 1=600 WATT  
 X-MIN = 0.00000E0  
 X-MAX = 1.00000E2  
 Y-MIN = 0.00000E0  
 Y-MAX = 0.30000E1

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : ASE/OUTDOOR;SITE: GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE;JUELICH

D

SITE - 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSF = 1/2) = 2 NUMBER OF DATA POINTS = 4

ID	NO	DATE	HOUR	I	ID/I	FLOW	TR	TI	IOELTAT	TH	T*	ETA	WIND	YSKY	
1	2	178.	5.301	11.301	928.01	0.0	35.6	24.40	22.1	9.0	26.6	0.02	0.81	4.5	0.0
1	2	178.	5.301	12.101	925.01	0.24	35.6	25.50	22.4	9.0	26.9	0.01	0.81	4.5	0.0
1	2	178.	5.301	12.401	917.01	0.0	35.4	26.30	22.4	8.8	27.0	0.01	0.80	4.5	0.0
1	2	178.	5.301	13.151	897.01	0.0	35.4	26.40	22.5	8.5	26.7	0.00	0.79	4.5	0.0


COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : ASE/INDOOR; SITE:GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE; JUELICH

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.810 0.0 #TSTAR  
 ETA=0.0 0.0 #TSTAR 0.0 (TSTAR\*\*2)

Q/M  
 --- 1-800 WATT  
 X-RIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

THE AVERAGED ETA  
 ETAO= 0.8025



**D**

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M<sup>2</sup>; FLUID: WATER ; SLOPE:45 DEGREE;HEIDELBERG

SITE = D COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE - 1/2) - 2 NUMBER OF DATA POINTS - 6

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.858- 0.42800\*STAR- 0.23000E-03ITSTAR\*\*2]M1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TM	TH-TA	QL	UM	WIND	TSKY	C-P
1	1	0.01	0.01	7.101	25.40	0.0	1.70	50.2	24.8	214.0	8.63	5.0	0.0	4186.7
1	2	0.01	0.01	7.401	26.70	0.0	3.30	70.0	43.3	411.0	7.49	5.0	0.0	4186.7
1	3	0.01	0.01	7.701	28.40	0.0	5.10	90.1	61.7	611.0	9.90	5.0	0.0	4186.7
1	4	0.01	0.01	7.301	27.90	0.0	5.30	90.0	62.1	633.0	10.19	5.0	0.0	4186.7
1	5	0.01	0.01	7.401	26.70	0.0	3.20	70.1	43.4	402.0	9.25	5.0	0.0	4186.7
1	6	0.01	0.01	7.301	26.20	0.0	1.70	50.1	23.9	204.0	8.54	5.0	0.0	4186.7

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M<sup>2</sup>; FLUID: WATER ; SLOPE:45 DEGREE;HEIDELBERG

LEAST SQUARE FIT


ETA=0.858- 0.42720\*STAR- 0.21841E-03ITSTAR\*\*2]M1

THE CORRECTED ETA0

ETA0= 0.8503

LEAST SQUARE FIT

ETA=0.858- 0.42720\*STAR- 0.21841E-03ITSTAR\*\*2]M1



ETA0  
 I=000 M11  
 X-RIN = 0.000000E0  
 X-MAX = 1.00000E2  
 Y-RIN = 0.00000E0  
 Y-MAX = 0.80000E1

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/OUTDOOR ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE:VARIABLE .HEIDELBERG

D

SITE = 0 COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 4

ID	NO	DATE	HOUR	I	IO/I	FLOW	TA	TI	IDELTA	TH	TM	ETA	WIND	TSKY
1	1	0. 01	0.0	0.0	0.0	43.8	25.30	0.0	7.4	32.2	0.08	0.87	5.0	0.0
1	2	0. 01	0.0	0.0	0.0	38.9	25.10	0.0	6.3	31.9	0.09	0.79	5.0	0.0
1	3	0. 01	0.0	0.0	0.0	36.4	26.00	0.0	8.5	37.2	0.12	0.80	5.0	0.0
1	4	0. 01	0.0	0.0	0.0	32.0	25.00	0.0	9.5	39.8	0.15	0.78	5.0	0.0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:GERMANY  
 REFERENCE AREA: 1.79 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE .HEIDELBERG

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT


ETA-0.858 0.0 \*TSTAR

ETA-0.858 0.428\*TSTAR 0.0001TSTAR\*\*2

0 0  
 — 1-000 H/IT  
 X-FIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-FIN = 0.00000E0  
 Y-MAX = 1.00000E0

THE AVERAGED ETA

ETA0= 0.8100



DK

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ;SITE: DENMARK  
 REFERENCE AREA: 1.78 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE. COPENHAGEN

SITE = DK COLLECTOR TYPE IEA- 1 TEST-PROCEDURE IASHRE/BSE = 1/21 = 2 NUMBER OF DATA POINTS = 4

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA-0.862- 0.35900\*STAR- 0.23000E-03ITSTAR\*\*2I=I

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TR	TN-TR	OL	UN	WIND	TSKY	C-P
1	1	0.	0.	35.301	22.00	35.2	0.59	35.5	12.9	87.2	6.75	5.0	20.0	4186.7
1	2	0.	0.	35.201	21.10	54.5	1.78	55.4	32.5	262.3	7.99	5.0	20.0	4186.7
1	3	0.	0.	36.001	21.80	71.9	2.78	73.3	48.7	419.0	8.47	5.0	20.0	4186.7
1	4	0.	0.	36.201	21.60	87.2	3.79	89.1	63.7	574.4	8.85	5.0	20.0	4186.7

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ;SITE: DENMARK  
 REFERENCE AREA: 1.78 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE. COPENHAGEN

LEAST SQUARE FIT


ETA-0.862- 0.35975\*STAR- 0.22941E-03ITSTAR\*\*2I=I

THE CORRECTED ETAO

ETAO= 0.8570

LEAST SQUARE FIT

ETA-0.857- 0.35975\*STAR- 0.22941E-03ITSTAR\*\*2I=I



HT LOSS COEFFICIENT  
 DELTA T  
 X-MIN = 0.00000E0  
 X-MAX = 1.00000E2  
 Y-MIN = 0.00000E0  
 Y-MAX = 0.80000E1

TH - TH DEGREE C

DK

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/OUTDOOR ; SITE: DENMARK  
 REFERENCE AREA: 1.78 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE. COPENHAGEN

SITE = DK COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE = 1/2) - 2 NUMBER OF DATA POINTS = 12

ID	NO	DATE	HOUR	I	ID/I	FLDH	TA	TI	IDELTAT	TH	TM	ETA	WIND	TSKY	
1	1	177	8	21	11.151	961.01	0.22	33.7	0.0	10.4	19.8	0.04	0.85	6.0	0.0
1	2	177	8	21	11.301	951.01	0.23	33.3	0.0	10.3	19.9	0.04	0.84	6.0	0.0
1	3	177	8	21	11.451	944.01	0.23	33.0	0.0	10.3	19.8	0.04	0.84	6.0	0.0
1	4	177	8	21	12.001	976.01	0.22	32.7	0.0	10.6	19.9	0.03	0.83	6.0	0.0
1	5	177	8	21	12.151	984.01	0.23	32.7	0.0	10.9	19.9	0.03	0.84	6.0	0.0
1	6	177	8	21	12.301	960.01	0.24	32.3	0.0	10.8	19.9	0.03	0.83	6.0	0.0
1	7	177	8	51	11.151	898.01	0.33	35.2	0.0	9.2	22.9	0.07	0.84	6.0	0.0
1	8	177	8	51	11.301	907.01	0.33	35.2	0.0	9.3	22.9	0.07	0.84	6.0	0.0
1	9	177	8	51	11.451	899.01	0.35	35.2	0.0	9.2	22.9	0.07	0.84	6.0	0.0
1	10	177	8	51	12.001	916.01	0.36	35.2	0.0	9.2	22.9	0.07	0.82	6.0	0.0
1	11	177	8	51	12.151	918.01	0.37	35.2	0.0	9.4	22.9	0.06	0.84	6.0	0.0
1	12	177	8	51	12.301	806.01	0.40	35.7	0.0	9.1	22.9	0.06	0.85	6.0	0.0

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE: DENMARK  
 REFERENCE AREA: 1.78 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE. COPENHAGEN


THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.862 0.0 M1STAR

ETA=0.862 0.359 M1STAR 0.0001 TSTAR\*\*2

THE AVERAGED ETA

ETA0= 0.8437



--- 1-800 HWT  
 X-MIN = 0.000000  
 X-MAX = 0.120000  
 Y-MIN = 0.000000  
 Y-MAX = 1.000000

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE +84YD00R/LOSS ; SITE: GREAT B.  
 REFERENCE AREA: 1.785 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE; CARDOIFF

**GB**

SITE = GB COLLECTOR TYPE IEA- 1 TEST-PROCEDURE (ASHRAE/95E - 1/2) - 2 NUMBER OF DATA POINTS = 11

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.840- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)|=1


I	ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TH	TH-TA	OL	UM	WIND	TSKY	C-P
1	1	1	0.0	0.01	0.0	0.0	0.0	0.0	0.0	9.5	65.0	6.84	0.0	0.0	4186.7
1	1	2	0.0	0.01	0.0	0.0	0.0	0.0	0.0	19.0	162.0	8.53	0.0	0.0	4186.7
1	1	3	0.0	0.01	0.0	0.0	0.0	0.0	0.0	20.7	138.0	6.67	0.0	0.0	4186.7
1	1	4	0.0	0.01	0.0	0.0	0.0	0.0	0.0	23.5	205.0	8.72	0.0	0.0	4186.7
1	1	5	0.0	0.01	0.0	0.0	0.0	0.0	0.0	24.2	165.0	6.82	0.0	0.0	4186.7
1	1	6	0.0	0.01	0.0	0.0	0.0	0.0	0.0	28.0	225.0	8.04	0.0	0.0	4186.7
1	1	7	0.0	0.01	0.0	0.0	0.0	0.0	0.0	31.5	250.0	7.94	0.0	0.0	4186.7
1	1	8	0.0	0.01	0.0	0.0	0.0	0.0	0.0	36.5	265.0	7.81	0.0	0.0	4186.7
1	1	9	0.0	0.01	0.0	0.0	0.0	0.0	0.0	38.5	304.0	7.88	0.0	0.0	4186.7
1	1	10	0.0	0.01	0.0	0.0	0.0	0.0	0.0	40.0	270.0	6.75	0.0	0.0	4186.7
1	1	11	0.0	0.01	0.0	0.0	0.0	0.0	0.0	48.5	375.0	7.73	0.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.840- 0.41514\*TSTAR- 0.30545E-04|TSTAR\*\*2|=1

LEAST SQUARE FIT

ETA=0.840- 0.41514\*TSTAR- 0.38545E-04|TSTAR\*\*2|=1





**NL**

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ;SITE:NETHERL  
 REFERENCE AREA: 1.791 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. DELFT

SITE = NL COLLECTOR TYPE IEA-1 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 3

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.780- 0.0 \*TSTAR- 0.0 ITSTAR\*\*2)=-1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TH	TH-TA	OL	UH	WIND	TSKY	C-P
1	1	0.01	0.0	34.401	25.70	0.0	0.55	37.3	11.6	79.7	6.88	5.0	20.0	4186.7
1	2	0.01	0.0	34.001	24.40	0.0	1.85	56.8	32.4	263.0	8.11	5.0	20.0	4186.7
1	3	0.01	0.0	34.801	24.00	0.0	3.14	77.5	53.5	459.0	8.58	5.0	20.0	4186.7

LEAST SQUARE FIT

ETA=0.780- 0.36513\*TSTAR- 0.22629E-031TSTAR\*\*2)=-1


THE CORRECTED ETA0

ETA0= 0.7671

LEAST SQUARE FIT

ETA=0.767- 0.36513\*TSTAR- 0.22629E-031TSTAR\*\*2)=-1

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ;SITE:NETHERL  
 REFERENCE AREA: 1.791 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. DELFT



COLLECTOR TYPE: IEA-1    TESTING PROCEDURE: OUTDOOR/LOSS, SITE: JAPAN  
 REFERENCE AREA: 1.790 M\*\*2; FLUID: WATER; SLOPE: 38 DEGREE; NAGOYA

J

SITE = J    COLLECTOR TYPE IEA-1    TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2    NUMBER OF DATA POINTS = 5

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.830- 0.0    \*TSTAR= 0.0    (TSTAR\*\*2)=1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA	TM	TM-TR	OL	UH	WIND	TSKY	C-P
1	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.5	65.0	7.75	0.0	0.0	4186.7
1	2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20.2	155.0	7.67	0.0	0.0	4186.7
1	3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	39.0	320.0	8.21	0.0	0.0	4186.7
1	4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.0	490.0	8.60	0.0	0.0	4186.7
1	5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	69.0	650.0	9.42	0.0	0.0	4186.7

COLLECTOR TYPE: IEA-1    TESTING PROCEDURE: OUTDOOR/LOSS, SITE: JAPAN  
 REFERENCE AREA: 1.790 M\*\*2; FLUID: WATER; SLOPE: 38 DEGREE; NAGOYA


LEAST SQUARE FIT

ETA=0.830- 0.40317\*TSTAR- 0.15742E-03(TSTAR\*\*2)=1

LEAST SQUARE FIT

ETA=0.830- 0.40317\*TSTAR- 0.15742E-03(TSTAR\*\*2)=1

--- 1.800 WATT  
 X-MIN = 0.00000E0  
 X-MAX = 1.00000E2  
 Y-MIN = 0.00000E0  
 Y-MAX = 0.80000E1



# USA

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:USA  
 REFERENCE AREA: 1.790 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE.MBS

SITE : USA      COLLECTOR TYPE IEA- 1      TEST-PROCEDURE (ASHRAE/BSE - 1/2) = 2      NUMBER OF DATA POINTS = 4

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA-0.830- 0.0    TSTAR- 0.0    (TSTAR\*\*2)M

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TA	TM-TA	QL	UM	WIND	TSKY	C-P	
1	1	0	0	0	0	0	0	0	0	19.5	140.0	7.18	5.0	0.0	4186.7
1	2	0	0	0	0	0	0	0	0	34.5	127.0	8.03	5.0	0.0	4186.7
1	3	0	0	0	0	0	0	0	0	56.0	102.0	8.96	5.0	0.0	4186.7
1	4	0	0	0	0	0	0	0	0	66.5	64.0	9.70	5.0	0.0	4186.7


LEAST SQUARE FIT

ETA-0.830- 0.34547\*TSTAR- 0.28918E-03(TSTAR\*\*2)M

LEAST SQUARE FIT

ETA-0.830- 0.34547\*TSTAR- 0.28918E-03(TSTAR\*\*2)M

COLLECTOR TYPE: IEA-1 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:USA  
 REFERENCE AREA: 1.790 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE.MBS



APPENDIX F

Data: IEA-2 Collector  
BSE Procedure  
EIR Procedure



COLLECTOR TYPE: ICA-2 , TESTING PROCEDURE : INDOOR/USE-SITE-BELGIUM  
 REFERENCE ARLR: 2.30 M\*\*2, FLUID: WATER , SLOPE: 7 DEGREE .ADMS **B**

SITE = B COLLECTOR TYPE ICA-2 TEST-PROCEDURE IASHRIE/USE = 1/21 = 2 NUMBER OF DATA POINTS = 7

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.609- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)\*I


I	ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA	TM	TM-TA	DL	UM=AREA	WIND	TSKY	C-P
1	1	1	0.0	0.0	40.021	20.00	31.1	0.62	30.8	10.8	105.8	9.77	0.0	0.0	4186.7
1	1	2	0.0	0.0	41.041	20.80	38.8	1.00	30.3	17.5	171.6	9.81	0.0	0.0	4186.7
1	1	3	0.0	0.0	41.691	18.60	38.8	1.00	30.3	19.8	174.3	8.80	0.0	0.0	4186.7
1	1	4	0.0	0.0	41.491	22.30	50.8	1.54	50.1	27.8	267.0	9.60	0.0	0.0	4186.7
1	1	5	0.0	0.0	42.741	19.50	53.1	2.02	51.6	32.1	361.0	11.25	0.0	0.0	4186.7
1	1	6	0.0	0.0	42.271	22.00	60.2	2.31	59.0	37.0	417.0	11.27	0.0	0.0	4186.7
1	1	7	0.0	0.0	42.291	22.80	70.4	3.08	68.9	46.1	530.0	11.50	0.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.609- 0.36791\*TSTAR- 0.29745E-031TSTAR\*\*2)\*I

LEAST SQUARE FIT

ETA=0.609- 0.36791\*TSTAR- 0.29745E-031TSTAR\*\*2)\*I



REFERENCE AREA: 2.32 0\*\*2; FLUID: WATER; SLOPE: 40 DEGREE

CH

SITE = CH COLLECTOR TYPE: IER-2 TEST-PROCEDURE: INSIRIE/BSE \* 1/21 - 0 NUMBER OF DATA POINTS = 21

ID	NO	DATE	HOUR	I	IO/I	FLOW	TR	TI	DELTA T	Ta	T*	ETR	WIND	TSKY
1	1	7.30	11.30	862.51	0.22	14.8	31.80	0.0	16.4	35.7	0.05	0.54	1.9	0.0
1	2	7.30	11.36	867.81	0.22	14.8	31.90	0.0	16.6	36.0	0.05	0.54	2.1	0.0
1	3	7.30	11.42	876.01	0.22	14.8	32.10	0.0	16.8	36.2	0.05	0.54	2.1	0.0
1	4	7.30	11.48	871.41	0.22	14.8	32.20	0.0	16.7	36.4	0.05	0.54	2.2	0.0
1	5	7.30	11.54	876.71	0.22	14.8	32.20	0.0	16.8	36.6	0.05	0.54	2.0	0.0
1	6	7.30	12.00	944.01	0.21	14.8	32.50	0.0	17.2	36.9	0.05	0.54	2.0	0.0
1	7	7.30	12.06	914.01	0.20	14.8	32.10	0.0	17.3	37.3	0.06	0.54	2.6	0.0
1	8	7.30	12.12	920.41	0.20	14.8	32.50	0.0	17.3	37.4	0.05	0.53	2.6	0.0
1	9	7.30	12.18	919.21	0.20	14.9	32.70	0.0	17.4	37.5	0.05	0.54	2.4	0.0
1	10	7.30	12.24	914.41	0.20	14.9	32.50	0.0	17.4	37.7	0.06	0.54	2.9	0.0
1	11	7.30	12.30	925.01	0.20	14.8	32.10	0.0	17.5	38.0	0.06	0.54	2.4	0.0
1	12	7.30	12.36	919.71	0.20	14.9	32.70	0.0	17.5	38.0	0.06	0.54	2.7	0.0
1	13	7.30	12.42	915.91	0.20	14.9	32.80	0.0	17.4	38.0	0.06	0.54	2.8	0.0
1	14	7.30	12.48	914.11	0.20	14.9	33.10	0.0	17.4	38.1	0.05	0.54	2.4	0.0
1	15	7.30	12.54	920.91	0.20	14.9	32.50	0.0	17.3	38.3	0.06	0.54	3.3	0.0
1	16	7.30	13.00	920.01	0.19	14.9	32.60	0.0	17.4	38.2	0.06	0.54	2.8	0.0
1	17	7.30	13.06	922.91	0.19	14.9	33.10	0.0	17.5	38.2	0.05	0.54	2.2	0.0
1	18	7.30	13.12	877.41	0.19	14.9	33.60	0.0	17.0	38.0	0.05	0.55	2.2	0.0
1	19	7.30	13.18	894.71	0.19	14.9	33.40	0.0	17.0	38.1	0.05	0.54	2.9	0.0
1	20	7.30	13.24	891.51	0.19	14.9	33.80	0.0	17.0	38.0	0.05	0.54	2.2	0.0
1	21	7.30	13.30	884.31	0.19	14.9	34.30	0.0	16.9	37.9	0.04	0.56	2.3	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT FOR DETAILS SEE APPENDIX A

ETA=0.0 0.0 \*1STAR

ETA=0.559 0.0 \*1STAR 0.0 (1STAR\*\*2)

THE AVERAGED ETA


ETAV= 0.5570

LEAST SQUARE FIT

ETA=0.566 - .478\*1STAR

ETA=0.645 \*\*\*\*\*1STAR \*\*\*\*\*1STAR\*\*2

COLLECTOR TYPE: IER-2; TESTING PROCEDURE: ETR, SITE: SHTZETZERLARD  
REFERENCE AREA: 2.32 0\*\*2; FLUID: WATER; SLOPE: 40. DIFFUSE-LOCH



CH

COLLECTOR TYPE: IEH-2, TESTING PROCEDURE: ETK, SITE:SWITZLERLAND  
 REFERENCE AREA: 2.32 M\*\*2, FLUID: WATER, SLOPE:40.DIFFUSL-LIGHT

SITE: CH COLLECTOR TYPE: IEH-1 TEST-PROCEDURE: INSHRRE/BSE = 1/2, NUMBER OF DATA POINTS:

ID	NO	DATE	HOUR	I	ID/I	FLOW	TA	TI	DELTA	TH	T*	ETR	WIND	TSKY	
1	1	178	8.14	5.48	11.61	0.88	14.4	12.50	0.0	-0.6	19.1	5.70	0.5	0.0	
1	2	178	8.14	5.54	12.41	0.88	14.5	12.50	0.0	-0.6	19.1	5.33	0.5	0.0	
1	3	178	8.14	5.54	12.41	0.88	14.5	12.50	0.0	-0.6	19.1	5.33	0.5	0.0	
1	4	178	8.14	6.06	11.11	0.87	14.5	12.60	0.0	-0.5	19.1	5.87	0.5	0.0	
1	5	178	8.14	6.12	12.01	0.88	14.5	12.60	0.0	-0.5	19.1	5.44	0.5	0.0	
1	6	178	8.14	6.18	13.61	0.93	14.5	12.50	0.0	-0.5	19.1	4.87	1.2	0.0	
1	7	178	8.14	6.24	17.71	0.89	14.4	12.50	0.0	-0.5	19.1	3.71	0.7	0.0	
1	8	178	8.14	6.30	18.41	0.90	14.4	12.60	0.0	-0.5	19.1	3.51	0.7	0.0	
1	9	178	8.14	6.36	21.61	0.91	14.5	12.60	0.0	-0.5	19.2	3.04	0.8	0.0	
1	10	178	8.14	6.42	21.61	0.92	14.5	12.60	0.0	-0.4	19.2	3.05	0.9	0.0	
1	11	178	8.14	6.48	29.61	0.92	14.5	12.60	0.0	-0.3	19.2	2.24	0.9	0.0	
1	12	178	8.14	6.54	32.11	0.91	14.4	12.60	0.0	-0.3	19.3	2.07	1.0	0.0	
1	13	178	8.14	7.00	32.51	0.93	14.4	12.70	0.0	-0.3	19.3	2.02	1.0	0.0	
1	14	178	8.14	7.06	31.51	0.92	14.5	12.70	0.0	-0.3	19.3	2.08	1.0	0.0	
1	15	178	8.14	7.12	34.51	0.92	14.4	12.80	0.0	-0.2	19.3	1.88	0.6	0.0	
1	16	178	8.14	7.18	34.71	0.91	14.4	12.90	0.0	-0.2	19.4	1.68	0.5	0.0	
1	17	178	8.14	7.24	35.61	0.92	14.4	13.00	0.0	-0.1	19.5	1.81	0.4	0.0	
1	18	178	8.14	7.30	41.61	0.93	14.4	13.10	0.0	-0.1	19.5	1.53	0.4	0.0	
1	19	178	8.14	7.36	54.51	0.96	14.4	13.10	0.0	0.1	19.5	1.18	0.5	0.0	
1	20	178	8.14	7.42	59.41	0.94	14.4	13.10	0.0	0.4	19.7	0.95	0.14	0.0	
1	21	178	8.14	7.48	75.01	0.92	14.4	13.20	0.0	0.5	19.8	0.65	0.19	0.0	
1	22	178	8.14	7.54	83.11	0.94	14.4	13.30	0.0	0.5	19.8	0.78	0.20	0.0	
1	23	178	8.14	8.00	110.91	0.94	13.8	13.20	0.0	1.0	19.5	0.60	0.23	1.1	0.0
1	24	178	8.14	8.06	109.61	0.93	14.0	13.30	0.0	1.1	20.0	0.61	0.27	1.3	0.0
1	25	178	8.14	8.12	112.41	0.94	14.0	13.30	0.0	1.2	20.0	0.60	0.28	1.3	0.0
1	26	178	8.14	8.18	122.91	0.93	14.1	13.40	0.0	1.4	20.1	0.55	0.29	1.2	0.0
1	27	178	8.14	8.24	123.71	0.93	14.2	13.40	0.0	1.4	20.1	0.54	0.32	1.2	0.0
1	28	178	8.14	8.30	128.71	0.93	14.1	13.70	0.0	1.5	20.3	0.51	0.33	1.1	0.0
1	29	178	8.14	8.36	129.91	0.90	14.1	13.90	0.0	1.6	20.5	0.51	0.33	0.9	0.0
1	30	178	8.14	8.42	144.01	0.94	14.1	14.10	0.0	1.7	20.6	0.45	0.33	1.0	0.0
1	31	178	8.14	8.48	154.91	0.94	14.1	14.20	0.0	2.0	20.0	0.43	0.34	1.3	0.0
1	32	178	8.14	8.54	155.41	0.93	14.1	14.40	0.0	2.2	20.9	0.39	0.36	1.0	0.0
1	33	178	8.14	9.00	168.71	0.93	14.1	14.90	0.0	2.3	21.1	0.37	0.37	0.6	0.0
1	34	178	8.14	9.06	166.61	0.92	14.0	14.80	0.0	2.4	21.1	0.38	0.38	0.8	0.0
1	35	178	8.14	9.12	183.61	0.92	14.0	15.20	0.0	2.6	21.2	0.33	0.37	0.5	0.0
1	36	178	8.14	9.18	194.51	0.92	14.0	15.40	0.0	2.8	21.3	0.30	0.39	0.7	0.0
1	37	178	8.14	9.24	213.11	0.92	14.0	15.60	0.0	3.1	21.6	0.28	0.39	0.7	0.0
1	38	178	8.14	9.30	205.91	0.92	14.0	15.70	0.0	3.3	21.6	0.29	0.43	0.6	0.0
1	39	178	8.14	9.36	194.41	0.93	14.0	15.70	0.0	3.2	21.6	0.30	0.44	0.6	0.0

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT FOR DETAILS SEE APPENDIX A

ETA=0.0 0.0 \*TSTAR

ETA=0.465 0.322\*TSTAR 0.0 (TSTAR\*\*2)

LEAST SQUARE FIT

ETA=0.465 0.322\*TSTAR



**D**

COLLECTOR TYPE: IEA-2 , TESTING PROCEDURE : BSE/OUTDOOR ;SITE:GERMANY  
 REFERENCE AREA: 2.300 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE, JUELICH

SITE = 0 COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/USE = 1/2) = 2 NUMBER OF DATA POINTS = 4

ID	NO	DATE	HOUR	I	IO/I	FLOW	TR	TI	IOELTAT	TA	TM	ETR	WIND	TSKY	
1	1	177	9.271	10.501	858.01	0.27	17.1	15.70	0.6	15.0	16.1	0.00	0.56	2.5	0.0
1	2	177	9.271	0.0	857.01	0.28	17.1	15.60	8.7	15.0	16.2	0.01	0.56	2.5	0.0
1	3	177	9.271	0.0	853.01	0.28	17.2	16.00	8.9	15.1	16.4	0.00	0.56	2.5	0.0
1	4	177	9.271	11.301	875.01	0.28	17.3	16.90	10.2	15.0	17.7	0.01	0.55	2.5	0.0


COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/BSE ;SITE:GERMANY  
 REFERENCE AREA: 2.300 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE, JUELICH

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.560 0.0 \*TSTAR  
 ETA=0.560 0.312\*TSTAR 0.0001TSTAR\*\*2

THE AVERAGED ETA

ETA0= 0.5575



--- 1.800 M\*\*2  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/BSE ; SITE:GERMANY  
 REFERENCE AREA: 2.300 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. JUELICH

D

SITE = 0 COLLECTOR TYPE IEA- 2 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 8

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.565- 0.31200\*STAR- 0.10000E-03(1STAR\*\*2)M

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TH	TH-TR	OL	UM*AREA	WIND	TSKY	C-P
1	1	177.10.281	8.151	16.701	19.00	0.0	1.30	0.0	11.6	90.9	6.85	2.5	0.0	4186.7
1	2	177.10.281	8.301	16.511	19.50	0.0	1.25	0.0	10.9	86.7	7.92	2.5	0.0	4186.7
1	3	177.10.281	9.301	16.451	19.30	0.0	3.30	0.0	28.0	227.9	8.11	2.5	0.0	4186.7
1	4	177.10.281	10.001	16.641	19.50	0.0	3.30	0.0	27.0	230.6	8.27	2.5	0.0	4186.7
1	5	177.10.281	12.151	17.401	19.30	0.0	5.50	0.0	49.2	431.0	8.70	2.5	0.0	4186.7
1	6	177.10.281	12.451	17.301	19.40	0.0	5.90	0.0	49.0	429.0	8.70	2.5	0.0	4186.7
1	7	177.10.281	13.301	16.581	19.30	0.0	8.70	0.0	65.8	605.6	9.14	2.5	0.0	4186.7
1	8	177.10.281	14.001	16.541	19.60	0.0	8.70	0.0	65.5	604.0	9.18	2.5	0.0	4186.7

LEAST SQUARE FIT

ETA=0.565- 0.31222\*STAR- 0.13718E-03(1STAR\*\*2)M


THE CORRECTED ETA

ETA0 = 0.5620

LEAST SQUARE FIT

ETA=0.562- 0.31222\*STAR- 0.13718E-03(1STAR\*\*2)M

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/BSE ; SITE:GERMANY  
 REFERENCE AREA: 2.300 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. JUELICH



COLLECTOR TYPE: IEA-2 , TESTING PROCEDURE : BSE/INDOOR , SITE:GERMANY ,  
 REFERENCE AREA: 2.30 M\*\*2, FLUID: WATER , SLOPE:45 DEGREE,HEIDELBERG

D

SITE = 0 COLLECTOR TYPE IEA- 2 TEST-PROCEDURE IASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 18

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.510- 0.26700\*TSTAR- 0.16000E-03ITSTAR\*\*2)M1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA	TM	TA-TA	QL	UM	AREAI	WIND	TSKY	C-P
1	1	0	0	0	14.30	20.10	0.0	1.10	29.5	9.5	62.0	6.53	0.0	0.0	4186.7
1	2	0	0	0	13.60	20.80	0.0	2.30	39.0	18.2	126.0	6.92	0.0	0.0	4186.7
1	3	0	0	0	12.60	23.90	0.0	8.40	77.9	52.0	416.0	8.00	0.0	0.0	4186.7
1	4	0	0	0	20.50	24.20	0.0	5.50	75.4	53.2	441.0	8.29	0.0	0.0	4186.7
1	5	0	0	0	19.50	25.00	0.0	4.40	68.2	43.2	346.0	8.01	0.0	0.0	4186.7
1	6	0	0	0	19.60	23.20	0.0	6.90	85.0	62.8	526.0	8.38	0.0	0.0	4186.7
1	7	0	0	0	19.90	22.40	0.0	2.50	48.7	26.3	199.0	7.57	0.0	0.0	4186.7
1	8	0	0	0	20.30	22.40	0.0	1.50	39.4	17.0	122.0	7.18	0.0	0.0	4186.7
1	9	0	0	0	20.30	22.50	0.0	0.60	30.2	7.7	51.0	6.62	0.0	0.0	4186.7
1	10	0	0	0	20.10	22.50	0.0	3.60	58.3	36.8	289.0	8.07	0.0	0.0	4186.7
1	11	0	0	0	20.60	19.40	0.0	0.50	25.4	6.0	48.0	6.00	0.0	0.0	4186.7
1	12	0	0	0	20.40	20.10	0.0	1.30	34.8	14.7	105.0	7.14	0.0	0.0	4186.7
1	13	0	0	0	20.50	20.90	0.0	2.10	43.0	22.1	172.0	7.78	0.0	0.0	4186.7
1	14	0	0	0	20.00	22.10	0.0	3.00	53.1	31.0	241.0	7.77	0.0	0.0	4186.7
1	15	0	0	0	19.60	23.40	0.0	4.10	62.7	39.3	320.0	8.14	0.0	0.0	4186.7
1	16	0	0	0	19.30	24.50	0.0	5.30	72.5	48.0	402.0	8.38	0.0	0.0	4186.7
1	17	0	0	0	19.10	24.50	0.0	6.50	82.0	57.5	488.0	8.49	0.0	0.0	4186.7
1	18	0	0	0	18.80	25.40	0.0	7.20	85.8	61.4	525.0	8.55	0.0	0.0	4186.7

LEAST SQUARE FIT


ETA=0.510- 0.26878\*TSTAR- 0.12010E-03ITSTAR\*\*2)M1

THE CORRECTED ETA

ETA0= 0.5049

LEAST SQUARE FIT

ETA=0.505- 0.29878\*TSTAR- 0.12010E-03ITSTAR\*\*2)M1



COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/OUTDOOR ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID: WATER ; SLOPE-VARIABLE : HEIDELBERG **D**

SITE = D COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 6

ID	NO	DATE	HOUR	ID	ID/V	FLOW	TR	T1	DELTA T	TM	T*	ETA	WIND	TSKY
1	1	1	0.01	0.0	813.01	0.0	64.0	0.0	3.4	28.8	0.12	0.45	4.0	0.0
1	2	1	0.01	0.0	862.01	0.0	62.9	0.0	3.6	29.3	0.10	0.45	4.0	0.0
1	3	1	0.01	0.0	663.01	0.0	34.2	18.50	5.8	20.9	0.04	0.53	4.0	0.0
1	4	1	0.01	0.0	715.01	0.0	44.9	19.30	4.7	20.4	0.02	0.52	4.0	0.0
1	5	1	0.01	0.0	714.01	0.0	45.1	19.60	4.4	20.2	0.01	0.49	4.0	0.0
1	6	1	0.01	0.0	776.01	0.0	44.7	20.40	4.9	20.5	0.00	0.49	4.0	0.0


COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/INDOOR ; SITE:GERMANY  
 REFERENCE AREA: 2.30 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE-HEIDELBERG

THE AUTHOR HAS GIVEN THE FOLLOWING DATA F1T

ETA=0.510 0.0 \*TSTAR  
 ETA=0.510 0.267\*TSTAR 0.000(TSTAR\*\*2)

UID  
 X-MIN = 0.00000E0  
 X-MAX = 0.12000E1  
 Y-MIN = 0.00000E0  
 Y-MAX = 1.00000E0

THE AVERAGED ETA  
 ETAA= 0.4883



COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/INDOOR ;SITE: DENMARK  
 REFERENCE AREA: 2.32 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE, COPENHAGEN

DK

SITE = DK COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 3

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.620- 0.36600\*TSTAR- 0.17000E-03ITSTAR\*\*2]M]

ID	NO	DATE	HOUR	FLOW	TA	TJ	DELTA T	TH	TH-TA	OL	UM*AREA	WIND	TSKY	C-P
1	1	0.01	0.0	0.0	0.0	0.0	0.0	11.5	102.0	8.87	5.0	0.0	4186.7	1
1	2	0.01	0.0	0.0	0.0	0.0	0.0	29.5	278.0	9.42	5.0	0.0	4186.7	1
1	3	0.01	0.0	0.0	0.0	0.0	0.0	46.7	477.0	10.21	5.0	0.0	4186.7	1

LEAST SQUARE FIT

ETA=0.620- 0.36627\*TSTAR- 0.16655E-03ITSTAR\*\*2]M]


THE CORRECTED ETAO

ETAO= 0.6299

LEAST SQUARE FIT

ETA=0.630- 0.36627\*TSTAR- 0.16655E-03ITSTAR\*\*2]M]

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/INDOOR ;SITE: DENMARK  
 REFERENCE AREA: 2.32 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE, COPENHAGEN



COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE :OUTDOOR/LOSS ;SITE: SPAIN  
 REFERENCE AREA: 2.31 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. MADRID

E

SITE = E COLLECTOR TYPE IEA- 2 TEST-PROCEDURE IASHRAE/GSE = 1/21 \* 2 NUMBER OF DATA POINTS = 8

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.551- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)\*

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA	TM	TM-TR	QL	UN*AREA	WIND	ISKY	C-P
1	1	0.	0.	0.0	0.0	0.0	0.0	0.0	16.0	130.0	8.13	0.0	0.0	4186.7
1	2	0.	0.	0.0	0.0	0.0	0.0	0.0	22.2	190.0	8.56	0.0	0.0	4186.7
1	3	0.	0.	0.0	0.0	0.0	0.0	0.0	25.0	212.0	8.48	0.0	0.0	4186.7
1	4	0.	0.	0.0	0.0	0.0	0.0	0.0	30.0	232.0	7.73	0.0	0.0	4186.7
1	5	0.	0.	0.0	0.0	0.0	0.0	0.0	39.0	320.0	8.21	0.0	0.0	4186.7
1	6	0.	0.	0.0	0.0	0.0	0.0	0.0	43.8	340.0	7.76	0.0	0.0	4186.7
1	7	0.	0.	0.0	0.0	0.0	0.0	0.0	49.4	398.0	8.06	0.0	0.0	4186.7
1	8	0.	0.	0.0	0.0	0.0	0.0	0.0	52.8	449.0	8.50	0.0	0.0	4186.7


LEAST SQUARE FIT

ETA=0.551- 0.36210\*TSTAR--0.14316E-04(TSTAR\*\*2)\*

LEAST SQUARE FIT

ETA=0.551- 0.36210\*TSTAR--0.14316E-04(TSTAR\*\*2)\*

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE :OUTDOOR/LOSS ;SITE: SPAIN  
 REFERENCE AREA: 2.31 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. MADRID



1-4000 WATT  
 X-MIN = 0.000000E0  
 X-MAX = 1.000000E2  
 Y-MIN = 0.000000E0  
 Y-MAX = 0.800000E1

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/OUTDOOR ; SITE: DENMARK  
 REFERENCE AREA: 2.32 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE; COPENHAGEN


SITE = DK COLLECTOR TYPE IEA- 2 TEST-PROCEDURE IASHRE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 12

ID	NO	DATE	HOUR	I	ID/1	FLOW	TR	TI	IDELTAT	TR	Y*	EPA	WIND	TSKY
1	1	177	8	21	11.151	961.01	0.23	35.8	9.2	25.4	0.04	0.62	4.0	-7.5
1	2	177	8	21	11.301	951.01	0.23	35.8	9.1	25.4	0.04	0.63	4.0	-7.5
1	3	177	8	21	11.451	941.01	0.23	35.8	9.0	25.3	0.04	0.62	4.0	-7.5
1	4	177	8	21	12.001	976.01	0.22	35.8	9.3	25.5	0.04	0.63	4.0	-7.5
1	5	177	8	21	12.151	984.01	0.23	35.8	9.5	25.5	0.03	0.63	4.0	-7.5
1	6	177	8	21	12.301	980.01	0.24	35.8	9.4	25.5	0.03	0.63	4.0	-7.5
1	7	177	8	51	11.151	898.01	0.33	41.8	7.0	27.8	0.07	0.59	4.0	-7.5
1	8	177	8	51	11.301	907.01	0.33	41.8	7.1	27.8	0.07	0.59	4.0	-7.5
1	9	177	8	51	11.451	898.01	0.35	41.9	7.1	27.8	0.07	0.59	4.0	-7.5
1	10	177	8	51	12.001	916.01	0.43	41.2	7.3	28.0	0.07	0.60	4.0	-7.5
1	11	177	8	51	12.151	918.01	0.37	41.0	7.4	28.0	0.07	0.61	4.0	-7.5
1	12	177	8	51	12.301	886.01	0.40	41.0	7.3	27.9	0.07	0.61	4.0	-7.5

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : BSE/INDOOR ; SITE: DENMARK  
 REFERENCE AREA: 2.32 M\*\*2; FLUID: WATER ; SLOPE: 45 DEGREE; COPENHAGEN

ETA=0.620 0.440\*1STAR  
 ETA=0.620 0.360\*1STAR 0.0001TSTAR\*\*2

THE AVERAGED ETA  
 ETA0= 0.6025



UW  
 I=800 MH1  
 X-RIN = 0.000000  
 X-MAX = 0.1200001  
 Y-RIN = 0.0000000  
 Y-MAX = 1.0000000

COLLECTOR TYPE: IEA-2 , TESTING PROCEDURE : OUTDOOR/LOSS , SITE: GREAT B.  
 REFERENCE AREA: 2.315 M\*\*2, FLUID: WATER , SLOPE: 45 DEGREE, CARDIFF

GB

SITE \* GB COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/BSE \* 1/2) = 2 NUMBER OF DATA POINTS = 13

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.550- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)\*I


ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA	TM	TM-TR	OL	UM*AREA	HIND	TSKY	C-P
1	1	0	0	0	0	0	0	0	23.0	211.0	9.17	0.0	0.0	4186.7
1	2	0	0	0	0	0	0	0	24.0	225.0	9.38	0.0	0.0	4186.7
1	3	0	0	0	0	0	0	0	27.0	250.0	9.26	0.0	0.0	4186.7
1	4	0	0	0	0	0	0	0	33.3	304.0	9.13	0.0	0.0	4186.7
1	5	0	0	0	0	0	0	0	35.2	268.0	7.61	0.0	0.0	4186.7
1	6	0	0	0	0	0	0	0	35.9	295.0	8.22	0.0	0.0	4186.7
1	7	0	0	0	0	0	0	0	35.8	337.0	9.41	0.0	0.0	4186.7
1	8	0	0	0	0	0	0	0	41.5	380.0	9.16	0.0	0.0	4186.7
1	9	0	0	0	0	0	0	0	46.0	395.0	8.59	0.0	0.0	4186.7
1	10	0	0	0	0	0	0	0	49.0	430.0	8.78	0.0	0.0	4186.7
1	11	0	0	0	0	0	0	0	52.0	460.0	8.85	0.0	0.0	4186.7
1	12	0	0	0	0	0	0	0	55.5	510.0	9.33	0.0	0.0	4186.7
1	13	0	0	0	0	0	0	0	57.0	482.0	8.46	0.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.550- 0.4045I\*TSTAR--0.43102E-04I\*TSTAR\*\*2)\*I

LEAST SQUARE FIT

ETA=0.550- 0.4045I\*TSTAR--0.43102E-04I\*TSTAR\*\*2)\*I





COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE :OUTDOOR/LOSS ;SITE: JAPAN  
 REFERENCE AREA: 2.297 M\*\*2; FLUID: WATER ; SLOPE:38 DEGREE, NAGOYA

SITE = J COLLECTOR TYPE IEA-2 TEST-PROCEDURE (ASHRAE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 5

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.564- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)=1

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TA	TA-TR	DL	UM	AREA	WIND	TSKY	C-P
1	1	0.0	0.0	0.0	0.0	0.0	0.0	8.6	55.0	6.40	0.0	0.0	0.0	0.0	4186.7
1	2	0.0	0.0	0.0	0.0	0.0	0.0	20.4	160.0	7.84	0.0	0.0	0.0	0.0	4186.7
1	3	0.0	0.0	0.0	0.0	0.0	0.0	39.5	310.0	7.85	0.0	0.0	0.0	0.0	4186.7
1	4	0.0	0.0	0.0	0.0	0.0	0.0	57.5	495.0	8.61	0.0	0.0	0.0	0.0	4186.7
1	5	0.0	0.0	0.0	0.0	0.0	0.0	70.5	665.0	9.49	0.0	0.0	0.0	0.0	4186.7

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE :OUTDOOR/LOSS ;SITE: JAPAN  
 REFERENCE AREA: 2.297 M\*\*2; FLUID: WATER ; SLOPE:38 DEGREE, NAGOYA


LEAST SQUARE FIT

ETA=0.564- 0.27931\*TSTAR- 0.18104E-031TSTAR\*\*2)=1

LEAST SQUARE FIT

ETA=0.564- 0.27931\*TSTAR- 0.18104E-031TSTAR\*\*2)=1

W U  
 --- 1-000 WRIT  
 X-MIN = 0.00000E0  
 X-MAX = 1.00000E2  
 Y-MIN = 0.00000E0  
 Y-MAX = 0.00000E1



COLLECTOR TYPE: IEA-2 , TESTING PROCEDURE : BSE/OUTDOOR ,SITE:NETHERL NL  
 REFERENCE AREA: 2.315 M\*\*2, FLUID: WATER , SLOPE:45 DEGREE, DELFT

SITE = NL COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHRAE/BSE = 1/2J \* 2 NUMBER OF DATA POINTS = 4

ID	NO	DATE	HOUR	ID/1	FLOW	TA	TI	DELTA T	TM	TS	ETA	HIND	TSKY		
1	1	177	5.25	13.00	969.01	0.13	28.6	19.70	0.0	10.6	20.7	0.01	0.57	8.5	0.0
1	2	177	5.25	14.00	955.01	0.13	28.7	19.80	0.0	10.2	22.6	0.03	0.56	8.5	0.0
1	3	177	5.25	14.30	944.01	0.13	28.7	20.70	0.0	9.8	24.9	0.05	0.54	8.5	0.0
1	4	177	5.25	15.15	936.01	0.13	28.6	20.90	0.0	9.4	29.8	0.10	0.53	8.5	0.0


THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.560 0.0 \*TSTAR

ETA=0.560 0.0 \*TSTAR 0.0 (TSTAR\*\*2)

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/USE ;SITE:NETHERL  
 REFERENCE AREA: 2.315 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE, DELFT

CI 01  
 I=480 HRTT  
 X-MIN = 0.000000  
 X-MAX = 0.120000  
 Y-MIN = 0.000000  
 Y-MAX = 1.000000



THE AVERAGED ETA

ETA0= 0.5492

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/BSE ;SITE:NETHERL NL  
 REFERENCE AREA: 2.315 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. DELFT

SITE = NL COLLECTOR TYPE IEA-2 TEST-PROCEDURE IASHARE/BSE = 1/2) = 2 NUMBER OF DATA POINTS = 4

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.560- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)M

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TA	TA-TR	TA	TA-TR	OL	UA	AREA	U	WIND	TSKY	C-P
1	1	J 0. 0.	0.0	26.30	21.80	0.0	0.29	26.2	4.4	31.9	7.25	5.0	0.0	4186.7	1	5.0	0.0	4186.7
1	2	I 0. 0.	0.0	27.20	23.10	0.0	0.97	36.3	13.2	110.0	8.33	5.0	0.0	4186.7	1	5.0	0.0	4186.7
1	3	I 0. 0.	0.0	27.40	22.60	0.0	2.44	54.1	31.5	278.0	8.63	5.0	0.0	4186.7	1	5.0	0.0	4186.7
1	4	I 0. 0.	0.0	26.90	23.10	0.0	3.98	71.0	47.9	449.0	9.37	5.0	0.0	4186.7	1	5.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.560- 0.32217\*TSTAR- 0.19231E-03(TSTAR\*\*2)M


THE CORRECTED ETAO

ETAO= 0.5636

LEAST SQUARE FIT

ETA=0.564- 0.32217\*TSTAR- 0.19231E-03(TSTAR\*\*2)M

COLLECTOR TYPE: IEA-2 ; TESTING PROCEDURE : INDOOR/BSE ;SITE:NETHERL  
 REFERENCE AREA: 2.315 M\*\*2; FLUID: WATER ; SLOPE:45 DEGREE. DELFT



Y=0  
 X-MIN = 0.000000E  
 X-MAX = 1.000000E2  
 Y-MIN = 0.000000E  
 Y-MAX = 0.000000E1

COLLECTOR TYPE: IER-2 ; TESTING PROCEDURE : INDOOR/BSE , SITE: USA  
 REFERENCE AREA: 2.290 M\*\*2, FLUID: WATER , SLOPE: 27 DEGREE. NBS

SITE : USA COLLECTOR TYPE IER- 2 TEST-PROCEDURE IASHRAE/BSE = 1/21 = 2 NUMBER OF DATA POINTS = 15

USA

THE AUTHOR HAS GIVEN THE FOLLOWING DATA FIT

ETA=0.583- 0.0 \*TSTAR- 0.0 (TSTAR\*\*2)\*I

ID	NO	DATE	HOUR	FLOW	TA	TI	DELTA T	TM	TR-TR	DL	UM	AREAI	UIND	TSKY	C-P
1	1	0	0	0	45.301	20.59	40.3	0.89	40.8	20.2	157.0	7.77	7.2	0.0	4186.7
1	2	0	0	0	45.301	20.68	40.3	0.90	40.8	20.1	170.0	8.45	8.0	0.0	4186.7
1	3	0	0	0	45.301	20.83	40.4	0.89	40.8	20.0	168.0	8.39	5.9	0.0	4186.7
1	4	0	0	0	45.101	20.79	40.4	0.89	40.9	20.0	156.0	7.80	6.7	0.0	4186.7
1	5	0	0	0	44.801	20.89	55.5	1.56	56.3	35.4	292.0	8.25	9.0	0.0	4186.7
1	6	0	0	0	44.801	20.96	55.4	1.57	56.2	35.3	294.0	8.34	10.2	0.0	4186.7
1	7	0	0	0	44.801	21.14	55.4	1.60	56.2	35.1	300.0	8.56	9.5	0.0	4186.7
1	8	0	0	0	44.801	21.42	55.3	1.59	56.1	34.7	295.0	8.52	8.1	0.0	4186.7
1	9	0	0	0	44.401	21.69	78.1	2.65	79.4	57.8	492.0	8.52	7.4	0.0	4186.7
1	10	0	0	0	44.401	21.88	78.1	2.62	79.4	57.6	487.0	8.46	7.0	0.0	4186.7
1	11	0	0	0	44.601	21.82	78.0	2.74	79.4	57.6	512.0	8.89	8.5	0.0	4186.7
1	12	0	0	0	44.401	21.67	78.0	2.75	79.4	57.7	511.0	8.85	9.9	0.0	4186.7
1	13	0	0	0	43.801	21.39	90.3	3.75	92.2	70.8	688.0	9.72	7.8	0.0	4186.7
1	14	0	0	0	43.901	21.44	90.4	3.71	92.3	70.8	682.0	9.63	8.5	0.0	4186.7
1	15	0	0	0	43.901	21.34	90.4	3.76	92.3	70.9	691.0	9.74	9.9	0.0	4186.7
1	16	0	0	0	43.801	21.54	90.4	3.73	92.3	70.9	684.0	9.64	7.0	0.0	4186.7

LEAST SQUARE FIT

ETA=0.583- 0.32530\*TSTAR- 0.12070E-03(TSTAR\*\*2)\*I

LEAST SQUARE FIT

ETA=0.583- 0.32530\*TSTAR- 0.12070E-03(TSTAR\*\*2)\*I

